

BSC ISI Flexure Attachment Design

Kick-off Meeting

Ken Mason

Nick Hunter-Jones

03 APR 2009



BSC ISI Flexure Attachment Design

- Problems with current design

30 The flexure rod with the shim attached should sit more securely in the spring cut out; the design should avoid misplacement during installation and shouldn't allow any movement later on-- more than friction should hold these shims in place against the spring

17 Tooling to hold this rod perpendicular to the top of the bracket to make sure flexure rod is straight as the spring is released onto the flexure rod would be helpful in aligning the flexure rod-- currently using parallels and trying to eyeball whether the flexure rod is straight up and down

Current Design




LIGO-G0900292-v2

HAM ISI Design



Flexure Termination





Advanced LIGO Single Stage HAM FDR1 Document G-0701156-00-R

68

Goals for Redesign



- Goals
 1. Use existing flexure and maintain its location
 2. Add round shims or ground spacers to move ZMP?
 3. Positive locking
 4. Tooling to check perpendicularity of flexure rod

Nut on Top and Bottom



LIGO-G0900292-v2

Solid Flex Mount / Nut on Bottom



LIGO-G0900292-v2