



LIGO Laboratory / LIGO Scientific Collaboration

LIGO-T080153-A-D

Advanced LIGO

08/12/2008

A Proposed Laser Incident Threshold Level

Peter King

Distribution of this document:
LIGO Science Collaboration

This is an internal working note
of the LIGO Project.

California Institute of Technology
LIGO Project – MS 18-34
1200 E. California Blvd.
Pasadena, CA 91125
Phone (626) 395-2129
Fax (626) 304-9834
E-mail: info@ligo.caltech.edu

Massachusetts Institute of Technology
LIGO Project – NW22-295
185 Albany St
Cambridge, MA 02139
Phone (617) 253-4824
Fax (617) 253-7014
E-mail: info@ligo.mit.edu

LIGO Hanford Observatory
P.O. Box 159
Richland WA 99352
Phone 509-372-8106
Fax 509-372-8137

LIGO Livingston Observatory
P.O. Box 940
Livingston, LA 70754
Phone 225-686-3100
Fax 225-686-7189

1 Executive Summary

This document presents the rationale and assumptions used to justify the proposed increase of the laser incident threshold power level. The proposed change is that the incident threshold power level be **increased from 100 μW to 2 mW** for all laser wavelengths within the LIGO Laboratory. This limit is derived from the current ANSI Z136.1—2007 American National Standard for Safe Use of Lasers. The ANSI standard is a factor of 10 below any known damage threshold.

The maximum permissible exposure level is calculated for the 200 W Advanced LIGO Laser and compared with that for a small source of the same wavelength. In all cases, the small source maximum permissible exposure level is found to be smaller than that of the Advanced LIGO Laser. The small source limit, with practical considerations discussed in this document, is adopted as the laser incident threshold power level.

2 Introduction

For Initial LIGO the laser incident threshold level for errant beams was set to be 100 μW . If a beam was found to be above this level, then a laser incident was deemed to have occurred. The laser would then be shutdown by the Laser Safety Officer and restoring the laser required LIGO Directorate approval.

With the advent of the 200 W Advanced LIGO Laser, it seems timely to revisit the 100 μW limit. 100 μW corresponds to the transmission of a 0.5 ppm mirror which is difficult, if not impossible, to obtain.

It should be noted that all stray beams and scattered light should be dumped or contained as a matter of good practice. It is proposed that the laser incident threshold level be set without regard to laser safety eyewear. This avoids a situation where a 200 W beam is deemed “safe” because people should be wearing laser safety eyewear. Most people would agree that a stray 200 W beam is hardly safe.

This document proposes that a new laser incident threshold be set. For the time being only one wavelength, 1064 nm, is being considered.

3 Properties of the Human Eye

3.1 Focal Length

The commonly accepted value for the focal length of a human eye is approximately 17 mm.

3.2 Pupil Diameter

Various measurements of the pupil diameter can be found in the literature. Whether under the influence of drugs, low light conditions or bright light conditions a good working number for the pupil diameter is 7.0 mm. This number is the one adopted by the ANSI Z136.1-2007 standard.

4 Calculation of Laser Parameters

In working out the Accessible Emission Limit (AEL) or the Maximum Permissible Exposure (MPE), the laser concerned must be categorised as either a small source or an extended source. By definition, a small source is one that subtends an angle, α , at the retina of less than the limiting angular subtense α_{\min} (1.5 mrad).

4.1 Assumptions

For the purposes of this note, the distance used to determine the nature of the source is 100 mm. This happens to be the same distance used for the hazard classification of a laser. Although there are not enough 200 W Advanced LIGO Lasers in existence to get a good range for the output beam size of the laser, it is expected that the beam waist of the laser will range from 150 μm to 250 μm . Anecdotally this has been the case with the Initial LIGO 10 W lasers and the many NPRO lasers within the Project. Other quantities such as the beam diameter, beam divergence and angular subtense are derived from this assumption.

4.2 Beam Size at Evaluation Distance

For a Gaussian beam of wavelength λ , the beam radius w is given at any location z by the well-known formula

$$w = w_0 \sqrt{1 + \left(\frac{\lambda z}{\pi w_0^2} \right)^2}$$

4.3 Full Angle Beam Divergence

The full angle beam divergence θ , is given by

$$\theta = \frac{2\lambda}{\pi w_0}$$

4.4 Angular Subtense

The angular subtense α for a Lambertian surface, is given by

$$\alpha = \frac{D_L}{r}$$

A Lambertian surface is one for which the intensity of scattered light appears with the same brightness irrespective of the observer's angle of view. For the calculations within this document, D_L is simply taken to be equal to $2w$. Figure 1 shows the relationship between the various quantities and the human eye.




Figure 1. The relationship between the source size D_L , the distance from the source to the eye r , the angular subtense α and the human eye.

4.5 Laser Parameters

Table 1 lists the **assumed** and **derived** laser parameters used in calculating the AEL and MPE values.

beam waist, w_0 (μm)	150	250
full angle beam divergence, θ (mrad)	4.516	2.709
beam diameter, $2w$ (μm)	542	568.7
angular subtense, α (mrad)	5.421	5.687
source type	extended	extended

Table 1. The laser parameters used in calculation of the AEL and MPE for an evaluation distance of 100 mm.

5 Eye Damage Threshold Level

Strictly speaking, eye damage in this context means retina damage. Finding references that state the eye damage threshold level has proven to be difficult. Most papers dealing with eye damage focus on the biological consequences and symptoms, not on exposure limits. It so happens that the ANSI-Z136.1 standard is a good reference, it being the result of a number of different experiments. This technical note bases its numbers on the 2007 ANSI standard and the references listed at the end of this note.

It should be noted that the ANSI exposure limits are a factor of 10 **below** any known damage threshold level.

5.1 Pre-retinal Absorption Correction Factor C_C

C_C is a correction factor related to the pre-retinal absorption for wavelengths between 1.150 μm and 1.400 μm . For 1064 nm, C_C is equal to 1.

5.2 Extended Source Correction Factor C_E

C_E is a correction factor used in calculating the MPE for the eye from the small source MPE. For extended sources with a wavelength between 0.400 μm and 1.400 μm and with an angular subtense between 1.5 mrad and 100 mrad, C_E is given by

$$C_E = \frac{\alpha}{\alpha_{\min}}$$

5.3 Constant Irradiance Injury Time T_2

T_2 is the exposure time beyond which extended source MPEs based on thermal injury are expressed as a constant irradiance. For extended sources with a wavelength between 0.400 μm and 1.400 μm and with an angular subtense between 1.5 mrad and 100 mrad, T_2^1 is given by

$$T_2 = 10 \times 10^{(\alpha-1.5)/98.5}$$

Table 2 shows the calculated correction factors used in deriving the proposed laser incident threshold level.

w_0 (μm)	150	250
C_C	1.000	1.000
C_E	3.614	3.791
T_2 (s)	10.960	11.028

Table 2. Calculated correction factors.

6 Threshold Calculations

Table 3 lists the calculated MPEs for the exposure durations of interest, as per Table 5a of ANSI Z136.1-2007 for small sources.

exposure duration (s)	MPE
-----------------------	-----

¹ See Table 6 of ANSI Z136.1-2007.

50 x 10 ⁻⁶ to 10	1.08E-1 W.cm ⁻²
10 to 3 x 10 ⁴	5.0E-3 W.cm ⁻²

Table 3. Calculated MPE for various exposure durations, in each case the lower bound of the time interval was used.

Converting the MPE values into AEL values simply involves multiplying by the area of the pupil (0.385 cm²). The lowest value small source AEL is therefore 1.9 mW.

Table 4 lists the calculated MPEs for various exposure durations, as per Table 5b of ANSI Z136.1-2007.

	irradiance for 150 μm spot size	irradiance for 250 μm spot size
exposure duration, <i>t</i> (s)		
50 x 10 ⁻⁶ to <i>T</i> ₂	3.87E-1 W.cm ⁻²	4.06E-1 W.cm ⁻²
<i>T</i> ₂ to 3 x 10 ⁴	17.9E-3 W.cm ⁻²	18.7E-3 W.cm ⁻²

Table 4. Calculated MPE for exposure durations of interest, in each case the lower bound of the time interval was used. Note the change in units for the last line of the table.

To the author’s knowledge, there are no pulsed lasers within the LVEA with the exception of the thermal compensation system’s CO₂ laser, which is run in a quasi-cw manner. Therefore only exposure durations of 50 x 10⁻⁶ s and higher are considered. With that consideration in mind, Figure 2 shows the calculated AEL versus exposure duration.




Figure 2. The extended source AEL plotted versus exposure time for the range of angular subtenses considered. The lowest value AEL is (7.0 ± 0.2) mW. The more stringent small source AEL limit of 1.9 mW is also displayed.

By varying the angular subtense for the range of expected output beam waists, the AEL is calculated to be between 6.8 mW and 7.2 mW. This is higher than the small source AEL by a factor of approximately 3.5.

7 Proposed New Threshold Limit

We see that in all cases that the AEL threshold for extended sources exceeds the small source threshold. Conservatively then, the small source limit determines the proposed laser incident threshold of 2.0 mW. 2 mW corresponds to the transmission of 200 W incident upon a 10 ppm mirror, which although is difficult to obtain, is not impossible.

2 mW is 5% greater than the AEL of 1.9 mW for a small source. However, the value is an easier limit to remember and this is a worst-case scenario; in addition as noted earlier there is already a factor of 10X in the AEL included by the ANSI Z136.1 – 2007 standard.

8 Verification Measures

Obtaining accurate and reliable power measurements at the milliwatt level can often be quite difficult and tedious. For verification purposes, a reliable and relatively fast method for measuring the power of the stray beam or scattered light would be desirable. “Fast” meaning on the order of 10 s, since that is the time scale for which the retina is considered to be stationary.

8.1 Verification Eyeball

For measuring the power of the stray beam or stray scattered light, it is proposed that a collection system of a 7.0 mm diameter aperture be used with a 17 mm focal length lens². The detector, placed at the focus of the lens, can be a large area photodetector that has been calibrated for low power levels. To the author’s knowledge no such device is commercially available and would have to be designed, fabricated and calibrated. This is not expected to be a difficult task.

8.2 Verification Location

For the purposes of verification, I would propose that the measurement be done at plane of the optical table edge where the stray beam or scattered light is located. For example, for the PSL this would be at the edge of the PSL table, where the table enclosure doors are located. This would coincide with the closest point a person would access a table without leaning over the edge or climbing onto the table and the point at which a person might sustain an eye injury. Figure 3 shows the geometry for the verification measurement for stray beams or scattered light.

² For example, a suitable lens might be the plano-convex lens PLCX-13.3-8.8-C from CVI Laser Corp. that has a focal length of 17.4 mm.




Figure 3. The proposed area where verification measurements of stray beams or scattered light would be performed.

9 References

François C. Delori, Robert H. Webb, David H. Sliney: Maximum permissible exposures for ocular safety (ANSI 2000), with emphasis on ophthalmic devices
 J. Opt. Soc. Am. A, Vol. 25, No. 5 (2007)
 American National Standard for Safe Use of Lasers, ANSI Z136.1-2007

10 Appendix

10.1 Other Wavelengths In LIGO

The Pre-stabilized Laser is not the only laser used within LIGO. Other detector subsystems employ laser of a different wavelength to 1064 nm. Table 5 lists the other wavelengths, known at the time of writing this document, their respective small source MPEs and proposed laser incident threshold level.

detector subsystem/laser	wavelength λ (nm)	MPE ($\text{W}\cdot\text{cm}^{-2}$)	incident threshold (mW)
Nd:YAG	532	1×10^{-3}	0.4
HeNe	632.8	1×10^{-3}	0.4

optical levers	635	1×10^{-3}	0.4
PSL pump diode	808	1.6×10^{-3}	0.6
AOS	980	3.6×10^{-3}	1.4
photon calibrator	1047	5.0×10^{-3}	1.9
PSL	1064	5.0×10^{-3}	1.9
TCS	10.6 (μm)	0.1	9.6

Table 5. The proposed laser incident power threshold for the wavelengths encountered in LIGO. For all wavelengths listed, a 7.0 mm diameter aperture was used to calculate the incident threshold power level.