

ELECTRIC HUMIDIFIER SCHEDULE

UNIT NO	LOCATION	SERVICE	TYPE	CAPACITY LB/H	HEATER				MANUFACTURER/ MODEL NO	REMARKS
					KW	V	PH	HZ		
W-CS-107-HU-01	CORNER STATION	LVEA	ELECTRIC	100	34	460	3	60	NORTEC NH-100	DOMESTIC WATER W/ BLOWDOWN CYCLE
W-CS-107-HU-02	CORNER STATION	LVEA	ELECTRIC	100	34	460	3	60	NORTEC NH-100	DOMESTIC WATER W/ BLOWDOWN CYCLE
W-CS-107-HU-03	CORNER STATION	LVEA	ELECTRIC	100	34	460	3	60	NORTEC NH-100	DOMESTIC WATER W/ BLOWDOWN CYCLE
W-CS-107-HU-04	CORNER STATION	LVEA	ELECTRIC	100	34	460	3	60	NORTEC NH-100	DOMESTIC WATER W/ BLOWDOWN CYCLE

AIR INLET & OUTLET SCHEDULE

UNIT NO	DESCRIPTION	FACE SIZE	NECK SIZE IN X IN	CONSTRUCTION	MANUFACTURER/ MODEL NO	REMARKS
HF-1	HEPA FILTER	48 X 24	12" Ø	STEEL	AMERICAN AIR FILTER PHARMA-GEL PGA-87	5" DEEP FILTER, (1), (2)
HF-2	HEPA FILTER	24 X 24	10" Ø	STEEL	AMERICAN AIR FILTER PHARMA-GEL PGA-43	5" DEEP FILTER, (1), (2)
CD-1	CEILING DIFFUSER	24 X 24	(3)	ALUMINUM	TITUS PDS	W/OBD
CD-2	CEILING DIFFUSER	N/A	(3)	ALUMINUM	TITUS TMR-2A	W/BUTTERFLY DAMPER
RR-1	RETURN REGISTER	(3)	N/A	ALUMINUM	TITUS JEL	W/OBB
RR-2	RETURN REGISTER	(3)	N/A	ALUMINUM	TITUS 4FL	W/OBB
RG-1	RETURN GRILLE	24 X 24	N/A	ALUMINUM	TITUS 8F	
RG-2	RETURN GRILLE	(3)	(3)	ALUMINUM	TITUS 35520A	
SR-1	SUPPLY REGISTER	(3)	(3)	ALUMINUM	TITUS 300F	W/OBD

(1) PROVIDE WITH HANGING TAPS, STAINLESS STEEL TRIM, 1/2" INSULATION WITH ALUMINUM FOIL
 (2) INITIAL PRESSURE DROP = 0.50" WC, REPLACEMENT PRESSURE DROP = 2.0" WC
 (3) SEE PLANS

VIBRATION ISOLATOR SCHEDULE

UNIT NO	NAME	LOCATION	(2) ISOLATOR TYPE	(3) SPRING DEFLECTION (INCHES)	(2) FRAME TYPE	(2) SEISMIC RESTRAINT	REMARKS
W-CS-107-SF-01, 02, 03, 04	VANE AXIAL FAN	CORNER STATION	B	1.0	G	SL	FANS (TYP 4)
W-CS-190-CH-01, 02, 03	AIR-COOLED WATER CHILLER	CORNER STATION	D	1.0	-	(1)	CHILLERS (TYP 3)
W-CS-190-WP-01, 02, 03	CHILLED WATER PUMP	CORNER STATION	C	1.0	G	SL	PUMPS (TYP 3)
W-CS-107-AC-01, 02	AIR COMPRESSOR	CORNER STATION	C	1.0	G	SL	COMPRESSORS (TYP 2)
W-CS-107-GP-01	GLYCOL FEED PUMP	CORNER STATION	C	1.0	G	SL	

(1) TYPE D ISOLATOR HOUSING INCLUDES SEISMIC RESTRAINTS
 (2) SEE SPECIFICATIONS FOR CODE LETTER
 (3) STATIC DEFLECTION 3/4"

ELECTRIC DUCT HEATER SCHEDULE

UNIT NO	LOCATION	SERVICE		HEATING CAPACITY (KW)	NUMBER OF STAGES	VOLTS/ PH/ HZ	DUCT SIZE (IN)	MANUFACTURER/ MODEL NO	REMARKS
		BUILDING	ROOM						
W-CS-107-HC-1A	MECH ROOM	LVEA	LASER AREA - 1	80	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-1B	MECH ROOM	LVEA	LASER AREA - 1	50	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-2A	MECH ROOM	LVEA	LASER AREA - 2	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-2B	MECH ROOM	LVEA	LASER AREA - 2	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-3A	MECH ROOM	LVEA	LASER AREA - 3	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-3B	MECH ROOM	LVEA	LASER AREA - 3	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-04	MECH ROOM	LVEA	LASER AREA - 4	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-05	MECH ROOM	LVEA	LASER AREA - 5	100	SCR	460/3/60	48X36	CHROMALOX DHIF	
W-CS-107-HC-06	MECH ROOM	LVEA	MECHANICAL ROOM	60	4	460/3/60	48X24	CHROMALOX DHIF	
W-CS-107-HC-07	MECH ROOM	LVEA	OUTSIDE AIR SUPPLY	60	4	460/3/60	24X24	CHROMALOX DHIF	
W-CS-107-HC-08	MECH ROOM	LVEA	OUTSIDE AIR SUPPLY	60	4	460/3/60	24X24	CHROMALOX DHIF	

NOTES:
 1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS WA-H-001 AND WA-H-002.

DUCT SILENCER SCHEDULE

UNIT NO	LOCATION	SERVICE		CFM	DIMENSIONS W X D X L	PD IN WC	MANUFACTURER/ MODEL NO	REMARKS
		BUILDING	ROOM					
W-CS-107-ST-1A	MECH ROOM 107	LVEA	LASER AREA - 1	10,260	48X36X120	0.15	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-1B	MECH ROOM 107	LVEA	LASER AREA - 1	5,130	48X36X120	0.15	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-2A	MECH ROOM 107	LVEA	LASER AREA - 2	11,400	48X36X120	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-2B	MECH ROOM 107	LVEA	LASER AREA - 2	11,400	48X36X120	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-3A	MECH ROOM 107	LVEA	LASER AREA - 3	10,260	48X36X120	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-3B	MECH ROOM 107	LVEA	LASER AREA - 3	10,260	48X36X120	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-04	MECH ROOM 107	LVEA	LASER AREA - 4	9,630	48X36X120	0.15	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-05	MECH ROOM 107	LVEA	LASER AREA - 5	10,830	48X36X120	0.15	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-06	MECH ROOM 107	LVEA	MECHANICAL ROOM #107	6,840	48X24X84	0.07	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-07	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	26,600	60X60X84	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-08	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	26,600	60X60X84	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-09	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	26,600	60X60X84	0.10	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-15	MECH ROOM 107	LVEA	OUTSIDE AIR	3,125	24X24X84	0.05	INDUSTRIAL ACOUSTICS CO MS	
W-CS-107-ST-16	MECH ROOM 107	LVEA	OUTSIDE AIR	3,125	24X24X84	0.05	INDUSTRIAL ACOUSTICS CO MS	

(1) TYPE D ISOLATOR HOUSING INCLUDES SEISMIC RESTRAINTS

not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
B	5-22-96	CLP	AA	AA	TDM	BID ADDENDUM #2
A	4-19-96	CLP	ME	AA	TDM	FINAL DESIGN REVIEW & BID

DRAWN	CLP
CHECKED	
ENGINEER	
PROJ	

PARSONS
 100 WEST WALNUT STREET
 PASADENA, CALIFORNIA

LIGO
 CALIFORNIA INSTITUTE OF TECHNOLOGY
 MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
 GRAVITATIONAL-WAVE OBSERVATORY
 SITE NO. 1 - HANFORD, WASHINGTON

HVAC
 CORNER STATION
 EQUIPMENT SCHEDULES
 SHEET 2

SCALE: NONE
 CONTRACT NUMBER: PPI50969
 PROJECT NUMBER: 8094

SHEET NUMBER: **WA-H-502**