

PANEL 107RP.1		LOCATION ROOM 107										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 4			FEEDER				BUS 100				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	Spare	1	1	0	0	0	0	0	0	0	0	0	1	2	RECEP RM 107	2
3	RECP RM 106	3	1	0	0	720	0	720	0	0	0	0	1	4	Spare	4
5	Spare	5	1	0	0	0	0	0	0	0	0	0	1	6	Spare	6
7	MECH ROOM LIGHT	7	1	0	0	800	800	0	0	800	0	0	1	8	ROOM MECH LIGHT	8
9	ROOM MECH LIGHT	9	1	0	0	600	0	600	0	0	0	0	1	10	Spare	10
11	Spare	11	1	0	0	0	0	0	0	1150	0	0	1	12	WCS107GP01	12
13	Spare	13	1	0	0	0	0	0	0	0	0	0	1	14	Spare	14
15	Spare	15	1	0	0	0	0	0	0	0	0	0	1	16	Spare	16
17	Spare	17	1	0	0	0	0	0	0	0	0	0	1	18	Spare	18
19	Spare	19	1	0	0	0	0	0	0	0	0	0	1	20	Spare	20
21	Spare	21	1	0	0	0	0	0	0	0	0	0	1	22	Spare	22
23	Spare	23	1	0	0	0	0	0	0	0	0	0	1	24	Spare	24
25	Spare	25	1	0	0	0	0	0	0	0	0	0	1	26	Spare	26
27	Spare	27	1	0	0	0	0	0	0	0	0	0	1	28	Spare	28
29	Spare	29	1	0	0	0	0	0	0	0	0	0	1	30	Spare	30
TOTAL							1600	1320	1150							
TOTAL CONNECTED LOAD (VA)							4070									
TOTAL							(AMPS)									

PANEL 107LP.1		LOCATION ROOM 107										VOLTS 480Y/277V				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 3			FEEDER				BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	LIGHT RM 102	1	1	0	0	2820	2820	0	0	348	0	0	1	2	OUTSIDE VEST LTG	2
3	OUTSIDE VEST LTG	3	1	0	0	458	0	458	0	2820	0	0	1	4	LIGHT RM 103	4
5	LTG RM 105,104	5	1	0	0	2350	0	2350	0	66	0	0	1	6	EXIT EMRG LTG 103	6
7	EXIT,EMERG	7	1	0	0	124	124	0	0	1410	0	0	1	8	LIGHT RM 106	8
9	EXIT,EMRG LTG	9	1	0	0	94	0	124	0	124	0	0	1	10	EXIT,EMERG 107	10
11	OUTSIDE,VEST 103	11	1	0	0	458	0	0	0	1880	0	0	1	12	LIGHT RM 107	12
13	Spare	13	1	0	0	0	0	0	0	450	0	0	1	14	LIGHT	14
15	LIGHT RM 107	15	1	0	0	2350	0	2350	0	0	0	0	1	16	Spare	16
17	Spare	17	1	0	0	0	0	0	0	288	0	0	1	18	PANEL LTG RM 107	18
19	SUMP PUMP	19	3	0	0	1500	500	0	0	75000	0	0	3	20	WCS107T02	20
21		21				0	0	0	0	0	0	0	1	22	Spare	22
23		23				0	0	0	0	0	0	0	1	24	Spare	24
25	Spare	25	1	0	0	0	0	0	0	0	0	0	1	26	Spare	26
27	Spare	27	1	0	0	0	0	0	0	0	0	0	1	28	Spare	28
29	Spare	29	1	0	0	0	0	0	0	0	0	0	1	30	Spare	30
TOTAL							30652	31346	30542							
TOTAL CONNECTED LOAD (VA)							92540									
TOTAL							(AMPS)									

PANEL 107HP.1		LOCATION ROOM 107										VOLTS 480				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 3			FEEDER				BUS 800				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	SPARE	1	3	0	0	0	16667	0	0	0	0	0	3	2	WCS107HC10	2
3		3				0	16667	0	0	0	0	0	3	4		4
5		5				0	16667	0	0	0	0	0	3	6		6
7	SPARE	7	3	0	0	0	5000	0	0	15000	0	0	3	8	WCS107HC12	8
9		9				0	5000	0	0	0	0	0	3	10		10
11		11				0	5000	0	0	0	0	0	3	12		12
13	SPARE	13	3	0	0	0	16667	0	0	50000	0	0	3	14	WCS107HC08	14
15		15				0	16667	0	0	0	0	0	3	16		16
17		17				0	16667	0	0	0	0	0	3	18		18
19	SPARE	19	3	0	0	0	25000	0	0	75000	0	0	3	20	WCS107HC01	20
21		21				0	25000	0	0	0	0	0	3	22		22
23		23				0	25000	0	0	0	0	0	3	24		24
25	SPARE	25	3	0	0	0	50000	0	0	150000	0	0	3	26	WCS107HC02	26
27		27				0	50000	0	0	0	0	0	3	28		28
29		29				0	50000	0	0	0	0	0	3	30		30
31	WCS107HC03	31	3	0	0	0	150000	50000	0	0	0	0	3	32	WCS107HC06	32
33		33				0	50000	0	0	0	0	0	3	34		34
35		35				0	50000	0	0	0	0	0	3	36		36
37	SPARE	37	3	0	0	0	0	0	0	0	0	0	3	38	SPARE	38
39		39				0	0	0	0	0	0	0	3	40		40
41		41				0	0	0	0	0	0	0	3	42		42
TOTAL							188333	188333	188333							
TOTAL CONNECTED LOAD (VA)							565000									
TOTAL							(AMPS)									

PANEL 107HP.2		LOCATION ROOM 107										VOLTS 480				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 3			FEEDER				BUS 800				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	WCS107HU01	1	3	0	0	26000	8667	8667	0	17000	0	0	3	2	WCS107HU06	2
3		3				0	8667	8667	0	0	0	0	3	4		4
5		5				0	8667	8667	0	0	0	0	3	6		6
7	WCS107HU02	7	3	0	0	25000	8667	8667	0	52000	0	0	3	8	WCS107HU07	8
9		9				0	8667	17333	0	0	0	0	3	10		10
11		11				0	8667	17333	0	0	0	0	3	12		12
13	WCS107HU03	13	3	0	0	26000	8667	8667	0	50000	0	0	3	14	WCS107HC09	14
15		15				0	8667	8667	0	0	0	0	3	16		16
17		17				0	8667	8667	0	0	0	0	3	18		18
19	WCS107HU04	19	3	0	0	26000	8667	8667	0	50000	0	0	3	20	WCS160HC13	20
21		21				0	8667	8667	0	0	0	0	3	22		22
23		23				0	8667	8667	0	0	0	0	3	24		24
25	WCS107HU05	25	3	0	0	17000	5667	33333	0	100000	0	0	3	26	WCS107HC05	26
27		27				0	5667	33333	0	0	0	0	3	28		28
29		29				0	5667	33333	0	0	0	0	3	30		30
31	WCS107HC11	31	3	0	0	15000	5000	33333	0	100000	0	0	3	32	WCS107HC04	32
33		33				0	5000	33333	0	0	0	0	3	34		34
35		35				0	5000	33333	0	0	0	0	3	36		36
37	WCS107HC07	37	3	0	0	50000	16667	0	0	0	0	0	3	38	SPARE	38
39		39				0	16667	0	0	0	0	0	3	40		40
41		41				0	16667	0	0	0	0	0	3	42		42
TOTAL							185000	185000	185000							
TOTAL CONNECTED LOAD (VA)							555000									
TOTAL							(AMPS)									

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
B	5-22-96	KAP	TR	JK	SDM	BID ADDENDUM #2
A	4-19-96				TOM	FINAL DESIGN REVIEW & BID

DRAWN	J. G.
CHECKED	
ENGINEER	
PROJ	

PARSONS
100 WEST WALNUT STREET
PASADENA, CALIFORNIA

LIGO
CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
GRAVITATIONAL-WAVE OBSERVATORY
SITE NO. 1 - HANFORD, WASHINGTON

ELECTRICAL
CORNER STATION MECH. RM.
LIGHTING AND POWER
PANEL SCHEDULES

SCALE: NONE
CONTRACT NUMBER: PP150969
PROJECT NUMBER: 8094

SHEET NUMBER: **WA-E-117**