



- NOTES:
- 1) ALL CABLETRAY LENGTHS ARE 12'-0" UNLESS OTHERWISE SPECIFIED.
 - 2) ALL CABLE TRAY SHALL BE GROUNDED PER N.E.C.
 - 3) ALL CABLE TRAY SHALL BE FIELD SUPPORTED.
 - 4) CABLE TRAY FOR ION PUMP POWER CABLES SHALL BE LABELED "DANGER HIGH VOLTAGE".

APR 30 1996

0960553-00-V

PROPRIETARY AND CONFIDENTIAL THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION BELONGING TO PROCESS SYSTEMS INTERNATIONAL, INC. OR ITS AFFILIATED COMPANIES AND SHALL BE USED ONLY FOR THE PURPOSE FOR WHICH IT WAS SUPPLIED. IT SHALL NOT BE COPIED, REPRODUCED OR OTHERWISE USED, NOR SHALL SUCH INFORMATION BE FURNISHED IN WHOLE OR IN PART TO OTHERS EXCEPT IN ACCORDANCE WITH THE TERMS OF ANY AGREEMENT UNDER WHICH IT WAS SUPPLIED OR WITH THE PRIOR WRITTEN CONSENT OF PROCESS SYSTEMS INTERNATIONAL, INC. AND SHALL BE RETURNED UPON REQUEST.				UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES: FRACTIONAL ± ANGULARMACH ±0°-30' BEND ±2° TWO PLACE DECIMAL ±.01 THREE PLACE DECIMAL ±.005 FINISHED SURFACE RMS BREAK CORNERS IN REMOVE ALL BURRS				PROCESS SYSTEMS INTERNATIONAL INC. 20 WALKUP DR. WESTBOROUGH, MASSACHUSETTS 01581 USA			
V049-3-108 CABLE TRAY PLAN RIGHT BEAM MANIFOLD V049-3-107 CABLE TRAY PLAN LEFT BEAM MANIFOLD V049-3-002 WASHINGTON OVERALL SITE PLAN V049-3-001 GENERAL NOTES & LEGEND				DD NOT SCALE THIS DRAWING 0 ISSUE FOR FDR USED ON REV DESCRIPTION NEXT ASS'Y:				CAD FILE V0493106 SIZE D DWG. NO. V049-3-106 DATE 04.26.96 DECD# 0129 SCALE 3/16" = 1' - 0" SHEET 1 OF 1			
DWG. NO.	DESCRIPTION	DWG. NO.	DESCRIPTION	ISSUE DESCRIPTION	CHKD	DRWN	DATE	DECD#	8 7 6 5 4 3 2 1		