



- NOTES:**
- 1) ALL CABLETRAY LENGTHS ARE 12'-0" UNLESS OTHERWISE SPECIFIED.
  - 2) ALL CABLE TRAY SHALL BE GROUNDED PER N.E.C.
  - 3) ALL CABLE TRAY SHALL BE FIELD SUPPORTED.
  - 4) CABLE TRAY FOR ION PUMP POWER CABLES SHALL BE LABELED "DANGER HIGH VOLTAGE".

0960584-00-V

APR 30 1996

<p><b>PROPRIETARY AND CONFIDENTIAL</b></p> <p>THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION BELONGING TO PROCESS SYSTEMS INTERNATIONAL, INC. OR ITS AFFILIATED COMPANIES AND SHALL BE USED ONLY FOR THE PURPOSE FOR WHICH IT WAS SUPPLIED. IT SHALL NOT BE COPIED, REPRODUCED OR OTHERWISE USED, NOR SHALL SUCH INFORMATION BE FURNISHED IN WHOLE OR IN PART TO OTHERS EXCEPT IN ACCORDANCE WITH THE TERMS OF ANY AGREEMENT UNDER WHICH IT WAS SUPPLIED OR WITH THE PRIOR WRITTEN CONSENT OF PROCESS SYSTEMS INTERNATIONAL, INC. AND SHALL BE RETURNED UPON REQUEST.</p>		<p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES</p> <p>TOLERANCES:          FRACTIONAL ±          ANGULAR/MACH ±0°-30' BEND ±2°          TWO PLACE DECIMAL ± .01          THREE PLACE DECIMAL ± .005          FINISHED SURFACE RNS          BREAK CORNERS IN OUT          REMOVE ALL BURRS</p>		<p>DO NOT SCALE THIS DRAWING 0 ISSUE FOR FDR</p>		<p>USED ON: REV DESCRIPTION</p>		<p>ISSUE DESCRIPTION</p>		<p>PROCESS SYSTEMS INTERNATIONAL INC.          20 WALKUP DR. WESTBOROUGH, MASSACHUSETTS 01581 USA</p>	
<p>V049-3-002 WASHINGTON OVERALL SITE PLAN</p>										<p>CABLE TRAY PLAN          LIGD VACUUM EQUIPMENT          WASHINGTON SITE          RIGHT MID STATION</p>	
<p>V049-3-001 GENERAL NOTES &amp; LEGEND</p>										<p>CAD FILE: V0493302          SIZE: D          DWG. NO.: V049-3-302          REV: 0</p>	
<p>DWG. NO. DESCRIPTION DWG. NO. DESCRIPTION</p>		<p>REFERENCE DRAWINGS</p>								<p>SCALE: 3/16" = 1'-0" SHEET 1 OF 1</p>	