

INPUT/OUTPUT SUMMARY FOR AIR HANDLING UNIT AH-03

Table with columns: SYSTEM APPARATUS OR AREA POINT DESCRIPTION, ANALOG (MEASURED, CALCULATED), BINARY, DIGITAL, ANALOG, ALARMS, PROGRAMS, GENERAL, SUPPLEMENTARY NOTES. Rows include: OUTSIDE TEMPERATURE, OUTSIDE RELATIVE HUMIDITY (H), PREHEAT COIL, HC-11, PREHEAT COIL, HC-12, AIR FILTER, AF-03 (TYP 2), COOLING COIL, CC-05, COOLING COIL, CC-06, HEATING COIL, HC-09, HEATING COIL, HC-10, SUPPLY FAN, SF-05, SUPPLY FAN, SF-06, COLD AIR DECK, WARM AIR DECK, WARM AIR RELATIVE HUMIDITY, SPACE AVERAGE RELATIVE HUMIDITY, ROOM TEMPERATURE (TYPICAL 17 ZONES), SMOKE DETECTOR (SD-02), MIXING AIR TEMP, MIXING AIR RELATIVE HUMIDITY, ROOM PRESSURIZATION (TYP 2), AIR FLOW DIAGRAM, FUME HOOD EXHAUST SYSTEM (TYP 2), HEPA FILTER, RETURN & OUTSIDE AIR DAMPERS (TYP 3), FLOOR PLANS, VIBRATIONS FOR FANS.

NOTES:

- 1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS LA-H-001 AND LA-H-002.
- 2. FOR SEQUENCE OF OPERATION SEE SHEET LA-H-141.

INPUT/OUTPUT SUMMARY FOR AIR HANDLING UNIT AH-04

Table with columns: SYSTEM APPARATUS OR AREA POINT DESCRIPTION, ANALOG (MEASURED, CALCULATED), BINARY, DIGITAL, ANALOG, ALARMS, PROGRAMS, GENERAL, SUPPLEMENTARY NOTES. Rows include: OUTSIDE TEMPERATURE, OUTSIDE RELATIVE HUMIDITY (H), PREHEAT COIL, HC-13, AIR FILTER, AF-03, COOLING COIL, CC-05, SUPPLY FAN, SUPPLY AIR, SUPPLY AIR RELATIVE HUMIDITY, ROOM TEMPERATURE (TYPICAL 20 ZONES), SPACE AVERAGE RELATIVE HUMIDITY, ZONE DUCT HEATERS (TYPICAL 20 ZONES), EXHAUST FAN, EF-01, EXHAUST FAN, EF-02, SMOKE DETECTOR, AIR FLOW DIAGRAM, ECONOMIZER DAMPERS, FLOOR PLANS.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

Table with columns: NO., DATE, BY, CHKD, ENGR, PROJ. Row 1: 1, 8-7-98, DJB, AA, AA, WJD. Below table: AS-BUILT DRAWINGS

Table with columns: DRAWN, CHECKED, ENGINEER, PROJ. Row 1: CLP, MN, AA, TDM. Row 2: 11-15-96, 10-25-96, 1-23-96, 11-15-96.

AS-BUILT DRAWINGS

PARSONS 100 WEST WALNUT STREET PASADENA, CALIFORNIA

LIGO CALIFORNIA INSTITUTE OF TECHNOLOGY MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LIGO-D960978-01-O LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 2 - LIVINGSTON, LOUISIANA. TITLE: HVAC CORNER STATION SEQUENCES OF OPERATION & I/O SUMMARY SHEET 2. SCALE: NONE. CONTRACT NUMBER: PPI50969. PROJECT NUMBER: 8094. SHEET NUMBER: LA-H-142. REVISIONS: 1.

E
D
C
B
A
LIGO.AF.BDR