

PANEL 163RP.1		LOCATION ROOM 163										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 4			FEEDER				BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT RM 165	1	3		30	8646	2882	0	0	720	20	1	2	RCPT RM 162	2	
3		3					0	2882	0	720	20	1	4	RCPT RM 162	4	
5		5					0	0	2882	540	20	1	6	RCPT RM 165	6	
7	RCPT RM 162	7	1		20	540	540	0	0	360	20	1	8	RCPT RM 165	8	
9	RCPT RM 165	9	1		20	360	0	360	0	900	20	1	10	RCPT RM 161	10	
11	RCPT RM 163	11	1		20	360	0	0	360	360	20	1	12	RCPT RM 163	12	
13	RCPT RM 162	13	1		20	540	540	0	0	900	20	1	14	RCPT RM 161	14	
15	RCPT RM 165	15	1		20	540	0	540	0	360	20	1	16	RCPT RM 163	16	
17	CORR 177,178 & 179	17	1		20	900	0	0	900	20	1	18	SPARE	18		
19	LTG RM 162	19	1		20	540	540	0	0	300	20	1	20	FACP RM 161	20	
21	RCPT RM 163	21	1		20	360	0	0	360	500	20	1	22	EXHAUST RM 137	22	
23	SPARE	23	1		20		0	0	3750	7500	50	2	24	L-CS-139-SV-03	24	
25	MICROWAVE RM 145	25	1		20	1350	1350	0	0		20	1	26		26	
27	JB REMOTE FIRE PNL	27	1		20	1920	0	1920	0	4000	30	2	28	L-CS-140-SV-05	28	
29	J BOX RM 121	29	1		20		0	0	2000		20	1	30		30	
31	COOK TOP RM 145	31	3		30	7300	2433	0	0	4000	30	2	32	L-CS-141-SV-07	32	
33		33					0	2433	0			2	34		34	
35		35					0	0	2433	4000	30	2	36	L-CS-142-SV-09	36	
37	RCPT RM 160	37	1		20	720	720	0	0		20	1	38		38	
39	L-CS-160-SV-18	39	2		30	4000	0	2000	2000	4000	30	2	40	L-CS-143-SV-10	40	
41		41					0	0	2000	2000		1	42		42	
TOTAL							19035	18975	19225							
TOTAL CONNECTED LOAD (VA)							57235									
(AMPS)																

PANEL 163RP.2		LOCATION ROOM 163										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 4			FEEDER				BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	DUAL DUPLEX RCPT RM 162	1	1		20	1920	1920	0	0	1920	20	1	2	DUAL DUPLEX RCPT RM 165	2	
3	DUAL DUPLEX RCPT RM 162	3	1		20	1920	0	1920	0	1920	20	1	4	DUAL DUPLEX RCPT RM 165	4	
5	DUAL DUPLEX RCPT RM 162	5	1		20	1920	0	0	1920	1920	20	1	6	DUAL DUPLEX RCPT RM 165	6	
7	DUAL DUPLEX RCPT RM 162	7	1		20	1920	1920	0	0	1920	20	1	8	DUAL DUPLEX RCPT RM 165	8	
9	DUAL DUPLEX RCPT RM 162	9	1		20	1920	0	1920	0	1920	20	1	10	DUAL DUPLEX RCPT RM 165	10	
11	DUAL DUPLEX RCPT RM 162	11	1		20	1920	0	0	1920	1920	20	1	12	DUAL DUPLEX RCPT RM 165	12	
13	DUAL DUPLEX RCPT RM 162	13	1		20	1920	1920	0	0	1920	20	1	14	DUAL DUPLEX RCPT RM 161	14	
15	DUAL DUPLEX RCPT RM 162	15	1		20	1920	0	1920	0	1920	20	1	16	DUAL DUPLEX RCPT RM 161	16	
17	DUAL DUPLEX RCPT RM 162	17	1		20	1920	0	0	1920	1920	20	1	18	DUAL DUPLEX RCPT RM 161	18	
19	DUAL DUPLEX RCPT RM 161	19	1		20	1920	1920	0	0	1920	20	1	20	DUAL DUPLEX RCPT RM 161	20	
21	DUAL DUPLEX RCPT RM 161	21	1		20	1920	0	1920	0		20	1	22	SPARE	22	
23	DUAL DUPLEX RCPT RM 163	23	1		20	1920	0	0	1920		20	1	24	SPARE	24	
25	SPARE	25	1		20		0	0	0		20	1	26	SPARE	26	
27	SPARE	27	1		20		0	0	0		20	1	28	SPARE	28	
29	SPARE	29	1		20		0	0	0		20	1	30	SPARE	30	
31	SPARE	31	1		20		0	0	0		20	1	32	SPARE	32	
33	SPARE	33	1		20		0	0	0		20	1	34	SPARE	34	
35	SPARE	35	1		20		0	0	0		20	1	36	SPARE	36	
37	SPARE	37	1		20		0	0	0		20	1	38	SPARE	38	
39	SPARE	39	1		20		0	0	0		20	1	40	SPARE	40	
41	SPARE	41	1		20		0	0	0		20	1	42	SPARE	42	
TOTAL							15360	13440	13440							
TOTAL CONNECTED LOAD (VA)							42240									
(AMPS)																

PANEL 172PP.1		LOCATION ROOM 172										VOLTS 480Y/277V				
FED FROM	CKT #	MOUNTING Recessed										MAIN Main Lugs				
		PHASE 3			WIRE 4			FEEDER				BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	JB RM 167	1	3		60	39905	13302	0	0	39905	60	3	2	JB ROOM 167	2	
3		3					13302	0	0			3	4		4	
5		5					13302	0	0			3	6		6	
7	RM 166	7	3		60	39905	13302	0	0	831	15	3	8	DOOR MOTOR 170	8	
9		9					13302	0	0			3	10		10	
11		11					499	0	0			3	12		12	
13	DOOR MOTOR 173	13	3		15	1496	499	0	0	831	15	3	14	DOOR MOTOR 170	14	
15		15					499	0	0			3	16		16	
17		17					499	0	0			3	18		18	
19	J BOX RM 174	19	3		60	39905	13302	0	0		15	3	20	SPARE	20	
21		21					0	13302	0			3	22		22	
23		23					0	0	13302			3	24		24	
25	JB RM 167	25	3		60	39905	13302	0	0	39905	60	3	26	JB FUME HOOD 169	26	
27		27					13302	0	0			3	28		28	
29		29					13302	0	0			3	30		30	
31	JB BAKE OVEN 169	31	3		60	39905	13302	0	0		20	3	32	SPARE	32	
33		33					0	13302	0			3	34		34	
35		35					0	0	13302			3	36		36	
37	SPARE	37	3		60		0	0	0		30	3	38	SPARE	38	
39		39					0	0	0			3	40		40	
41		41					0	0	0			3	42		42	
TOTAL							94164	94164	94164							
TOTAL CONNECTED LOAD (VA)							282492									
(AMPS)																

PANEL 144RP.1		LOCATION ROOM 144										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING Recessed										MAIN				
		PHASE 3			WIRE 4			FEEDER				BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT XEROX RM 144	1	3		30	2880	1260	0	0	1260	20	1	2	RCPT RMS 122,147 & 148	2	
3		3					0	1260	0	1260	20	1	4	RCPT RMS 122,146,147 & 149	4	
5		5					0	0	1260	1080	20	1	6	RCPT RMS 122,123,146 & 147	6	
7	DISHWASHER RM 145	7	1		20	1020	1020	0	0	720	20	1	8	REFRIGERATOR RM 145	8	
9	RECEPTACLE RM 147	9	1		20	360	0	360	0	1260	20	1	10	RECEPTACLE RMS 123 TO 129	10	
11	SPARE	11	1		20		0	0	1080	180	20	1	12	RECEPTACLE RM 144	12	
13	RECEPTACLE RMS 140 TO 144	13	1		20	1260	1260	0	0	900	20	1	14	RCPT RMS 142,143,144 & 145	14	
15	RECEPTACLE	15	1		20	1260	0	1260	0	1080	20	1	16	RECEPTACLE RMS 130 TO 135	16	
17	RECEPTACLE EWC	17	1		20	1020	0	0	1020	1260	20	1	18	RECEPTACLE RMS 136 & 138	18	
19	RECEPTACLE RMS 137 & 138	19	1		20	1260	1260	0	0	1260	20	1	20	RECEPTACLE RMS 123 TO 129	20	
21	RECEPTACLE RMS 123 TO 127	21	1		20	1260	0	1260	0	1080	20	1	22	RCPT RMS 140,141,142 & 145	22	
23	DISPOSAL RM 145	23	1		20	1150	0	0	1150	7500	50	2	24	L-CS-144-SV-11	24	
25	RECEPTACLE RM 138	25	1		20	900	0	0	0		20	1	26		26	
27	L-CS-146-SV-17	27	2		50	7500	0	3750	2000	4000	30	2	28	L-CS-123-SV-13	28	
29		29					0	3750	2000			2	30		30	
31	RECEPTACLE RMS 130 TO 135	31	1		20	1080	1080	0	0	4000	30	2	32	L-CS-146-SV-14	32	
33	RCPT RMS 130,131,133,134 & 135	33	1		20	1080	0	1080	0		30	2	34		34	
35	L-CS-144-SV-12	35	2		30	4000	0	2000	1260	1260	20	1	36	RECEPTACLE GFCI	36	
37		37					2080	0	0	2210	30	1	38	ROOM 121 & 122 LTG	38	
39	EXHAUST MOTOR RM 149	39	1		20	1176	0	1176	0	900	15	1	40	ROOM 122 LTG	40	
41	PATID LTG	41	1		15	82	0	0	0		20	1	42	SPARE	42	
TOTAL							21100	19426	19292							
TOTAL CONNECTED LOAD (VA)							59818									
(AMPS)																

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

ISSUED FOR CONSTRUCTION	DATE	BY
DRAWN	M. M.	11-15-96
CHECKED	JCL	7-24-96
ENGINEER	K	