

PANEL 163RP.1		LOCATION ROOM 163										VOLTS 208Y/120V				
FED FROM		MOUNTING Recessed										MAIN				
CKT #		PHASE 3 WIRE 4 FEEDER										BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT RM 165	1	3		30	8646	2882	720	0	720	20		1	2	RCPT RM 162	2
3		3					2882	720	0	720	20		1	4	RCPT RM 162	4
5		5					2882	720	0	720	20		1	6	RCPT RM 165	6
7	RCPT RM 162	7	1		20	540	540	0	0	360	20		1	8	RCPT RM 165	8
9	RCPT RM 165	9	1		20	360	0	0	0	900	20		1	10	RCPT RM 161	10
11	RCPT RM 163	11	1		20	360	0	0	0	360	20		1	12	RCPT RM 163	12
13	RCPT RM 162	13	1		20	540	540	0	0	900	20		1	14	RCPT RM 161	14
15	RCPT RM 165	15	1		20	540	0	0	0	360	20		1	16	RCPT RM 163	16
17	CORR 177,178 & 179	17	1		20	900	0	0	0	900	20		1	18	SPARE	18
19	LTG RM 162	19	1		20	540	540	0	0	300	20		1	20	FACP RM 161	20
21	RCPT RM 163	21	1		20	360	0	0	0	500	20		1	22	EXHAUST RM 137	22
23	SPARE	23	1		20		0	0	0	7500	50		2	24	L-CS-139-SV-03	24
25	MICROWAVE RM 145	25	1		20	1350	1350	0	0					26		
27	JB REMOTE FIRE PNL	27	1		20	1920	0	0	0	4000	30		2	28	L-CS-140-SV-05	28
29	J BOX RM 121	29	1		20		0	0	0					30		
31	COOK TOP RM 145	31	3		30	7300	2433	0	0	4000	30		2	32	L-CS-141-SV-07	32
33		33					2433	0	0					34		
35		35					2433	0	0	4000	30		2	36	L-CS-142-SV-04	36
37	RCPT RM 160	37	1		20	720	720	0	0					38		
39	L-CS-160-SV-18	39	2		30	4000	0	0	0	4000	30		2	40	L-CS-143-SV-10	40
41		41					0	0	0					42		
TOTAL							19035	18975	19225							
TOTAL CONNECTED LOAD (VA)							57235									
(AMPS)																

PANEL 163RP.2		LOCATION ROOM 163										VOLTS 208Y/120V				
FED FROM		MOUNTING Recessed										MAIN				
CKT #		PHASE 3 WIRE 4 FEEDER										BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	DUAL DUPLEX RCPT RM 162	1	1		20	1920	1920	0	0	1920	20		1	2	DUAL DUPLEX RCPT RM 165	2
3	DUAL DUPLEX RCPT RM 162	3	1		20	1920	0	0	0	1920	20		1	4	DUAL DUPLEX RCPT RM 165	4
5	DUAL DUPLEX RCPT RM 162	5	1		20	1920	0	0	0	1920	20		1	6	DUAL DUPLEX RCPT RM 165	6
7	DUAL DUPLEX RCPT RM 162	7	1		20	1920	1920	0	0	1920	20		1	8	DUAL DUPLEX RCPT RM 165	8
9	DUAL DUPLEX RCPT RM 162	9	1		20	1920	0	0	0	1920	20		1	10	DUAL DUPLEX RCPT RM 165	10
11	DUAL DUPLEX RCPT RM 162	11	1		20	1920	0	0	0	1920	20		1	12	DUAL DUPLEX RCPT RM 165	12
13	DUAL DUPLEX RCPT RM 162	13	1		20	1920	1920	0	0	1920	20		1	14	DUAL DUPLEX RCPT RM 161	14
15	DUAL DUPLEX RCPT RM 162	15	1		20	1920	0	0	0	1920	20		1	16	DUAL DUPLEX RCPT RM 161	16
17	DUAL DUPLEX RCPT RM 162	17	1		20	1920	0	0	0	1920	20		1	18	DUAL DUPLEX RCPT RM 161	18
19	DUAL DUPLEX RCPT RM 161	19	1		20	1920	1920	0	0	1920	20		1	20	DUAL DUPLEX RCPT RM 161	20
21	DUAL DUPLEX RCPT RM 161	21	1		20	1920	0	0	0					22	SPARE	22
23	DUAL DUPLEX RCPT RM 163	23	1		20	1920	0	0	0					24	SPARE	24
25	SPARE	25	1		20		0	0	0					26	SPARE	26
27	SPARE	27	1		20		0	0	0					28	SPARE	28
29	SPARE	29	1		20		0	0	0					30	SPARE	30
31	SPARE	31	1		20		0	0	0					32	SPARE	32
33	SPARE	33	1		20		0	0	0					34	SPARE	34
35	SPARE	35	1		20		0	0	0					36	SPARE	36
37	SPARE	37	1		20		0	0	0					38	SPARE	38
39	SPARE	39	1		20		0	0	0					40	SPARE	40
41	SPARE	41	1		20		0	0	0					42	SPARE	42
TOTAL							15360	13440	13440							
TOTAL CONNECTED LOAD (VA)							42240									
(AMPS)																

PANEL 172PP.1		LOCATION ROOM 172										VOLTS 480Y/277V				
FED FROM		MOUNTING Recessed										MAIN				
CKT #		PHASE 3 WIRE 4 FEEDER										BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	JB RM 167	1	3		60	39905	13382	13382	0	39905	60		3	2	JB ROOM 167	2
3		3					13382	13382	0					4		
5		5					13382	13382	0					6		
7	RM 166	7	3		60	39905	13382	13382	0	831	15		3	8	DOOR MOTOR 170	8
9		9					13382	13382	0					10		
11		11					13382	13382	0					12		
13	DOOR MOTOR 173	13	3		15	1496	499	499	0	831	15		3	14	DOOR MOTOR 170	14
15		15					499	499	0					16		
17		17					499	499	0					18		
19	J BOX RM 174	19	3		60	39905	13382	13382	0		15		3	20	SPARE	20
21		21					13382	13382	0					22		
23		23					13382	13382	0					24		
25	JB RM 167	25	3		60	39905	13382	13382	0	39905	60		3	26	JB FUME HOOD 169	26
27		27					13382	13382	0					28		
29		29					13382	13382	0					30		
31	JB BAKE OVEN 169	31	3		60	39905	13382	13382	0		20		3	32	SPARE	32
33		33					13382	13382	0					34		
35		35					13382	13382	0					36		
37	SPARE	37	3		60		0	0	0		30		3	38	SPARE	38
39		39					0	0	0					40		
41		41					0	0	0					42		
TOTAL							94164	94164	94164							
TOTAL CONNECTED LOAD (VA)							282492									
(AMPS)																

PANEL 144RP.1		LOCATION ROOM 144										VOLTS 208Y/120V				
FED FROM		MOUNTING Recessed										MAIN				
CKT #		PHASE 3 WIRE 4 FEEDER										BUS 225				
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	BKR	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	BKR	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RCPT XEROX RM 144	1	3		30	2880	960	1260	0	1260	20		1	2	RCPT RMS 122,147 & 148	2
3		3					960	1260	0	1260	20		1	4	RCPT RMS 122,146,147 & 149	4
5		5					960	1260	0	1000	20		1	6	RCPT RMS 122,123,146 & 147	6
7	DISHWASHER RM 145	7	1		20	1000	1000	720	0	720	20		1	8	REFRIGERATOR RM 145	8
9	RECEPTACLE RM 147	9	1		20	360	0	0	0	1260	20		1	10	RECEPTACLE RMS 123 TO 129	10
11	SPARE	11	1		20		0	0	0	180	20		1	12	RECEPTACLE RM 144	12
13	RECEPTACLE RMS 140 TO 144	13	1		20	1260	1260	0	0	900	20		1	14	RCPT RMS 142,143,144 & 145	14
15	RECEPTACLE	15	1		20	1260	0	0	0	1080	20		1	16	RECEPTACLE RMS 130 TO 135	16
17	RECEPTACLE EWC	17	1		20	1000	0	0	0	1260	20		1	18	RECEPTACLE RMS 136 & 138	18
19	RECEPTACLE RMS 137 & 138	19	1		20	1260	1260	0	0	1260	20		1	20	RECEPTACLE RMS 123 TO 129	20
21	RECEPTACLE RMS 123 TO 127	21	1		20	1260	0	0	0	1080	20		1	22	RCPT RMS 140,141,142 & 145	22
23	DISPOSAL RM 145	23	1		20	1150	0	0	0	7500	50		2	24	L-CS-144-SV-11	24
25	RECEPTACLE RM 138	25	1		20	900	0	0	0					26		
27	L-CS-146-SV-17	27	2		50	7500	0	3750	0	4000	30		2	28	L-CS-123-SV-13	28
29		29					0	3750	0					30		
31	RECEPTACLE RMS 130 TO 135	31	1		20	1080	0	0	0	4000	30		2	32	L-CS-146-SV-14	32
33	RCPT RMS 130,131,133,134 & 135	33	1		20	1080	0	0	0					34		
35	L-CS-144-SV-12	35	2		30	4000	0	2000	0	1260	20		1	36	RECEPTACLE GFCI	36
37		37					2000	0	0	2210	30		1	38	ROOM 121 & 122 LTG	38
39	EXHAUST MOTOR RM 149	39	1		20	1176	0	1176	0	900	15		1	40	ROOM 122 LTG	40
41	PATIO LTG	41	1		15	82	0	0	0				1	42	SPARE	42
TOTAL							21100	19426	19292							
TOTAL CONNECTED LOAD (VA)							59818									
(AMPS)																

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

REVISIONS	NO.	DATE	
-----------	-----	------	--