

VOLUME II ATTACHMENTS

ATTACHMENT 1 *Part I* LIGO-C960964-01-V

1. STRUCTURAL CALCULATIONS

TITLE	DOCUMENT NO.	REVISION
I. LIGO Vacuum Equipment Structural Design Criteria	V049-1-066	0
II. Beam Splitter Chamber		
Finite Element Analysis of Upper Section	V049-1-014	0
ASME Code Calculations for Upper Section	V049-1-015	0
FE Analysis of 1 in. Thick Flange for Bolt Preload	V049-1-016	0
FE Analysis of 1 in. Thick Flange for Bolt Preload & Pos. Pressure	V049-1-017	0
FE Analysis of 3/4 in Thick Flange	V049-1-018	0
Flange Design for Internal Pressure	V049-1-019	0
Design of Removable Work Floor	V049-1-020	0
Design of Flange Welds	V049-1-021	1
Finite Element Analysis of Lower Section	V049-1-022	0
Design of 60 in Access Covers	V049-1-023	0
Design of Support Legs & Base Plates	V049-1-024	0
Temporary Cover for 60 in Nozzle	V049-1-025	0
Nozzle to Shell Welds	V049-1-026	0
Lifting Lugs	V049-1-027	0
Shipping Loads	V049-1-028	0
BSC Deflections	V049-1-029	1
NASTRAN Buckling Analysis	V049-1-040	0
BSC Support Clevis	V049-1-069	0
Nozzle D Analysis For 200 kg Force	V049-1-104	0
BSC Point Loads	V049-1-111	0

TITLE	DOCUMENT NO.	REVISION
III. Vacuum Equipment General Structural Calculations		
Vacuum Equipment Seismic Acceleration	V049-1-031	0
Component Interface Loads	V049-1-032	0
Bolted Flange Analysis for Tensile Forces	V049-1-042	0
Design of Pipe Bridge (Corner Station)	V049-1-071	0
Welds For 60.5 In. Nozzle To Shell Joints	V049-1-107	0
44" Gate Valve Weld Stub/Beamtube Buckling Stress Evaluation	V049-1-122	0
IV. Horizontal Access Module		
Ham Vessel Stress Analysis (Finite Element Analysis)	V049-1-039	0
Ham Vessel Buckling Analysis	V049-1-041	0
Design of Nozzle Jacking Bolt Assembly	V049-1-048	0
Design of 60 inch Cover	V049-1-073	0
Design of 84 inch Cover	V049-1-074	0



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-066 PAGE 1 OF 3
REV.	DEO #	DATE	BY:	CHECK	TITLE: LIGO Vacuum Equipment Structural Design Criteria	
0	0136	4/24/96	RDC	DW		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Establish structural design criteria for LIGO vacuum vessels and supports.						
<u>METHOD:</u> Review LIGO vacuum equipment specification and design codes to determine requirements for structural integrity.						
<u>ASSUMPTIONS:</u> N/A						
<u>INPUTS:</u> LIGO project drawings and sketches. LIGO E940002-02-V, Vacuum Equipment Specification						
<u>REFERENCES:</u> See INPUTS						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> These LIGO vacuum equipment structural design criteria conform to project and code requirements.						
<u>NOTES:</u>						

LIGO VACUUM EQUIPMENT STRUCTURAL DESIGN CRITERIA

Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1, 1992 Edition through 1994 Addenda

Alternate Design Code for Vessels: ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 2, 1992 Edition through 1994 Addenda

Internal Vacuum = -14.7 psig

Positive Internal Pressure = 2 psig for vacuum chambers. Special conditions for 80K cryopumps (see Doc. No. V049-I-056).

Mechanical Loads

- Unbalanced Vacuum Loads - These loads are imposed at end components, and at branches in the system.
- Component Interface Loads - Equipment shall be designed for loads from adjacent components that are imposed when gate valves are closed and portions of the system are vented. See Doc. No. V049-1-032.

Design Temperature = 400° F

Seismic Acceleration = .05625 G (ASCE 7-88) lateral only, single direction

Pressure Boundary Material = SA240, Type 304/304L stainless steel for shells and SA182, Grade F Type 304L for flange forging. Other specification numbers and product forms of Type 304/304L may be used for miscellaneous pressure parts. Flange Bolting Material = SA193, Gr B7.

Basic Stress Limits (Section VIII, Div. 1):

Type 304L

S = 14.7 ksi at 400° F for membrane stress

S = 1.5S = 22 ksi at 400° F for membrane + bending stress

Type 304

S = 16.2 ksi at 400° F for membrane stress

S = 1.5S = 24.3 ksi at 400° F for membrane + bending stress

Basic Stress Limits (Section VIII, Div. 2):

Type 304L

$S_m = 15.8$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 23.7$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 47.4$ ksi at 400° F for Secondary Membrane + Bending

Type 304

$S_m = 18.7$ ksi at 400° F for Primary Membrane Stress Intensity

$1.5S_m = 28.0$ ksi at 400° F for Primary Bending Stress Intensity

$3S_m = 56.1$ ksi at 400° F for Secondary Membrane + Bending

O-Ring Seal Material = Viton (1/4 in)

Maximum Durometer = 90

Compression Range = .058 in to .080 in (21% to 29 %)

Maximum Compression Force = 160 lb/in

Shipping Acceleration

Vertical Accel = 1G

Horizontal Accel = .5G

Design Code for Supports: AISC Manual of Steel Construction, Allowable Stress Design, Ninth Edition.

Material for Supports: A36 shapes and plate, A500 Gr B tube steel. See AISC Code for allowable stresses.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-014 PAGE 1 OF 16
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of Upper Section	
0	0024	12/6/95	RDC	WDB		
					BY: R.D. Ciario	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<u>PURPOSE:</u> To evaluate the upper section of the beam splitter chamber for vacuum pressure and lifting loads.						
<u>METHOD:</u> Finite element analysis of vessel upper section including cylinder, head and lifting lugs. 563 nodes and 537 elements.						
<u>ASSUMPTIONS:</u> Ring stiffener and nozzle omitted from analysis since area of interest is shell near lug.						
<u>INPUTS:</u> LIGO project sketches and drawings. The thickness of the cylinder is .25 in and the thickness head is .375 in.						
<u>REFERENCES:</u> 1. ASME Boiler and Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. Images - 3D, Version 3.0, R.L. Cloud & Associates. 3. Doc. No V049-1-006, LIGO Vacuum Equip., Same Dept. as V049-1-015						
<u>CALCULATIONS:</u> (See Attachment)						
<u>CONCLUSIONS:</u> Stresses in head and shell in the area of the lifting lugs are within limits of ASME Code, Section VIII, Div. 1. A spreader beam should be used when lifting vessel.						
<u>NOTES:</u> See stress contour plots attached. See V049-1-015 for buckling analysis per the ASME Code. Computer File: 1350 V049-1-015						

FINITE ELEMENT ANALYSIS OF BEAM SPLITTER CHAMBER UPPER SECTION

THE PURPOSE OF THIS ANALYSIS IS TO EVALUATE THE UPPER HEAD AND CYLINDER OF THE BEAM SPLITTER CHAMBER FOR THE EFFECTS OF VACUUM PRESSURE AND LIFTING LUG LOADS. IT IS NOTED THAT THE UPPER HEAD IS A FLANGED AND DISKED HEAD WITH A CROWN RADIUS OF 105 IN AND A THICKNESS OF 3/4 IN. THE THICKNESS OF THE STRAIGHT CYLINDER IS 1/2 IN.

TO TAKE ADVANTAGE OF SYMMETRY, THE MODEL EXTENDS 180° AROUND ITS CIRCUMFERENCE.

IMAGES WAS USED FOR THE MODEL WHICH IS FILED AS


FILE NAME: BSCUPPER

THE STRESS INTENSITY PLOTS SHOWN IN THIS SECTION CONFIRM THAT STRESSES ARE LOW AND MEET THE REQUIREMENTS OF ASME SECT. VIII, DIV. 1, PAR UG-23(c)

PRIMARY MEMBRANE STRESS $\leq S_{all} = 14.7 \text{ ksi}$
@ 400°F

PRIMARY MEMBRANE + BENDING STRESS $\leq 1.5 S_{all}$
 $= 22 \text{ ksi}$
@ 400°F

IMAGES-3D
Ver. 3.0
Geometry Plot



BEAM SPLITTER CHAMBER - UPPER SECTION CYLINDER & HEAD
Hidden Line Removal

10/25/95
13:53:32

Revision 0
Doc. No. V049-1-014
Page 3 of 16

MATERIAL PROPERTIES OF SA 240 TYPE 304 L
AT 400 °F

MODULUS OF ELASTICITY

$$26.5 \times 10^6 \text{ PSI}$$

POISSON'S RATIO

$$\nu = .3$$

COEF. OF THERMAL EXPANSION

$$\alpha = 9.19 \times 10^{-6}$$

DENSITY

$$\rho = .290 \text{ LB/IN}^3$$


THESE PROPERTIES ARE GIVEN IN IMAGES
MODELS FOR TYPE 304L SS.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




IMAGES-3D
Ver. 3.0
Geometry Plot

BOUNDARY CONDITIONS SHOWN



?





Revision 0
Doc. No. V049-1-014
Page 4 of 16

Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
--------------	-----------------	---------------	---------------	--------------	----------------	-----------------	---------------

IMAGES FE MODEL

KEY NODE NUMBERS



$$\theta = 90 - \frac{180}{27}$$

$$= 83.3333^\circ$$

$$y = 52.25 \cos 83.3333$$

$$= 6.0653$$

$$z = 48$$

$$z = 52.25 \sin 83.3333$$

$$= 51.8967$$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS





1.000 [25.4]

← 2.1250 [53.975]

39.438 [1001.7]
35.438 [900.1]

11.750 [298.5]





12.000 [304.8]


LUG

Revision 0
Doc. No. V049-1-014
Page 7 of 16

LUG

NODES 534 TO 541 ARE ADDED AT MID SURFACE OF PLATE


50 SHEETS
100 SHEETS
200 SHEETS



ELEMENTS 229 TO 231, 254 TO 258 WERE DELETED AND REPLACED WITH ELEMENTS WITH ABOVE NODES

ADDITIONAL NODES WILL BE OFFSET FROM NODES 534 TO 541 WITH RIGID ELEMENTS. THESE NEW ELEMENTS WILL REPRESENT THE EXISTING LUG

ASSUME LUG IS 1 IN THICK. RADII TO MID SURFACE IS



$$r = 52.25 + .125 + .5 = 52.875 \text{ IN}$$

$$\theta = \tan^{-1} \left(\frac{6.0659}{51.8967} \right) = 6.6667^\circ$$



$$y = r \sin \theta = 52.875 \sin 6.6667 = 6.1385 \text{ IN}$$

$$z = r \cos \theta = 52.875 \cos 6.6667 = 52.5175 \text{ IN}$$

IMAGES-3D
 Ver. 3.0
 Geometry Plot

- 5-Solid or 5,F,I
- 6-Spring or 6,F,I
- 7-Rigid or 7,F,I
- 8-No element numbers
- 9-All elemt. numbers
- 10-Exit or 10,Size

?9
 ?#
 ?h,n
 ?n
 ?n
 ?n
 ?



Auto Blowup Elen# Exit Full Help Local Move
 Node Node# Plot Range Rest Rotate Shrink Slice

LUG NODES 563 566 549 - y-90

LOAD THIS NODE 555 43

555 76

555 69

555 60 RIGID ELEMENTS

555 54

557 580 543 - z = 48

RIGID ELEMENTS

I	J	TYPE	RELEASE
{ 534	543	1	0
	535		
	536		
{ 537	540	1	0
	538		
	539		
{ 540	557	1	0
	541		
	542		

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PLATES 1 TO 25 HAVE EXT. PRESSURE.

LUG LOADS (NO DIS 555)

VERTICAL (LOAD CASE 2)


TOTAL ESTIMATED WEIGHT

$$W = 12500 \text{ LB}$$

$$F_{Y555} = \frac{12500}{2}$$

$$= 6250 \text{ LB}$$

FOR LEFT TO VERTICAL POSITION FROM
HORIZONTAL CONSTRUCTION, SHIPBOARD
POSITION, LOAD IS IN X-DIRECTION
ASSUME VESSEL PIVOTS ABOUT BASE
PLATE & CG IS MIDWAY BETWEEN
BASE PLATE AND EYE OF LUG






$$F_x = \frac{W}{2} \times \frac{S}{2} \div S = \frac{W}{4}$$

$$= \frac{12500}{4} = 3125 \text{ LB}$$

LOAD CASE 3

$$F_{Y555} = 3125$$

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 12 of 16



Load Case
1

Stress Contour Plot
Surf: Bottom
Stress Intensity

10/25/95
10:46:21

Vacuum Pressure

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 13 of 16

Load Case
2




Surf: Top

Stress Contour Plot
Stress Intensity

10/25/95
10:48:56

VERTICAL LUG 2010

IMAGES-3D
Version 3.0





Revision 0
Doc. No. V049-1-014
Page 14 of 16

Load Case
2

Stress Contour Plot
Surf: Middle
Stress Intensity

10/25/95
10:52:10

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 15 of 16

Load Case
3


Stress Contour Plot
Surf: Middle

Stress Intensity

10/25/95
10:54:34

HORIZONTAL LUG LOADS

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-014
Page 16 of 16

Load Case
3

Displacement Contour Plot
DX

10/25/95
11:21: 2

15

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-015 PAGE 1 OF 57
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - ASME Code Calculations for Upper Section.	
0	0024	12/6/95	RDC	P.W.Y.		
					BY: R. D. Chiaro	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p><u>PURPOSE:</u> To determine if the upper section of the beam splitter chamber meets Section VIII, Div. 1 of the ASME Code for vacuum pressure.</p>						
<p><u>METHOD:</u> Equations for thickness requirements and pressure rating in the ASME Code, Section VIII, Div.1 are evaluated using the COMPRESS computer program, Version 5.31.</p>						
<p><u>ASSUMPTIONS:</u></p>						
<p><u>INPUTS:</u> Vacuum pressure = 14.7 psi Design temperature = 400⁰F</p>						
<p><u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. COMPRESS 5.31, Computer Aided Pressure Vessel Design, Codeware Computer Systems, Inc. 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN REPORT</p>						
<p><u>CALCULATIONS:</u> (See Attached)</p>						
<p><u>CONCLUSIONS:</u> Requirements of the ASME Code, Section VIII, Div. 1 are met for the BSC upper section head and cylinder.</p>						
<p><u>NOTES:</u> Nozzle G in lower section is included in this analysis. This nozzle penetrates the 1/2 in. shell. No reinforcing pad is required by code.</p>						

THE COMPRESS PROGRAM IS USED TO
EVALUATE THE UPPER SECTION OF THE
BSC. THIS INCLUDES:

TOP HEAD


UPPER CYLINDRICAL SHELL (ABOVE
FLANGE)

SHELL STIFFENER

MAIN CYLINDRICAL SHELL (BELOW
FLANGE) DOES NOT INCLUDE
NOZZLES

COMPRESS FILENAME: BSCUPPER.JSL

NOTE: THE 1/2 IN LOWER SHELL
INCLUDING NOZZLE 6 IS ALSO
INCLUDED IN THE COMPRESS MODEL.





NOZZLE E (LOCATED ON 1/4 IN SHELL)

RADIAL LOAD FROM VACUUM PAD.

$$F_R = \pi r^2 p$$

$$r = \frac{13.75}{2} = 6.875 \text{ IN INSIDE RADIUS}$$

$$p = 14.7 \text{ PSI}$$

$$F_R = \pi (6.875)^2 (14.7)$$

$$= 2183 \text{ LB}$$

WRC 107 ANAL BY COMPRESS

MAX STRESS IS

$$f = 13222 \text{ PSI AT EDGE OF REIN. PAD}$$

$$f = 4686 \text{ PSI AT NOZZLE O.D.}$$

PAD AFO'D (COMPRESS) FOR NOZ E ON OPEN SECTION

$$O.D. = 20" \times t = .25 \text{ IN} *$$

WELDS FROM COMPRESS *

INNER FILLET = .125


OUTER " = .25

VACUUM GROOVE = 0

LOWELL GROOVE = .25

PAD FOR VACUUM SERVICE

*.5 IN USED TO COMPENSATE FOR GAP



Ø SHELL

* WELDS WERE MODIFIED FOR VACUUM SERVICE SEE V 049-1-026

Ø NOZ



NOZZLE G (LOCATED ON 1/2 IN SHELL)
RADIAL LOAD FROM VACUUM PRESSURE

$$F_R = \pi r^2 p$$

$$r = \frac{7.75}{2} = 3.875$$

$$p = 14.7 \text{ psi}$$

$$F_R = \pi (3.875)^2 (14.7)$$

$$= 693.4 \text{ LB}$$

MAX STRESS FROM WRC 107


$$f = 2378 \text{ psi}$$

NO REINFORCEMENT REQ'D FOR THIS NOZZLE
SINCE IT IS ATTACHED TO 1/2" VESSEL

REQUIRED WELDS FROM COMPARISONS *

$$\text{FILLET WELD} = .125$$

$$\text{GROOVE WELD} = .1875$$



* WELDS WERE MODIFIED
FOR VACUUM VESSEL SERVICE

Top Head - BSC

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1232.9 corr = 1232.9 lb
 capacity: new = 468.96 corr = 468.96 US ga

ID = 104.25 crown L = 105 knuckle r = 6.5 t = .375 in (min)

Straight flange = 2 forming allowance = 0 in

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^.5)$$

$$= .25*(3 + (105/6.5)^.5)$$

$$= 1.7548$$

$$t = P*L*M/(2*S*E - 0.2*P) + Corrosion + fa$$

$$= 2*105*1.7548/(2*14700*0.85 - 0.2*2) + 0 + 0$$

$$= 0.0147 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*16700*0.85*0.375/(105*1.7548 + 0.2*0.375) - 0$$

$$= 57.75679 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.375/(105*1.7548 + 0.2*0.375) - 0$$

$$= 50.83981 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(Ro/t)$$

$$= .125/(105.375/0.32589)$$

$$= 0.000387$$

From table HA-3: B = 4755.5

Rev 0
 Doc V049-1-015
 Page 6 of 57

Top Head - BSC

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4755.5/(105.375/0.32589) \\ &= 14.7072 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67*Pa*Lo*M/(2*S*E + 1.67*Pa*(M-0.2)) \\ &= 1.67*14.7072*105.375*1.7548/(2*14700*1 + 1.67*14.7072*(1.7548-0.2)) \\ &= 0.154277 \text{ in} \end{aligned}$$

Design thickness for external pressure Pa = 14.7072 psi:

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.32589 + 0 + 0 \\ &= 0.32589 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(105.375/0.375) \\ &= 0.000445 \end{aligned}$$

From table HA-3: B = 4873.8

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4873.8/(105.375/0.375) \\ &= 17.3445 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pe &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.375/((1.7548*105.375 - 0.375*(1.7548-0.2))*1.67) \\ &= 35.81529 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 17.3445 psi.

REV 0
Doc. No. V049-1-015

*ANALYSIS FOR THICKNESS
REQUIRED BY 1/32"*

Top Head - BSC

ASME Section VIII Division 1, 1992 Edition, A93 Addenda.

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1128.8 corr = 1128.8 lb
 capacity: new = 468.96 corr = 468.96 US ga

ID = 104.25 crown L = 105 knuckle r = 6.5 t = .34375 in (min)
 = 11/32
 Straight flange = 2 forming allowance = 0 in

WARNING! F&D head geometry is not per UG-32(j).

(Crown R10 = 125 > OD = 104 5/16)

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^{.5})$$

$$= .25*(3 + (105/6.5)^{.5})$$

$$= 1.7548$$

$$t = P*L*M/(2*S*E - 0.2*P) + Corrosion + fa$$

$$= 2*105*1.7548/(2*14700*0.85 - 0.2*2) + 0 + 0$$

$$= 0.0147 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*16700*0.85*0.34375/(105*1.7548 + 0.2*0.34375) - 0$$

$$= 52.94551 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps$$

$$= 2*14700*0.85*0.34375/(105*1.7548 + 0.2*0.34375) - 0$$

$$= 46.60474 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(Ro/t)$$

$$= .125/(105.3438/0.32589)$$

Top Head - BSC

$$= 0.000387$$

From table HA-3:

$$B = 4754.8$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4754.8/(105.3438/0.32589) \\ &= 14.7094 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67*Pa*Lo*M/(2*S*E + 1.67*Pa*(M-0.2)) \\ &= 1.67*14.7094*105.3438*1.7548/(2*14700*1 + 1.67*14.7094*(1.7548-0.2)) \\ &= 0.154254 \text{ in} \end{aligned}$$

Design thickness for external pressure Pa = 14.7094 psi:

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.32589 + 0 + 0 \\ &= 0.32589 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(105.3438/0.34375) \\ &= 0.000408 \end{aligned}$$

From table HA-3:

$$B = 4797.2$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4797.2/(105.3438/0.34375) \\ &= 15.6539 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pe &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.34375/((1.7548*105.3438 - 0.34375*(1.7548-0.2))*1.67) \\ &= 32.83179 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 15.6539 psi.

Upper Cylindrical Shell - BSCASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH

Internal design pressure: $P = 2$ psi @ 400 deg F
 External design pressure: $P_e = 14.7$ psi @ 400 deg F

Corrosion allowance: Inner $C = 0$ Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 1428.1 corr = 1428.1 lb
 capacity: new = 2217.078 corr = 2217.078 US ga

ID = 104.25 length $L_c = 60$ $t = 0.25$ in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.125 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0083 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.25 / (52.125 + 0.6 \cdot 0.25) - 0$$

$$= 67.88618 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.25 / (52.125 + 0.6 \cdot 0.25) - 0$$

$$= 59.7561 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 37.90131/104.75 = 0.3618 \quad Do/t = 104.75/0.23897 = 438.3395$$

From table G: $A = 0.000425$
 From table HA-3: $B = 4834.6$

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 4834.6 / (3 \cdot 104.75/0.23897)$$

$$= 14.7058 \text{ psi}$$

Design thickness for external pressure $P_a = 14.7058$ psi:

$$= t + \text{Corrosion}$$

$$= 0.23897 + 0$$

REV 0
 Doc No 1009-1-015
 Page 10 of 57

Upper Cylindrical Shell - BSC

$$= 0.23897 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$L/Do = 37.90131/104.75 = 0.3618 \quad Do/t = 104.75/0.25 = 419$$

$$\text{From table G:} \quad A = 0.000452$$

$$\text{From table HA-3:} \quad B = 4887.2$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*4887.2/(3*104.75/0.25) \\ &= 15.5519 \text{ psi} \end{aligned}$$

REV. 0
Doc. NO. 1049-1-015

Shell StiffenerStiffening Ring Calculations Per UG-29ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Identifier:	Shell Stiffener
Ring material specification:	SA 240 304L HIGH
Number of rings in this group:	1
Distance first ring to datum line:	110 in
Ring spacing:	0 in
Ring description:	4x4x1/4 Equal Angle
Ring is rolled:	leg out (easy way)
Ring cross sectional area:	As = 1.94 in ²
Ring moment of inertia:	Ir = 3.04 in ⁴

Calculations for ring 110 in from datum

Shell material specification:	SA 240 304L HIGH
Required shell thickness:	t = 0.23897 in
Corroded shell thickness:	ts = 0.25 in
Shell outer diameter:	Do = 104.75 in
Design temperature:	= 400 deg F
External design pressure:	P = 14.7 psi
Stiffener supported length:	Ls = 33.95065 in

$$B = .75*(P*Do/(t + As/Ls))$$

$$= .75*(14.7*104.75/(0.23897 + 1.94/33.95065))$$

$$= 3900.111$$

From table HA-3 (ring) A = 2.949634E-04

Required moment of inertia of the combined ring-shell section

$$I_s = (Do^2 * Ls * (t + As/Ls) * A) / 10.9$$

$$= (104.75^2 * 33.95065 * (0.23897 + 1.94/33.95065) * 2.949634E-04) / 10.9$$

$$= 2.985063 \text{ in}^4$$

Available moment of inertia of the combined ring-shell section

Shell width contributing smaller of = 5.62911

$$W = 1.1 * \text{Sqr}(Do * ts)$$

$$= 1.1 * \text{Sqr}(104.75 * 0.25)$$

$$= 5.62911 \text{ in}$$

$$W = Ls = 33.95065 \text{ in}$$

$$\text{Shell area } A_1 = W * ts = 1.407277 \text{ in}^2$$

Distance to the ring neutral axis

Shell Stiffener

$$\begin{aligned} Y2 &= \text{Ring NA} + ts/2 \\ &= 1.09 + 0.25/2 \\ &= 1.215 \text{ in} \end{aligned}$$

Neutral axis of combined section

$$\begin{aligned} \text{NA} &= A_s * Y2 / (A_1 + A_s) \\ &= 1.94 * 1.215 / (1.407277 + 1.94) \\ &= .7041842 \text{ in} \end{aligned}$$

Inertia of the shell about the combined section NA

$$\begin{aligned} I1 &= W * ts^3 / 12 + A1 * \text{NA}^2 \\ &= 5.62911 * 0.25^3 / 12 + 1.407277 * 0.7041842^2 \\ &= .7051639 \text{ in}^4 \end{aligned}$$

Inertia of the ring about the combined section NA

$$\begin{aligned} I2 &= I_r + A_s * (\text{NA} - Y2)^2 \\ &= 3.04 + 1.94 * (0.7041842 - 1.215)^2 \\ &= 3.54621 \text{ in}^4 \end{aligned}$$

$$\text{Total available } I = I1 + I2 = 4.251373 \text{ in}^4$$

The 4x4x1/4 Equal Angle vacuum stiffener is satisfactory.

REV 0
Doc No V049-1-015

RING STIFFENER CONNECTION WELD - PER ASME
VIII-1, UG-30

USE INTERMITTENT WELD STAGGERED, 2 IN
@ 4 IN

MAX CLEAR SPACING

$$S = 2 \text{ IN} = 8t \text{ FOR EXT. RING - OK}$$

$$t = .25 \text{ IN SHELL THICKNESS}$$

1) RADIAL PRESS LOAD

$$PL_s = 14.7(30) = 441 \text{ LB/IN}$$

2) RADIAL SHEAR LOAD

$$.01 PL_s D_o = .01(441)(105) \\ = 463 \text{ LB}$$

FOR A 4 IN SPACING THE TOTAL RADIAL
PRESS LOAD IS

$$F = 4 PL_s = 4(441) = 1764 \text{ LB}$$

WELD AREA FOR $t = 3/16$

$$A_w = 2 \times 2 \times .707(3/16) = .53 \text{ IN}^2$$

WELD SHEAR STRESS

$$f_v = \frac{F}{A_w} = \frac{1764}{.53} = 3300 \text{ PSI OK} \\ < .55(14700) = 8085 \text{ PSI}$$

MIN WELD SIZE IS $1/4$ " (UG 30f)

∴ USE $1/4$ IN 2 IN @ 4 IN STAGGERED



Main Section Cylinder

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 3817.3 corr = 3817.3 lb
 capacity: new = 2956.104 corr = 2956.104 US ga

ID = 104.25 length Lc = 80 t = 0.5 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.125 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0083 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.5 / (52.125 + 0.6 \cdot 0.5) - 0$$

$$= 135.3839 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.5 / (52.125 + 0.6 \cdot 0.5) - 0$$

$$= 119.1702 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 80/105.25 = 0.7601 \quad Do/t = 105.25/0.30747 = 342.3098$$

From table G: A = 0.000288
 From table HA-3: B = 3807.2

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 3807.2 / (3 \cdot 105.25/0.30747)$$

$$= 14.8295 \text{ psi}$$

Design thickness for external pressure Pa = 14.8295 psi:

$$= t + \text{Corrosion}$$

$$= 0.30747 + 0$$

REV 0
 Doc. No. V049-1-015
 Page 14 OF 57

Main Section Cylinder

$$= 0.30747 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} L/Do &= 80/105.25 = 0.7601 & Do/t &= 105.25/0.5 = 210.5 \\ \text{From table G:} & & A &= 0.000587 \\ \text{From table HA-3:} & & B &= 5117.2 \end{aligned}$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*5117.2/(3*105.25/0.5) \\ &= 32.413 \text{ psi} \end{aligned}$$

Nozzle E


Opening N-E Reinforcement Calculations Per UG-37

Located on: Upper Cylindrical Shell - BSC
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 14 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Pad material specification: SA 240 304L HIGH

Nozzle orientation: 45 degrees
 End of nozzle to shell center: 55.875 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3.5 in



Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75$ in
 Normal to the vessel wall outside $2.5*(t_n - C_n) + t_e = .55$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$\begin{aligned}
 t_{rn} &= P \cdot R_n / (S_n \cdot E - 0.6 \cdot P) \\
 &= 2 \cdot 6.875 / (14700 \cdot 1 - 0.6 \cdot 2) \\
 &= 0.0009 \text{ in}
 \end{aligned}$$

Required thickness t_r from UG-37(a)

$$\begin{aligned}
 t_r &= P \cdot R / (S \cdot E - 0.6 \cdot P) \\
 &= 2 \cdot 52.125 / (14700 \cdot 1 - 0.6 \cdot 2) \\
 &= 0.0071 \text{ in}
 \end{aligned}$$

Area required

Rev 0
Doc. No. V049-1-015

Nozzle E

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700$ psi

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$
 $fr3 = \text{lesser of } fr2 \text{ or } S_p/S_v \text{ so } fr3 = 1$
 $fr4 = \text{lesser of } 1 \text{ or } S_p/S_v \text{ so } fr4 = 1$

$$A = d*tr*F + 2*tn*tr*F*(1 - fr1)$$

$$= 13.75*0.0071*1 + 2*0.12*0.0071*1*(1 - 1)$$

$$= .0976 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} = 3.34 \text{ in}^2$$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$

$$= 13.75*(1*0.25-1*0.0071) - 2*0.12*(1*0.25-1*0.0071)*(1-1)$$

$$= 3.34 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$

$$= 2*(0.25+0.12)*(1*0.25-1*0.0071) - 2*0.12*(1*0.25-1*0.0071)*(1-1)$$

$$= .18 \text{ in}^2$$

$$A2 = \text{smaller of the following} = 0.131 \text{ in}^2$$

$$= 5*(tn - trn)*fr2*t$$

$$= 5*(0.12 - 0.0009)*1*0.25$$

$$= .149 \text{ in}^2$$

$$= 2*(tn - trn)*(2.5*tn + te)*fr2$$

$$= 2*(0.12 - 0.0009)*(2.5*0.12 + 0.25)*1$$

$$= .131 \text{ in}^2$$

$$A41 = \text{Leg}^2*fr3$$

$$= 0.125^2*1 = .016 \text{ in}^2$$

$$A42 = \text{Leg}^2*fr4$$

$$= 0.25^2*1 = .063 \text{ in}^2$$

$$A5 = (Dp - d - 2*tn)*te*fr4$$

$$= (20 - 13.75 - 2*0.12)*0.25*1$$

$$= 1.5025 \text{ in}^2$$

$$\text{Area} = A1 + A2 + A41 + A42 + A5$$

$$= 3.34 + 0.131 + 0.016 + 0.063 + 1.5025$$

$$= 5.0525 \text{ in}^2$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(c)(2)

Inner Fillet: $t_{min} = \text{lesser of } 0.75 \text{ or } t_n \text{ or } t_e$, $t_{min} = 0.12 \text{ in}$
 $tw(\text{min}) = 0.7*t_{min} = 0.084 \text{ in}$

REV 0
 Doc No 1049-1-015
 Page 17 of 57

Nozzle E

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.125 = 0.0875 \text{ in}$$

Outer Fillet: $t_{\min} = \text{lesser of } 0.75 \text{ or } t_e \text{ or } t, t_{\min} = 0.25 \text{ in}$

$$tw(\text{min}) = 0.5 * t_{\min} = 0.125 \text{ in}$$

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a): $tr1 = 0.0009 \text{ in (E = 1)}$

Wall thickness per UG-45(b)(1): $tr2 = 0.0071 \text{ in}$

Wall thickness per UG-16(b): $tr3 = 0.0625 \text{ in}$

Std pipe wall per UG-45(b)(4): $tr4 = 0.328125 \text{ in}$

The greater of $tr2$ or $tr3$: $tr5 = 0.0625 \text{ in}$

The lesser of $tr4$ or $tr5$: $tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.12 \text{ in}$

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 14700 = 10878 \text{ psi}$

Nozzle wall in shear = $0.7 * 14700 = 10290 \text{ psi}$

Inner fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Outer fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Strength of welded joints:

(1) Inner fillet weld in shear

$$(Pi/2) * \text{Nozzle O.D.} * \text{Leg} * Si = 1.57 * 13.99 * 0.125 * 7203 = 19776.11 \text{ lbf}$$

(2) Outer fillet weld in shear

$$(Pi/2) * \text{Pad O.D.} * \text{Leg} * So = 1.57 * 20 * 0.25 * 7203 = 56543.55 \text{ lbf}$$

(3) Nozzle wall in shear

$$(Pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 13.87 * 0.12 * 10290 = 26888.88 \text{ lbf}$$

(4) Groove weld in tension

$$(Pi/2) * \text{Nozzle O.D.} * tw * S_g = 1.57 * 13.99 * 0.25 * 10878 = 59731.91 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E1 * t - F * tr)) * S_v \\ &= (0.0976 - (13.75 - 2 * 0.12) * (1 * 0.25 - 1 * 0.0071)) * 14700 \\ &= -46804.49 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * S_v \\ &= (0.131 + 1.5025 + 0.016 + 0.063) * 14700 \\ &= 25173.75 \text{ lbf} \end{aligned}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2 * t_n * t * fr1) * S_v$$

Rev. 0
Doc No. V049-1-015

Nozzle E

$$= (0.131 + 0 + 0.016 + 0 + 2*0.12*0.25*1)*14700$$

$$= 3042.9 \text{ lbf}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2*tn*t*fr1)*Sv$$

$$= (0.131 + 0 + 1.5025 + 0.016 + 0.063 + 0 + 2*0.12*0.25*1)*14700$$

$$= 26055.75 \text{ lbf}$$

Load for path 1-1 lesser of W or W1-1 = -46804.49 lbf
 Path 1-1 Thru (2) & (3) = 56543.55 + 26888.88 = 83432.43 lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -46804.49 lbf
 Path 2-2 Thru (1), (4) = 19776.11 + 59731.91 = 79508.02 lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 3-3 lesser of W or W3-3 = -46804.49 lbf
 Path 3-3 Thru (2), (4) = 56543.55 + 59731.91 = 116275.5 lbf
 Path 3-3 is stronger than W so it is acceptable per UG-41(b)(2).

Pad strength = $A5*Sp = 22086.75 \text{ lbf}$
 Outer fillet weld strength is adequate.

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75 \text{ in}$
 Normal to the vessel wall outside $2.5*(tn-Cn) + te = .55 \text{ in}$
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3 \text{ in}$

Nozzle required thickness

$$L/Do = 3.5/13.99 = .2502 \quad Do/t = 13.99/0.03032 = 461.4116$$

From table G: $A = 0.000587$
 From table HA-3: $B = 5117.2$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*5117.2/(3*13.99/0.03032)$$

$$= 14.7871 \text{ psi}$$

Nozzle required thickness $trn = .03032 \text{ in}$

Required thickness tr from UG-37(d)(1) = .239 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700 \text{ psi}$

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$
 $fr3 = \text{lesser of } fr2 \text{ or } S_p/S_v \text{ so } fr3 = 1$
 $fr4 = \text{lesser of } 1 \text{ or } S_p/S_v \text{ so } fr4 = 1$

REV 0

Doc. No V049-1-015

Nozzle E

$$\begin{aligned}
 A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\
 &= 0.5*(13.75*0.239*1 + 2*0.12*0.239*1*(1 - 1)) \\
 &= 1.6431 \text{ in}^2
 \end{aligned}$$

Area available

$$\begin{aligned}
 A1 &= \text{larger of the following} && = .151 \text{ in}^2 \\
 &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 13.75*(1*0.25-1*0.239) - 2*0.12*(1*0.25-1*0.239)*(1-1) \\
 &= .151 \text{ in}^2 \\
 &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 2*(0.25+0.12)*(1*0.25-1*0.239) - 2*0.12*(1*0.25-1*0.239)*(1-1) \\
 &= .008 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A2 &= \text{smaller of the following} && = 0.099 \text{ in}^2 \\
 &= 5*(tn - tm)*fr2*t \\
 &= 5*(0.12 - 0.03032)*1*0.25 \\
 &= .112 \text{ in}^2 \\
 &= 2*(tn - tm)*(2.5*tn + te)*fr2 \\
 &= 2*(0.12 - 0.03032)*(2.5*0.12 + 0.25)*1 \\
 &= .099 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A41 &= \text{Leg}^2*fr3 \\
 &= 0.125^2*1 = .016 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A42 &= \text{Leg}^2*fr4 \\
 &= 0.25^2*1 = .063 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A5 &= (Dp - d - 2*tn)*te*fr4 \\
 &= (20 - 13.75 - 2*0.12)*0.25*1 \\
 &= 1.5025 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area} &= A1 + A2 + A41 + A42 + A5 \\
 &= 0.151 + 0.099 + 0.016 + 0.063 + 1.5025 \\
 &= 1.8315 \text{ in}^2
 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.03032 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0522 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.328125 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Nozzle E

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_e .

REV 0

Doc. No. Y049-1-015

Page 21 OF 57

Nozzle EApplied Loads

Radial load	$P_r = 2183$ lbf
Circumferential moment	$M_c = 0$ lbf-ft
Circumferential shear	$V_c = 0$ lbf
Longitudinal moment	$M_L = 0$ lbf-ft
Longitudinal shear	$V_L = 0$ lbf
Torsion moment	$M_t = 0$ lbf-ft
Internal pressure	$P = 2$ psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean radius } R_m = 52.25 \text{ in}$$

$$R_m/t = 104.5$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.5

$$I = .25*(4 + 3*(r/x)^2 + 3*(r/x)^4)$$

$$= .25*(4 + 3*(6.875/7.12)^2 + 3*(6.875/7.12)^4)$$

$$= 2.351$$

$$\text{Local circ. pressure stress} = I*P*R_m/t = 491 \text{ psi}$$

$$\text{Local long. pressure stress} = P*R_m/2t = 104 \text{ psi}$$

$$\text{Maximum combined stress} = -4686 \text{ psi}$$

$$\text{Allowable combined stress} = +3*S = \pm 44100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -1154 \text{ psi}$$

$$\text{Allowable primary membrane stress} = \pm 1.5*S = \pm 22050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

REV 0

Doc. No. V049-1-015

Page 22 of 57

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	10.677	0.117					-892	-892	-892	-892
4C*	15.057	0.117	-1258	-1258	-1258	-1258				
1C	0.0765	0.117					-4008	4008	-4008	4008
2C-1	0.0440	0.117	-2305	2305	-2305	2305				
3A*	4.1315	0.117								
1A	0.0774	0.117								
3B*	11.036	0.117								
1B-1	0.0281	0.117								
pressure stress*			491	491	491	491	491	491	491	491
Total circ stress			-3072	1538	-3072	1538	-4409	3607	-4409	3607
Primary membrane circ stress*			-767	-767	-767	-767	-401	-401	-401	-401
3C*	10.677	0.117	-892	-892	-892	-892				
4C*	15.057	0.117					-1258	-1258	-1258	-1258
1C-1	0.0744	0.117	-3898	3898	-3898	3898				
2C	0.0467	0.117					-2447	2447	-2447	2447
4A*	7.5665	0.117								
2A	0.0389	0.117								
4B*	4.0872	0.117								
2B-1	0.0385	0.117								
pressure stress*			104	104	104	104	104	104	104	104
Total long stress			-4686	3110	-4686	3110	-3601	1293	-3601	1293
Primary membrane long stress*			-788	-788	-788	-788	-1154	-1154	-1154	-1154
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-4686	3110	-4686	3110	-4409	3607	-4409	3607

REV 0

Doc. No. V049-1-015

Page 23 of 57

Nozzle EStresses at the pad edge per WRC bulletin 107 (psi)

Mean radius $R_m = 52.25$ in
 $R_m/t = 209$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned} I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\ &= .25*(4 + 3*(6.875/10.25)^2 + 3*(6.875/10.25)^4) \\ &= 1.489 \end{aligned}$$

Local circ. pressure stress = $I*P*R_m/t = 622$ psi

Local long. pressure stress = $P*R_m/2t = 209$ psi

Maximum combined stress = -13222 psi
 Allowable combined stress = $+3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -3300 psi
 Allowable primary membrane stress = $+1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	8.2255	0.167					-1375	-1375	-1375	-1375
4C*	20.996	0.167	-3509	-3509	-3509	-3509				
1C	0.0595	0.167					-12469	12469	-12469	12469
2C-1	0.0148	0.167	-3102	3102	-3102	3102				
3A*	6.4789	0.167								
1A	0.0553	0.167								
3B*	13.437	0.167								
1B-1	0.0104	0.167								
pressure stress*			622	622	622	622	622	622	622	622
Total circ stress			-5989	215	-5989	215	-13222	11716	-13222	11716
Primary membrane circ stress*			-2887	-2887	-2887	-2887	-753	-753	-753	-753
3C*	8.2255	0.167	-1375	-1375	-1375	-1375				
4C*	20.996	0.167					-3509	-3509	-3509	-3509
1C-1	0.0390	0.167	-8173	8173	-8173	8173				
2C	0.0353	0.167					-7398	7398	-7398	7398
4A*	17.794	0.167								
2A	0.0238	0.167								
4B*	5.7771	0.167								
2B-1	0.0144	0.167								
pressure stress*			209	209	209	209	209	209	209	209
Total long stress			-9339	7007	-9339	7007	-10698	4098	-10698	4098
Primary membrane long stress*			-1166	-1166	-1166	-1166	-3300	-3300	-3300	-3300
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-9339	7007	-9339	7007	-13222	11716	-13222	11716

Rev 0
Doc No 4049-1-015
Page 25 of 57


Nozzle G

Opening N-G Reinforcement Calculations Per UG-37

Located on: Main Section Cylinder
 Local vessel thickness: .5 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
 End of nozzle to shell center: 55.625 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3 in



corrosion allow = 0 in
 noz thick new tn = .12 in
 nozzle id. new d = 7.75 in
 fillet weld tw1 = .125 in
 groove weld tw2 = .1875 in

To datum L = 40 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.75$ in
 Normal to the vessel wall outside $2.5*(tn - Cn) + te = .3$ in
 Normal to the vessel wall inside $2.5*(tn - Cn - C) = .3$ in

Nozzle required thickness

$$trn = \frac{P \cdot Rn}{(Sn \cdot E - 0.6 \cdot P)}$$

$$= \frac{2 \cdot 3.875}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0005 \text{ in}$$

Required thickness tr from UG-37(a)

$$tr = \frac{P \cdot R}{(S \cdot E - 0.6 \cdot P)}$$

$$= \frac{2 \cdot 52.125}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0071 \text{ in}$$

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$

REV 0
 Doc No. V049-1-015
 Page 26 of 57

Nozzle G

fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.75*0.0071*1 + 2*0.12*0.0071*1*(1 - 1) \\ &= .055 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = 3.82 in²

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.75*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= 3.82 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.5+0.12)*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= .611 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.072 in²

$$\begin{aligned} &= 5*(tn - t_{rn})*fr2*t \\ &= 5*(0.12 - 0.0005)*1*0.5 \\ &= .299 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - t_{rn})*fr2*tn \\ &= 5*(0.12 - 0.0005)*1*0.12 \\ &= .072 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.125^2*1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 3.82 + 0.072 + 0.016 \\ &= 3.908 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.12 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.084 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.125 = 0.0875 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.275 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0005 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.0071 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

Rev 0

Doc. No V049-1-015

Nozzle G

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.12 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 \cdot 14700 = 10878$ psi
 Nozzle wall in shear = $0.7 \cdot 14700 = 10290$ psi
 Inner fillet weld in shear = $0.49 \cdot 14700 = 7203$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) \cdot \text{Nozzle O.D.} \cdot \text{Leg} \cdot \text{Si} = 1.57 \cdot 7.99 \cdot 0.125 \cdot 7203 = 11294.57$ lbf

(3) Nozzle wall in shear
 $(\pi/2) \cdot \text{Mean nozzle dia.} \cdot \text{tn} \cdot \text{Sn} = 1.57 \cdot 7.87 \cdot 0.12 \cdot 10290 = 15257.07$ lbf

(4) Groove weld in tension
 $(\pi/2) \cdot \text{Nozzle O.D.} \cdot \text{tw} \cdot \text{Sg} = 1.57 \cdot 7.99 \cdot 0.1875 \cdot 10878 = 25585.67$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 \cdot \text{tn})) \cdot (E1 \cdot t - F \cdot \text{tr}) \cdot \text{Sv}$
 $= (0.055 - (7.75 - 2 \cdot 0.12)) \cdot (1 \cdot 0.5 - 1 \cdot 0.0071) \cdot 14700$
 $= -53606.18$ lbf

$W1-1 = (A2 + A5 + A41 + A42) \cdot \text{Sv}$
 $= (0.072 + 0 + 0.016 + 0) \cdot 14700$
 $= 1293.6$ lbf

$W2-2 = (A2 + A3 + A41 + A43 + 2 \cdot \text{tn} \cdot \text{t} \cdot \text{fr1}) \cdot \text{Sv}$
 $= (0.072 + 0 + 0.016 + 0 + 2 \cdot 0.12 \cdot 0.5 \cdot 1) \cdot 14700$
 $= 3057.6$ lbf

Load for path 1-1 lesser of W or W1-1 = -53606.18 lbf
 Path 1-1 Thru (1) & (3) = $11294.57 + 15257.07 = 26551.64$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -53606.18 lbf
 Path 2-2 Thru (1), (4) = $11294.57 + 25585.67 = 36880.24$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.75 in

Nozzle G

Normal to the vessel wall outside $2.5*(t_n - C_n) + t_e = .3$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$L/Do = 3/7.99 = .3755 \quad Do/t = 7.99/0.01833 = 435.8974$$

$$\text{From table G:} \quad A = 0.000412$$

$$\text{From table HA-3:} \quad B = 4808.2$$

$$P_a = 4*B/(3*Do/t)$$

$$= 4*4808.2/(3*7.99/0.01833)$$

$$= 14.7074 \text{ psi}$$

Nozzle required thickness $t_{rn} = .01833$ in

Required thickness t_r from UG-37(d)(1) = .3075 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$
 $fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$

$$A = 0.5*(d*tr*F + 2*t_n*tr*F*(1 - fr_1))$$

$$= 0.5*(7.75*0.3075*1 + 2*0.12*0.3075*1*(1 - 1))$$

$$= 1.1916 \text{ in}^2$$

Area available

$A_1 = \text{larger of the following} = 1.492 \text{ in}^2$

$$= d*(E_1*t - F*tr) - 2*t_n*(E_1*t - F*tr)*(1 - fr_1)$$

$$= 7.75*(1*0.5 - 1*0.3075) - 2*0.12*(1*0.5 - 1*0.3075)*(1 - 1)$$

$$= 1.492 \text{ in}^2$$

$$= 2*(t + t_n)*(E_1*t - F*tr) - 2*t_n*(E_1*t - F*tr)*(1 - fr_1)$$

$$= 2*(0.5 + 0.12)*(1*0.5 - 1*0.3075) - 2*0.12*(1*0.5 - 1*0.3075)*(1 - 1)$$

$$= .239 \text{ in}^2$$

$A_2 = \text{smaller of the following} = 0.061 \text{ in}^2$

$$= 5*(t_n - t_{rn})*fr_2*t$$

$$= 5*(0.12 - 0.01833)*1*0.5$$

$$= .254 \text{ in}^2$$

$$= 5*(t_n - t_{rn})*fr_2*t_n$$

$$= 5*(0.12 - 0.01833)*1*0.12$$

$$= .061 \text{ in}^2$$

$$A_{41} = \text{Leg}^2*fr_2$$

$$= 0.125^2*1 = .016 \text{ in}^2$$

REV 0

Doc No. V049-1-015

Page 29 OF 57

Nozzle G

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.492 + 0.061 + 0.016 \\ &= 1.569 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_e = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.01833 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0522 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_e .

Nozzle GApplied Loads

Radial load	$P_r = 693.4 \text{ lbf}$
Circumferential moment	$M_c = 0 \text{ lbf-ft}$
Circumferential shear	$V_c = 0 \text{ lbf}$
Longitudinal moment	$M_L = 0 \text{ lbf-ft}$
Longitudinal shear	$V_L = 0 \text{ lbf}$
Torsion moment	$M_t = 0 \text{ lbf-ft}$
Internal pressure	$P = 2 \text{ psi}$

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius $R_m = 52.375 \text{ in}$
 $R_m/t = 104.75$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$I = .25*(4 + 3*(r/x)^2 + 3*(r/x)^4)$$

$$= .25*(4 + 3*(3.875/4.12)^2 + 3*(3.875/4.12)^4)$$

$$= 2.25$$

Local circ. pressure stress = $I*P*R_m/t = 471 \text{ psi}$

Local long. pressure stress = $P*R_m/2t = 105 \text{ psi}$

Maximum combined stress = -2379 psi
 Allowable combined stress = $+3*S = \pm 44100 \text{ psi}$

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -364 psi
 Allowable primary membrane stress = $+1.5*S = \pm 22050 \text{ psi}$

The maximum primary membrane stress is within allowable limits.

Nozzle G

From Fig.	Value read	beta	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
3C*	16.021	0.067					-424	-424	-424	-424
4C*	17.720	0.067	-469	-469	-469	-469				
1C	0.1209	0.067					-2012	2012	-2012	2012
2C-1	0.0837	0.067	-1393	1393	-1393	1393				
3A*	3.2919	0.067								
1A	0.0926	0.067								
3B*	10.724	0.067								
1B-1	0.0440	0.067								
pressure stress*			471	471	471	471	471	471	471	471
Total circ stress			-1391	1395	-1391	1395	-1965	2059	-1965	2059
Primary membrane circ stress*			2	2	2	2	47	47	47	47
3C*	16.021	0.067	-424	-424	-424	-424				
4C*	17.720	0.067					-469	-469	-469	-469
1C-1	0.1238	0.067	-2060	2060	-2060	2060				
2C	0.0837	0.067					-1393	1393	-1393	1393
4A*	4.8183	0.067								
2A	0.0535	0.067								
4B*	3.2756	0.067								
2B-1	0.0696	0.067								
pressure stress*			105	105	105	105	105	105	105	105
Total long stress			-2379	1741	-2379	1741	-1757	1029	-1757	1029
Primary membrane long stress*			-319	-319	-319	-319	-364	-364	-364	-364
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-2379	1741	-2379	1741	-1965	2059	-1965	2059

Rev 0
 Doc. No. Y889-1-015
 Page 2 of 57

MAXIMUM ALLOWABLE COMPRESSIVE STRESS
IN UPPER SECTION CYLINDRICAL SHELL

REF: UG-23(b)

$$A = \frac{.125}{(R_o/t)}$$

$$R_o = 52.375 \text{ in}$$

$$t = .25 \text{ in}$$

$$A = 5.97 (10)^{-4}$$

$$B = 5750 \text{ (FIG. HA-1 FOR TP304 @ 4500R SECT. II, P. 640)}$$

LONGITUDINAL STRESS

$$S_L = \frac{P r}{2t}$$

$$= \frac{14.7(52.375)}{2(.25)}$$

$$= 1540 \text{ psi} < B = 5750 \text{ psi}$$

REQUIREMENT OF UG-23(b) IS MET
CYLINDRICAL SHELL



105 IN ID SHELL *

HEAD FOR 105 IN ID SHELL

DIMENSIONS FROM SECT VIII, DIV 1, VC-32(e)

CROWN RADIUS (INSIDE)

$$ICR = OD \text{ OF SHELL}$$

$$= 105 + 2t$$

$$t = .375$$

$$ICR = 105 + 2(.375) = 105.75$$

KNUCKLE RADIUS = $6\frac{3}{4}$ OF ICR

$$= .06(105.75) = 6.345 \text{ IN}$$

COMPASS ANALYSIS OF BSC WITH RN
INCREASED ID = 105 IN FOLLOWS

FILENAME: BSC105ID.VSL

RESULTS SHOW THAT CODE REQUIREMENTS ARE
MET FOR THE INCREASED ID.

* FINAL ID IS 104.5 IN

Top Head - BSC

ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 1140.8 corr = 1140.8 lb
 capacity: new = 474.64 corr = 474.64 US ga

ID = 105 crown L = 105.75 knuckle r = 6.345 t = .34375 in (min)

3/8 - 1/32 FOR TILINNING

Straight flange = 2 forming allowance = 0 in

WARNING! F&D head geometry is not per UG-32(j).

Design thickness: (At 400 deg F) Appendix 1-4(d) Eq 3

$$M = .25*(3 + (L/r)^.5) = .25*(3 + (105.75/6.345)^.5) = 1.7706$$

$$t = P*L*M/(2*S*E - 0.2*P) + Corrosion + fa = 2*105.75*1.7706/(2*14700*0.85 - 0.2*2) + 0 + 0 = 0.015 \text{ in}$$

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps = 2*16700*0.85*0.34375/(105.75*1.7706 + 0.2*0.34375) - 0 = 52.10122 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) Appendix 1-4(d) Eq 3

$$P = 2*S*E*t/(L*M + 0.2*t) - Ps = 2*14700*0.85*0.34375/(105.75*1.7706 + 0.2*0.34375) - 0 = 45.86155 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$A = .125/(Ro/t) = .125/(106.0938/0.32873) = 0.000387$$

*REV 0
 Doc. No. V049-1-015
 Page 35 of 57*

Top Head - BSC

From table HA-3:

$$B = 4755.5$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4755.5/(106.0938/0.32873) \\ &= 14.7348 \text{ psi} \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned} t &= 1.67*Pa*Lo*M/(2*S*E + 1.67*Pa*(M-0.2)) \\ &= 1.67*14.7348*106.0938*1.7706/(2*14700*1 + 1.67*14.7348*(1.7706-0.2)) \\ &= 0.15702 \text{ in} \end{aligned}$$

Design thickness for external pressure Pa = 14.7348 psi:

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.32873 + 0 + 0 \\ &= 0.32873 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(106.0938/0.34375) \\ &= 0.000405 \end{aligned}$$

From table HA-3:

$$B = 4793.7$$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 4793.7/(106.0938/0.34375) \\ &= 15.5319 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pe &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.34375/((1.7706*106.0938 - 0.34375*(1.7706-0.2))*1.67) \\ &= 32.30824 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 15.5319 psi.

Upper Cylindrical Shell - BSCASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH

Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F

Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 1438.3 corr = 1438.3 lb
 capacity: new = 2249.093 corr = 2249.093 US ga

ID = 105 length Lc = 60 t = 0.25 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.5 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0084 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.25 / (52.5 + 0.6 \cdot 0.25) - 0$$

$$= 67.40266 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.25 / (52.5 + 0.6 \cdot 0.25) - 0$$

$$= 59.33049 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 37.90327/105.5 = 0.3593 \quad Do/t = 105.5/0.24092 = 437.9047$$

From table G: A = 0.000429
 From table HA-3: B = 4842.5

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 4842.5 / (3 \cdot 105.5/0.24092)$$

$$= 14.7445 \text{ psi}$$

Design thickness for external pressure Pa = 14.7445 psi:

$$= t + \text{Corrosion}$$

$$= 0.24092 + 0$$

Upper Cylindrical Shell - BSC

$$= 0.24092 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$L/D_o = 37.90327/105.5 = 0.3593 \quad D_o/t = 105.5/0.25 = 422$$

$$\text{From table G:} \quad A = 0.000452$$

$$\text{From table HA-3:} \quad B = 4887.2$$

$$\begin{aligned} P_a &= 4*B/(3*D_o/t) \\ &= 4*4887.2/(3*105.5/0.25) \\ &= 15.4414 \text{ psi} \end{aligned}$$

*Rev 0**Doc. No V049-1-015***Page 38 of 57**

Shell StiffenerStiffening Ring Calculations Per UG-29ASME Section VIII Division 1, 1992 Edition, A93 Addenda

Identifier:	Shell Stiffener
Ring material specification:	SA 240 304L HIGH
Number of rings in this group:	1
Distance first ring to datum line:	110 in
Ring spacing:	0 in
Ring description:	4x4x1/4 Equal Angle
Ring is rolled:	leg out (easy way)
Ring cross sectional area:	As = 1.94 in ²
Ring moment of inertia:	Ir = 3.04 in ⁴

Calculations for ring 110 in from datum

Shell material specification:	SA 240 304L HIGH
Required shell thickness:	t = 0.24092 in
Corroded shell thickness:	ts = 0.25 in
Shell outer diameter:	Do = 105.5 in
Design temperature:	= 400 deg F
External design pressure:	P = 14.7 psi
Stiffener supported length:	Ls = 33.95164 in

$$B = .75*(P*Do/(t + As/Ls))$$

$$= .75*(14.7*105.5/(0.24092 + 1.94/33.95164))$$

$$= 3902.359$$

From table HA-3 (ring) A = 2.951318E-04

Required moment of inertia of the combined ring-shell section

$$I_s = (Do^2 * Ls * (t + As/Ls) * A) / 10.9$$

$$= (105.5^2 * 33.95164 * (0.24092 + 1.94/33.95164) * 2.951318E-04) / 10.9$$

$$= 3.049713 \text{ in}^4$$

Available moment of inertia of the combined ring-shell section

Shell width contributing smaller of = 5.649226

$$W = 1.1 * \text{Sqr}(Do * ts)$$

$$= 1.1 * \text{Sqr}(105.5 * 0.25)$$

$$= 5.649226 \text{ in}$$

$$W = Ls = 33.95164 \text{ in}$$

$$\text{Shell area } A_1 = W * ts = 1.412306 \text{ in}^2$$

Distance to the ring neutral axis

REV 0

Doc. No. V049-1-015

Shell Stiffener

$$\begin{aligned} Y2 &= \text{Ring NA} + ts/2 \\ &= 1.09 + 0.25/2 \\ &= 1.215 \text{ in} \end{aligned}$$

Neutral axis of combined section

$$\begin{aligned} \text{NA} &= A_s * Y2 / (A_1 + A_s) \\ &= 1.94 * 1.215 / (1.412306 + 1.94) \\ &= .7031279 \text{ in} \end{aligned}$$

Inertia of the shell about the combined section NA

$$\begin{aligned} I_1 &= W * ts^3 / 12 + A_1 * \text{NA}^2 \\ &= 5.649226 * 0.25^3 / 12 + 1.412306 * 0.7031279^2 \\ &= .7055842 \text{ in}^4 \end{aligned}$$

Inertia of the ring about the combined section NA

$$\begin{aligned} I_2 &= I_r + A_s * (\text{NA} - Y2)^2 \\ &= 3.04 + 1.94 * (0.7031279 - 1.215)^2 \\ &= 3.548306 \text{ in}^4 \end{aligned}$$

$$\text{Total available } I = I_1 + I_2 = 4.25389 \text{ in}^4$$

The 4x4x1/4 Equal Angle vacuum stiffener is satisfactory.

Rev 0

Doc. No. 1049-1-015

Main Section CylinderASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: Cylinder
 Material specification: SA 240 304L HIGH
 Internal design pressure: P = 2 psi @ 400 deg F
 External design pressure: Pe = 14.7 psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Category B joints - Spot UW-11(b) type 1

Estimated weight: new = 3844.7 corr = 3844.7 lb
 capacity: new = 2998.79 corr = 2998.79 US ga

ID = 105 length Lc = 80 t = 0.5 in (new)

Design thickness: UG-27(c)(1) Circ. stress

$$t = P \cdot R / (S \cdot E - 0.6 \cdot P) + \text{Corrosion}$$

$$= 2 \cdot 52.5 / (14700 \cdot 0.85 - 0.6 \cdot 2) + 0$$

$$= 0.0084 \text{ in}$$

MAP: (New & at 0 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 16700 \cdot 0.85 \cdot 0.5 / (52.5 + 0.6 \cdot 0.5) - 0$$

$$= 134.4223 \text{ psi}$$

MAWP: (Corroded & at 400 deg F) UG-27(c)(1)

$$P = S \cdot E \cdot t / (R + 0.6 \cdot t) - P_s$$

$$= 14700 \cdot 0.85 \cdot 0.5 / (52.5 + 0.6 \cdot 0.5) - 0$$

$$= 118.3239 \text{ psi}$$

External Pressure: (Corroded & at 400 deg F) UG-28

$$L/Do = 80/106 = 0.7547 \quad Do/t = 106/0.30843 = 343.6761$$

From table G: A = 0.000288
 From table HA-3: B = 3807.2

$$P_a = 4 \cdot B / (3 \cdot Do/t)$$

$$= 4 \cdot 3807.2 / (3 \cdot 106/0.30843)$$

$$= 14.7705 \text{ psi}$$

Design thickness for external pressure Pa = 14.7705 psi:

$$= t + \text{Corrosion}$$

$$= 0.30843 + 0$$

REV 0

Doc. No. V049-1-015

Main Section Cylinder

$$= 0.30843 \text{ in}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$L/Do = 80/106 = 0.7547$$

From table G:

From table HA-3:

$$Do/t = 106/0.5 = 212$$

$$A = 0.000586$$

$$B = 5115.7$$

$$\begin{aligned} Pa &= 4*B/(3*Do/t) \\ &= 4*5115.7/(3*106/0.5) \\ &= 32.1742 \text{ psi} \end{aligned}$$

REV D

Doc No. U049-1-015

Page 406 of 57

Nozzle E


Opening N-E Reinforcement Calculations Per UG-37

Located on: Upper Cylindrical Shell - BSC
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 14 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Pad material specification: SA 240 304L HIGH

Nozzle orientation: 45 degrees
 End of nozzle to shell center: 55.875 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 3.125 in



Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75$ in
 Normal to the vessel wall outside $2.5*(tn-Cn) + te = .55$ in
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3$ in

Nozzle required thickness

$$tr_n = \frac{P \cdot R_n}{S_n \cdot E - 0.6 \cdot P}$$

$$= \frac{2 \cdot 6.875}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0009 \text{ in}$$

Required thickness tr from UG-37(a)

$$tr = \frac{P \cdot R}{S \cdot E - 0.6 \cdot P}$$

$$= \frac{2 \cdot 52.5}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0071 \text{ in}$$

Area required

REV D
 Doc. No. V049-1-015
 Page 41 of 57

Nozzle E

Allowable stresses: $S_n = 14700$, $S_v = 14700$, $S_p = 14700$ psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$
 $fr_2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_2 = 1$
 $fr_3 = \text{lesser of } fr_2 \text{ or } S_p/S_v \text{ so } fr_3 = 1$
 $fr_4 = \text{lesser of } 1 \text{ or } S_p/S_v \text{ so } fr_4 = 1$

$$A = d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr_1)$$

$$= 13.75 \cdot 0.0071 \cdot 1 + 2 \cdot 0.12 \cdot 0.0071 \cdot 1 \cdot (1 - 1)$$

$$= .0976 \text{ in}^2$$

Area available

$$A_1 = \text{larger of the following} = 3.34 \text{ in}^2$$

$$= d \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 13.75 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1)$$

$$= 3.34 \text{ in}^2$$

$$= 2 \cdot (t + tn) \cdot (E_1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E_1 \cdot t - F \cdot tr) \cdot (1 - fr_1)$$

$$= 2 \cdot (0.25 + 0.12) \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) - 2 \cdot 0.12 \cdot (1 \cdot 0.25 - 1 \cdot 0.0071) \cdot (1 - 1)$$

$$= .18 \text{ in}^2$$

$$A_2 = \text{smaller of the following} = 0.131 \text{ in}^2$$

$$= 5 \cdot (tn - tm) \cdot fr_2 \cdot t$$

$$= 5 \cdot (0.12 - 0.0009) \cdot 1 \cdot 0.25$$

$$= .149 \text{ in}^2$$

$$= 2 \cdot (tn - tm) \cdot (2.5 \cdot tn + te) \cdot fr_2$$

$$= 2 \cdot (0.12 - 0.0009) \cdot (2.5 \cdot 0.12 + 0.25) \cdot 1$$

$$= .131 \text{ in}^2$$

$$A_{41} = Leg^2 \cdot fr_3$$

$$= 0.125^2 \cdot 1 = .016 \text{ in}^2$$

$$A_{42} = Leg^2 \cdot fr_4$$

$$= 0.25^2 \cdot 1 = .063 \text{ in}^2$$

$$A_5 = (D_p - d - 2 \cdot tn) \cdot te \cdot fr_4$$

$$= (20 - 13.75 - 2 \cdot 0.12) \cdot 0.25 \cdot 1$$

$$= 1.5025 \text{ in}^2$$

$$\text{Area} = A_1 + A_2 + A_{41} + A_{42} + A_5$$

$$= 3.34 + 0.131 + 0.016 + 0.063 + 1.5025$$

$$= 5.0525 \text{ in}^2$$

As $\text{Area} > A$ the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(c)(2)

Inner Fillet: $t_{min} = \text{lesser of } 0.75 \text{ or } tn \text{ or } te$, $t_{min} = 0.12 \text{ in}$
 $tw(\text{min}) = 0.7 \cdot t_{min} = 0.084 \text{ in}$

REV D

Doc. No V049-1-015

Page 42 OF 57

Nozzle E

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.125 = 0.0875 \text{ in}$$

Outer Fillet: $t_{\min} = \text{lesser of } 0.75 \text{ or } t_e \text{ or } t, t_{\min} = 0.25 \text{ in}$

$$tw(\text{min}) = 0.5 * t_{\min} = 0.125 \text{ in}$$

$$tw(\text{actual}) = 0.7 * \text{Leg} = 0.7 * 0.25 = 0.175 \text{ in}$$

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a): $tr1 = 0.0009 \text{ in (E = 1)}$

Wall thickness per UG-45(b)(1): $tr2 = 0.0071 \text{ in}$

Wall thickness per UG-16(b): $tr3 = 0.0625 \text{ in}$

Std pipe wall per UG-45(b)(4): $tr4 = 0.328125 \text{ in}$

The greater of $tr2$ or $tr3$: $tr5 = 0.0625 \text{ in}$

The lesser of $tr4$ or $tr5$: $tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.12 \text{ in}$

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 14700 = 10878 \text{ psi}$

Nozzle wall in shear = $0.7 * 14700 = 10290 \text{ psi}$

Inner fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Outer fillet weld in shear = $0.49 * 14700 = 7203 \text{ psi}$

Strength of welded joints:

(1) Inner fillet weld in shear

$$(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 13.99 * 0.125 * 7203 = 19776.11 \text{ lbf}$$

(2) Outer fillet weld in shear

$$(\pi/2) * \text{Pad O.D.} * \text{Leg} * S_o = 1.57 * 20 * 0.25 * 7203 = 56543.55 \text{ lbf}$$

(3) Nozzle wall in shear

$$(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 13.87 * 0.12 * 10290 = 26888.88 \text{ lbf}$$

(4) Groove weld in tension

$$(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 13.99 * 0.25 * 10878 = 59731.91 \text{ lbf}$$

Loading on welds per UG-41(b)(1)

$$\begin{aligned} W &= (A - (d - 2 * t_n) * (E1 * t - F * tr)) * S_v \\ &= (0.0976 - (13.75 - 2 * 0.12) * (1 * 0.25 - 1 * 0.0071)) * 14700 \\ &= -46804.49 \text{ lbf} \end{aligned}$$

$$\begin{aligned} W1-1 &= (A2 + A5 + A41 + A42) * S_v \\ &= (0.131 + 1.5025 + 0.016 + 0.063) * 14700 \\ &= 25173.75 \text{ lbf} \end{aligned}$$

$$W2-2 = (A2 + A3 + A41 + A43 + 2 * t_n * t * fr1) * S_v$$

REV 0

Doc No V049-1-015

Page 43 of 57

Nozzle E

$$= (0.131 + 0 + 0.016 + 0 + 2*0.12*0.25*1)*14700$$

$$= 3042.9 \text{ lbf}$$

$$W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2*tn*t*fr1)*Sv$$

$$= (0.131 + 0 + 1.5025 + 0.016 + 0.063 + 0 + 2*0.12*0.25*1)*14700$$

$$= 26055.75 \text{ lbf}$$

Load for path 1-1 lesser of W or W1-1 = -46804.49 lbf
 Path 1-1 Thru (2) & (3) = 56543.55 + 26888.88 = 83432.43 lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -46804.49 lbf
 Path 2-2 Thru (1), (4) = 19776.11 + 59731.91 = 79508.02 lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 3-3 lesser of W or W3-3 = -46804.49 lbf
 Path 3-3 Thru (2), (4) = 56543.55 + 59731.91 = 116275.5 lbf
 Path 3-3 is stronger than W so it is acceptable per UG-41(b)(2).

Pad strength = $A5*Sp = 22086.75 \text{ lbf}$
 Outer fillet weld strength is adequate.

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall $d = 13.75 \text{ in}$
 Normal to the vessel wall outside $2.5*(tn-Cn) + tc = .55 \text{ in}$
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .3 \text{ in}$

Nozzle required thickness

$$L/Do = 3.125/13.99 = .2234 \quad Do/t = 13.99/0.02972 = 470.7268$$

From table G: $A = 0.000642$
 From table HA-3: $B = 5198.5$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*5198.5/(3*13.99/0.02972)$$

$$= 14.7247 \text{ psi}$$

Nozzle required thickness $trn = .02972 \text{ in}$

Required thickness tr from UG-37(d)(1) = .2409 in

Area required

Allowable stresses: $Sn = 14700, Sv = 14700, Sp = 14700 \text{ psi}$

$fr1 = \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } Sn/Sv \text{ so } fr2 = 1$
 $fr3 = \text{lesser of } fr2 \text{ or } Sp/Sv \text{ so } fr3 = 1$
 $fr4 = \text{lesser of } 1 \text{ or } Sp/Sv \text{ so } fr4 = 1$

Nozzle E

$$\begin{aligned}
 A &= 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\
 &= 0.5*(13.75*0.2409*1 + 2*0.12*0.2409*1*(1 - 1)) \\
 &= 1.6562 \text{ in}^2
 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = .125 \text{ in}^2$$

$$\begin{aligned}
 &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 13.75*(1*0.25-1*0.2409) - 2*0.12*(1*0.25-1*0.2409)*(1-1) \\
 &= .125 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\
 &= 2*(0.25+0.12)*(1*0.25-1*0.2409) - 2*0.12*(1*0.25-1*0.2409)*(1-1) \\
 &= .007 \text{ in}^2
 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.099 \text{ in}^2$$

$$\begin{aligned}
 &= 5*(tn - tm)*fr2*t \\
 &= 5*(0.12 - 0.02972)*1*0.25 \\
 &= .113 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 &= 2*(tn - tm)*(2.5*tn + te)*fr2 \\
 &= 2*(0.12 - 0.02972)*(2.5*0.12 + 0.25)*1 \\
 &= .099 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A41 &= \text{Leg}^2*fr3 \\
 &= 0.125^2*1 = .016 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A42 &= \text{Leg}^2*fr4 \\
 &= 0.25^2*1 = .063 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 A5 &= (Dp - d - 2*tn)*te*fr4 \\
 &= (20 - 13.75 - 2*0.12)*0.25*1 \\
 &= 1.5025 \text{ in}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area} &= A1 + A2 + A41 + A42 + A5 \\
 &= 0.125 + 0.099 + 0.016 + 0.063 + 1.5025 \\
 &= 1.8055 \text{ in}^2
 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.02972 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0525 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.328125 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

REV 0

Doc. No V049-1-015

Page 45 of 57

Nozzle E

Available nozzle wall thickness new, $t_n = 0.12$ in

The nozzle neck thickness is adequate for P_e .

REV. 0

Doc. No. V049-1-015

Page 46 OF 57

Nozzle EApplied Loads

Radial load	Pr = 2183 lbf
Circumferential moment	Mc = 0 lbf-ft
Circumferential shear	Vc = 0 lbf
Longitudinal moment	ML = 0 lbf-ft
Longitudinal shear	VL = 0 lbf
Torsion moment	Mt = 0 lbf-ft
Internal pressure	P = 2 psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean radius } R_m = 52.625 \text{ in}$$

$$R_m/t = 105.25$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned} I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\ &= .25*(4 + 3*(6.875/7.12)^2 + 3*(6.875/7.12)^4) \\ &= 2.351 \end{aligned}$$

$$\text{Local circ. pressure stress} = I*P*R_m/t = 495 \text{ psi}$$

$$\text{Local long. pressure stress} = P*R_m/2t = 105 \text{ psi}$$

$$\text{Maximum combined stress} = -4703 \text{ psi}$$

$$\text{Allowable combined stress} = +3*S = +44100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -1154 \text{ psi}$$

$$\text{Allowable primary membrane stress} = +1.5*S = +22050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

Rev 0

Doc. No 1049-1-012

Page 47 of 57

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	10.776	0.116					-894	-894	-894	-894
4C*	15.180	0.116	-1259	-1259	-1259	-1259				
1C	0.0768	0.116					-4024	4024	-4024	4024
2C-1	0.0443	0.116	-2321	2321	-2321	2321				
3A*	4.1565	0.116								
1A	0.0776	0.116								
3B*	11.121	0.116								
1B-1	0.0282	0.116								
pressure stress*			495	495	495	495	495	495	495	495
Total circ stress			-3085	1557	-3085	1557	-4423	3625	-4423	3625
Primary membrane circ stress*			-764	-764	-764	-764	-399	-399	-399	-399
3C*	10.776	0.116	-894	-894	-894	-894				
4C*	15.180	0.116					-1259	-1259	-1259	-1259
1C-1	0.0747	0.116	-3914	3914	-3914	3914				
2C	0.0469	0.116					-2457	2457	-2457	2457
4A*	7.6047	0.116								
2A	0.0390	0.116								
4B*	4.1127	0.116								
2B-1	0.0387	0.116								
pressure stress*			105	105	105	105	105	105	105	105
Total long stress			-4703	3125	-4703	3125	-3611	1303	-3611	1303
Primary membrane long stress*			-789	-789	-789	-789	-1154	-1154	-1154	-1154
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-4703	3125	-4703	3125	-4423	3625	-4423	3625

REV 0
 Doc. No. V049-1-015
 Page 48 OF 57

Nozzle EStresses at the pad edge per WRC bulletin 107 (psi)

Mean radius $R_m = 52.625$ in

$R_m/t = 210.5$

Stress concentration factor K_n (tension) = 1

Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned} I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\ &= .25*(4 + 3*(6.875/10.25)^2 + 3*(6.875/10.25)^4) \\ &= 1.489 \end{aligned}$$

Local circ. pressure stress = $I*P*R_m/t = 627$ psi

Local long. pressure stress = $P*R_m/2t = 210$ psi

Maximum combined stress = -13225 psi

Allowable combined stress = $\pm 3*S = \pm 44100$ psi

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -3307 psi

Allowable primary membrane stress = $\pm 1.5*S = \pm 22050$ psi

The maximum primary membrane stress is within allowable limits.

REV D

Doc. No. V049-1-015

Page 49 of 57

Nozzle E

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	8.3321	0.166					-1383	-1383	-1383	-1383
4C*	21.196	0.166	-3517	-3517	-3517	-3517				
1C	0.0595	0.166					-12469	12469	-12469	12469
2C-1	0.0149	0.166	-3123	3123	-3123	3123				
3A*	6.5607	0.166								
1A	0.0553	0.166								
3B*	13.588	0.166								
1B-1	0.0104	0.166								
pressure stress*			627	627	627	627	627	627	627	627
Total circ stress			-6013	233	-6013	233	-13225	11713	-13225	11713
Primary membrane circ stress*			-2890	-2890	-2890	-2890	-756	-756	-756	-756
3C*	8.3321	0.166	-1383	-1383	-1383	-1383				
4C*	21.196	0.166					-3517	-3517	-3517	-3517
1C-1	0.0392	0.166	-8215	8215	-8215	8215				
2C	0.0353	0.166					-7398	7398	-7398	7398
4A*	17.922	0.166								
2A	0.0238	0.166								
4B*	5.8428	0.166								
2B-1	0.0144	0.166								
pressure stress*			210	210	210	210	210	210	210	210
Total long stress			-9388	7042	-9388	7042	-10705	4091	-10705	4091
Primary membrane long stress*			-1173	-1173	-1173	-1173	-3307	-3307	-3307	-3307
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-9388	7042	-9388	7042	-13225	11713	-13225	11713

REV 0

Doc No V049-1-015

Page 50 of 57


Nozzle G

Opening N-G Reinforcement Calculations Per UG-37

Located on: Main Section Cylinder
 Local vessel thickness: .5 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 80 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 90 degrees
 End of nozzle to shell center: 55.625 in
 Nozzle offset from center Lo: 0 in
 Projection outside vessel Lpr: 2.625 in



corrosion allow = 0 in
 noz thick new $t_n = .12$ in
 nozzle id. new $d = 7.75$ in
 fillet weld $tw_1 = .125$ in
 groove weld $tw_2 = .1875$ in

To datum $L = 40$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.75$ in
 Normal to the vessel wall outside $2.5*(t_n - C_n) + t_c = .3$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$t_{rn} = \frac{P \cdot R_n}{S_n \cdot E - 0.6 \cdot P}$$

$$= \frac{2 \cdot 3.875}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0005 \text{ in}$$

Required thickness t_r from UG-37(a)

$$t_r = \frac{P \cdot R}{S \cdot E - 0.6 \cdot P}$$

$$= \frac{2 \cdot 52.5}{(14700 \cdot 1 - 0.6 \cdot 2)}$$

$$= 0.0071 \text{ in}$$

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

REV 0
 Doc. No. VD49-1-015
 Page 51 of 57

Nozzle G

$$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.75*0.0071*1 + 2*0.12*0.0071*1*(1 - 1) \\ &= .055 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} = 3.82 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.75*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= 3.82 \text{ in}^2 \\ &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.5+0.12)*(1*0.5-1*0.0071) - 2*0.12*(1*0.5-1*0.0071)*(1-1) \\ &= .611 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} = 0.072 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.12 - 0.0005)*1*0.5 \\ &= .299 \text{ in}^2 \\ &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.12 - 0.0005)*1*0.12 \\ &= .072 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= Leg^2*fr2 \\ &= 0.125^2*1 = .016 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 3.82 + 0.072 + 0.016 \\ &= 3.908 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 2 at 400 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.12 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.084 \text{ in} \\ t1(\text{actual}) &= 0.7*Leg = 0.7*0.125 = 0.0875 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.275 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0005 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0.0071 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

REV 0
Doc. No 1049-1-015
Page 52 OF 57

Nozzle G

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.12 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 14700 = 10878$ psi
 Nozzle wall in shear = $0.7 * 14700 = 10290$ psi
 Inner fillet weld in shear = $0.49 * 14700 = 7203$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 7.99 * 0.125 * 7203 = 11294.57$ lbf

(3) Nozzle wall in shear
 $(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 7.87 * 0.12 * 10290 = 15257.07$ lbf

(4) Groove weld in tension
 $(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 7.99 * 0.1875 * 10878 = 25585.67$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 * t_n) * (E_1 * t - F * tr)) * S_v$
 $= (0.055 - (7.75 - 2 * 0.12) * (1 * 0.5 - 1 * 0.0071)) * 14700$
 $= -53606.18$ lbf

$W1-1 = (A_2 + A_5 + A_{41} + A_{42}) * S_v$
 $= (0.072 + 0 + 0.016 + 0) * 14700$
 $= 1293.6$ lbf

$W2-2 = (A_2 + A_3 + A_{41} + A_{43} + 2 * t_n * t * fr_1) * S_v$
 $= (0.072 + 0 + 0.016 + 0 + 2 * 0.12 * 0.5 * 1) * 14700$
 $= 3057.6$ lbf

Load for path 1-1 lesser of W or W1-1 = -53606.18 lbf
 Path 1-1 Thru (1) & (3) = $11294.57 + 15257.07 = 26551.64$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -53606.18 lbf
 Path 2-2 Thru (1), (4) = $11294.57 + 25585.67 = 36880.24$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.75 in

Nozzle G

Normal to the vessel wall outside $2.5*(t_n - C_n) + t_e = .3$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .3$ in

Nozzle required thickness

$$L/Do = 2.625/7.99 = .3285 \quad Do/t = 7.99/0.01796 = 444.8775$$

$$\text{From table G:} \quad A = 0.000462$$

$$\text{From table HA-3:} \quad B = 4906.1$$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*4906.1/(3*7.99/0.01796)$$

$$= 14.704 \text{ psi}$$

Nozzle required thickness $t_{rn} = .01796$ in

Required thickness t_r from UG-37(d)(1) = .3084 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$$

$$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$$

$$A = 0.5*(d*tr*F + 2*t_n*tr*F*(1 - fr1))$$

$$= 0.5*(7.75*0.3084*1 + 2*0.12*0.3084*1*(1 - 1))$$

$$= 1.1951 \text{ in}^2$$

Area available

$$A1 = \text{larger of the following} \quad = 1.485 \text{ in}^2$$

$$= d*(E1*t - F*tr) - 2*t_n*(E1*t - F*tr)*(1 - fr1)$$

$$= 7.75*(1*0.5 - 1*0.3084) - 2*0.12*(1*0.5 - 1*0.3084)*(1 - 1)$$

$$= 1.485 \text{ in}^2$$

$$= 2*(t + t_n)*(E1*t - F*tr) - 2*t_n*(E1*t - F*tr)*(1 - fr1)$$

$$= 2*(0.5 + 0.12)*(1*0.5 - 1*0.3084) - 2*0.12*(1*0.5 - 1*0.3084)*(1 - 1)$$

$$= .238 \text{ in}^2$$

$$A2 = \text{smaller of the following} \quad = 0.061 \text{ in}^2$$

$$= 5*(t_n - t_{rn})*fr2*t$$

$$= 5*(0.12 - 0.01796)*1*0.5$$

$$= .255 \text{ in}^2$$

$$= 5*(t_n - t_{rn})*fr2*t_n$$

$$= 5*(0.12 - 0.01796)*1*0.12$$

$$= .061 \text{ in}^2$$

$$A41 = Leg^2*fr2$$

$$= 0.125^2*1 = .016 \text{ in}^2$$

Rev. 0

Doc. No. V049-1-015

Page 54 of 57

Nozzle G

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.485 + 0.061 + 0.016 \\ &= 1.562 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for $P_c = 14.7$ at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	$tr1 = 0.01796 \text{ in (E = 1)}$
Wall thickness per UG-45(b)(2):	$tr2 = 0.0525 \text{ in}$
Wall thickness per UG-16(b):	$tr3 = 0.0625 \text{ in}$
Std pipe wall per UG-45(b)(4):	$tr4 = 0.28175 \text{ in}$
The greater of $tr2$ or $tr3$:	$tr5 = 0.0625 \text{ in}$
The lesser of $tr4$ or $tr5$:	$tr6 = 0.0625 \text{ in}$

Req'd per UG-45 is the larger of $tr1$ or $tr6 = 0.0625 \text{ in}$

Available nozzle wall thickness new, $t_n = 0.12 \text{ in}$

The nozzle neck thickness is adequate for P_c .

REV 0

Doc. No U049-1-015

Page 55 of 57

Nozzle GApplied Loads

Radial load	$P_r = 693.4 \text{ lbf}$
Circumferential moment	$M_c = 0 \text{ lbf-ft}$
Circumferential shear	$V_c = 0 \text{ lbf}$
Longitudinal moment	$M_L = 0 \text{ lbf-ft}$
Longitudinal shear	$V_L = 0 \text{ lbf}$
Torsion moment	$M_t = 0 \text{ lbf-ft}$
Internal pressure	$P = 2 \text{ psi}$

Stresses at the nozzle OD per WRC bulletin 107 (psi)

Mean radius $R_m = 52.75 \text{ in}$
 $R_m/t = 105.5$

Stress concentration factor K_n (tension) = 1
 Stress concentration factor K_b (bending) = 1

Pressure stress intensity factor, Farr equation 11.5

$$\begin{aligned}
 I &= .25*(4 + 3*(r/x)^2 + 3*(r/x)^4) \\
 &= .25*(4 + 3*(3.875/4.12)^2 + 3*(3.875/4.12)^4) \\
 &= 2.25
 \end{aligned}$$

Local circ. pressure stress = $I*P*R_m/t = 475 \text{ psi}$

Local long. pressure stress = $P*R_m/2t = 106 \text{ psi}$

Maximum combined stress = -2389 psi
 Allowable combined stress = $\pm 3*S = \pm 44100 \text{ psi}$

The maximum combined stress is within allowable limits.

Maximum primary membrane stress = -363 psi
 Allowable primary membrane stress = $\pm 1.5*S = \pm 22050 \text{ psi}$

The maximum primary membrane stress is within allowable limits.

REV 0

Doc No V049-1-015

Page 56 OF 57

Nozzle G

From Fig.	Value read	beta	Au	A1	Bu	B1	Cu	C1	Du	D1
3C*	16.149	0.066					-425	-425	-425	-425
4C*	17.850	0.066	-469	-469	-469	-469				
1C	0.1215	0.066					-2022	2022	-2022	2022
2C-1	0.0842	0.066	-1401	1401	-1401	1401				
3A*	3.3073	0.066								
1A	0.0927	0.066								
3B*	10.765	0.066								
1B-1	0.0441	0.066								
pressure stress*			475	475	475	475	475	475	475	475
Total circ stress			-1395	1407	-1395	1407	-1972	2072	-1972	2072
Primary membrane circ stress*			6	6	6	6	50	50	50	50
3C*	16.149	0.066	-425	-425	-425	-425				
4C*	17.850	0.066					-469	-469	-469	-469
1C-1	0.1244	0.066	-2070	2070	-2070	2070				
2C	0.0842	0.066					-1401	1401	-1401	1401
4A*	4.8372	0.066								
2A	0.0535	0.066								
4B*	3.2886	0.066								
2B-1	0.0699	0.066								
pressure stress*			106	106	106	106	106	106	106	106
Total long stress			-2389	1751	-2389	1751	-1764	1038	-1764	1038
Primary membrane long stress*			-319	-319	-319	-319	-363	-363	-363	-363
torsion moment Mt										
Circ shear from Vc										
Long shear from VL										
Total Shear stress										
Combined stress			-2389	1751	-2389	1751	-1972	2072	-1972	2072

REV D
 Doc. No. VD49-1-015
 Page 57 of 57

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-016 PAGE 1 OF 33
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of 1 in. Thick Flanges for Bolt Preload.	
0	0139	12/6/95	RDC	AGR		
					BY: <i>Z.D. Ciarrro</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To determine if bolt clamping force results in flange deformation that could allow leakage at Viton o-rings.</p>						
<p>METHOD: A 3D finite element analysis of a section of the plane flange is performed. Brick elements (3D solids) are used in the IMAGES program. Both a coarse model and an enhanced finer model are analyzed. The enhanced model includes compression only springs at the flange interface to simulate gap opening (nonlinear).</p>						
<p>ASSUMPTIONS: Symmetry is used to minimize the model by using appropriate boundary conditions. Curvature of the flange is ignored. O-ring glands and pumping channel are not included.</p>						
<p>INPUTS: LIGO project design sketches and drawings. Durometer is 90 for Viton o-rings.</p>						
<p>REFERENCES: 1. Parker O-Ring Handbook. 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates</p>						
<p>CALCULATIONS: (See Attachment)</p>						
<p>CONCLUSIONS: At a location that is midway between bolts, the gap between flanges opens a negligible amount that does not affect the seal.</p>						
<p>NOTES: This analysis was performed for the 104 in diameter flange, but it applies to other diameter as well because of similar dimensions and bolt spacing. Computer file is FLANGE.</p>						

104 1 1/4" I D FLANGES - ANALYSIS FOR
VACUUM LOAD

HOLE SPACING

$$\text{No. OF BOLTS} = 44$$

BOLT CIRCLE DIAM

$$C = 110"$$

CIRCUMF.

$$C' = \pi C = 345.6 \text{ IN}$$

SPACING

$$S = \frac{C'}{N} = \frac{345.6}{44}$$


$$= 7.20 \text{ IN}$$

TRY 7/8" Ø BOLTS w/ 1" Ø HOLES


USE FE MODEL TO DETERMINE
IF BOLT SPACING & FLANGE THICKNESS
WILL BE SUFFICIENT TO PROVIDE
CLAMPING FORCE BETWEEN THE BOLTS
AT THE CLAMPING. 3-D BENCH
ELEMENTS WILL BE USED, MODEL
TOP FLANGE WHICH IS THINNER THAN
BOTTOM FLANGE.

THE FE MODEL WILL NEGLECT
CORRUPTION WHICH HAS NEGLIGIBLE
EFFECT ON RESULTS.






$$S' = \frac{S}{2} = 3.60 \text{ IN}$$






Revision 0
Doc No. V049-1-016
Page 4 of 33






BOUNDARY CONDITIONS
 @ $y = 0, \Delta y = 0$




Revision 0
 Doc. No. V049-1-016
 Page 5 of 33

G = EQUIV NOT
 BEARING
 WIDTH
 1.875 IN

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



TYPICAL ELEMENT NODE NUMBERING



1ST EL i j k l m n o p
 1, 2, 12, 11, 101, 102, 112, 111

DELETE ELEMENTS AT BOLT HOLE
6, 7, 47, 48, 164, 129, 249, 250

REACTIONS AT BOLT

NODE	F _x
6	14.3
8	-25.6
14	16.7
17	-29.7
14	-8.9


REACTIONS AT OUTER O-RING

NODE	F _x
5	49.3
15	65.2
25	50.6
35	43.4
45	41.0
55	27.6
65	46.7
75	57.5
85	-47.0
95	-11.0


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Ver. 3.0
Geometry Plot



DELETED
REMOVED




Flange - ID = 104, No. Bolts = 48
Wireframe Plot

9/29/95
15: 4:28


TOP LAYER

IMAGES-3D
Ver. 3.0
Geometry Plot



Outer O-Ring →

.39
.39




Flange - ID = 104, No. Bolts = 48
Wireframe Plot

9/29/95
14:55:49

IMAGES-3D
Ver. 3.0
L Case 1

BOUNDARY CONDITIONS

Reading.....
Reading.....
?t
?r,15,15
?




Auto	Blowup	Disp	Elem#	Exit	Full	Help	Load
Move	Node	Node#	Range	Rest	Rotate	Shrink	Slice

IMAGES-3D
 Ver. 3.0
 Geometry Plot

8-No element numbers
 9-All elent. numbers
 10-Exit or 10,Size
 ?9
 ?i
 X range
 ?-1,.6
 Y range
 ?-1,2
 Z range
 ?-1,6
 ?#
 ?

401	402	403	404	405	406	407	408	409	410
244	245	246	247	248	249	250	251	252	
301	302	303	304	305	306	307	308	309	310
163	164	165	166	167	168	169	170	171	
201	202	203	204	205	206	207	208	209	210
82	83	84	85	86	87	88	89	90	
101	102	103	104	105	106	107	108	109	110
1	2	3	4	5	6	7	8	9	
11	12	13	14	15	16	17	18	19	20



Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
--------------	-----------------	---------------	---------------	--------------	----------------	-----------------	---------------


ENHANCED FE MODEL

THIS MODEL WILL BE ENHANCED BY INCREASING THE NO. OF ELEMENTS THROUGH THE FLANGE THICKNESS FROM 4 TO 6 AND BY INCREASING THE NO OF ELEMENTS ALONG EACH SIDE FROM 9 TO 14.

50 SHEETS
22-141
100 SHEETS
22-142
200 SHEETS
22-144




ENHANCED MODEL { 1575 NODES
1176 ELEMENTS



* ENHANCED MODEL NODE
 BOUNDS END SAME AS COARSE MODEL
 EXCEPT THAT $\Delta z = 0$ ALONG x AXIS ONLY

TYPICAL ELEMENT NODE NUMBERING



1st EL i j k l m n o p
 INITIAL MODEL → 1, 2, 12, 11, 101, 102, 112, 111

ENHANCED MODEL {
 MAT = 1 (STAINLESS)
 ELZOOM = 2 (3RD ORDER INTEGRATION)

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS




BOTTOM LAYER ELEMENTS

IMAGES-3D
Ver. 3.0
Geometry Plot

Z range
?
Z=Default
?i
X range
?
X=Default
Y range
?.1,.2
Z range
?
Z=Default
?

1	15	29	43	57	71	85	99	113	127	141	155	169	183
2	16	30	44	58	72	86	100	114	128	142	156	170	184
3	17	31	45	59	73	87	101	115	129	143	157	171	185
4	18	32	46	60	74	88	102	116	130	144	158	172	186
5	19	33	47	61	75	89	103	117	131	145	159	173	187
6	20	34	48	62	76	90	104	118	132	146	160	174	188
7	21	35	49	63	77	91	105	119	133	147	161	175	189
8	22	36	50	64	78	92	106	120	134	148	162	176	190
9	23	37	51	65	79	93	107	121	135	149	163	177	191
10	24	38	52	66	80	94	108	122	136	150	164	178	192
11	25	39	53	67	81	95	109	123	137	151	165	179	193
12	26	40	54	68	82	96	110	124	138	152	166	180	194
13	27	41	55	69	83	97	111	125	139	153	167	181	195
14	28	42	56	70	84	98	112	126	140	154	168	182	196

*DELETED
ELEMENTS FOR
ROOT HOLES ->*




Auto Node Blowup Node# Elem# Plot Exit Range Full Rest Help Rotate Local Shrink Move Slice

TOP LAYER ELEMENTS

IMAGES-3D
Ver. 3.0
Geometry Plot

9-All elemt. numbers
10-Exit or 10,Size
?9
?i
X range
?
X=Default
Y range
?.8,1.1
Z range
?
Z=Default
?

981	995	1009	1023	1037	1051	1065	1079	1093	1107	1121	1135	1149	1163
982	996	1010	1024	1038	1052	1066	1080	1094	1108	1122	1136	1150	1164
983	997	1011	1025	1039	1053	1067	1081	1095	1109	1123	1137	1151	1165
984	998	1012	1026	1040	1054	1068	1082	1096	1110	1124	1138	1152	1166
985	999	1013	1027	1041	1055	1069	1083	1097	1111	1125	1139	1153	1167
986	1000	1014	1028	1042	1056	1070	1084	1098	1112	1126	1140	1154	1168
987	1001	1015	1029	1043	1057	1071	1085	1099	1113	1127	1141	1155	1169
988	1002	1016	1030	1044	1058	1072	1086	1100	1114	1128	1142	1156	1170
989	1003	1017	1031	1045	1059	1073	1087	1101	1115	1129	1143	1157	1171
990	1004	1018	1032	1046	1060	1074	1088	1102	1116	1130	1144	1158	1172
991	1005	1019	1033	1047	1061	1075	1089	1103	1117	1131	1145	1159	1173
992	1006	1020	1034	1048	1062	1076	1090	1104	1118	1132	1146	1160	1174
993	1007	1021	1035	1049	1063	1077	1091	1105	1119	1133	1147	1161	1175
994	1008	1022	1036	1050	1064	1078	1092	1106	1120	1134	1148	1162	1176



Auto Blowup Elem# Exit Full Help Local Move
Node Node# Plot Range Rest Rotate Shrink Slice


TOP LAYER NODES

IMAGES-3D
Ver. 3.0
Geometry Plot

?
Z=Default
?#
?i
X range
?
X=Default
Y range
?.9,1.1
Z range
?
Z=Default
?

1351	1366	1381	1396	1411	1426	1441	1456	1471	1486	1501	1516	1531	1546	1561
1352	1367	1382	1397	1412	1427	1442	1457	1472	1487	1502	1517	1532	1547	1562
1353	1368	1383	1398	1413	1428	1443	1458	1473	1488	1503	1518	1533	1548	1563
1354	1369	1384	1399	1414	1429	1444	1459	1474	1489	1504	1519	1534	1549	1564
1355	1370	1385	1400	1415	1430	1445	1460	1475	1490	1505	1520	1535	1550	1565
1356	1371	1386	1401	1416	1431	1446	1461	1476	1491	1506	1521	1536	1551	1566
1357	1372	1387	1402	1417	1432	1447	1462	1477	1492	1507	1522	1537	1552	1567
1358	1373	1388	1403	1418	1433	1448	1463	1478	1493	1508	1523	1538	1553	1568
1359	1374	1389	1404	1419	1434	1449	1464	1479	1494	1509	1524	1539	1554	1569
1360	1375	1390	1405	1420	1435	1450	1465	1480	1495	1510	1525	1540	1555	1570
1361	1376	1391	1406	1421	1436	1451	1466	1481	1496	1511	1526	1541	1556	1571
1362	1377	1392	1407	1422	1437	1452	1467	1482	1497	1512	1527	1542	1557	1572
1363	1378	1393	1408	1423	1438	1453	1468	1483	1498	1513	1528	1543	1558	1573
1364	1379	1394	1409	1424	1439	1454	1469	1484	1499	1514	1529	1544	1559	1574
1365	1380	1395	1410	1425	1440	1455	1470	1485	1500	1515	1530	1545	1560	1575

LOADING AREA



Revision 0
Doc No. V049-1-016
Page 16 of 33

Auto Node	Blowup Node#	Elem# Plot	Exit Range	Full Rest	Help Rotate	Local Shrink	Move Slice
-----------	--------------	------------	------------	-----------	-------------	--------------	------------

DELETE ELEMENTS

10, 11, 24, 25 IN BOTTOM LAYER

INCREMENT = 196

TO

990, 991, 1004, 1005 IN TOP LAYER

APPLY LOADS $F_y = -1000^*$ LB AT
TOP LAYER NODS 1359, 1360, 1362, 1363
1374, 1375, 1377, 1378
1389, TO 1393
1404 TO 1408

* UNIT LOAD SELECTED
TO DETERMINE REQUIRED
LOAD FROM OUTPUT

IMAGES-3D
Ver. 3.0
Geometry Plot

?
Z=Default
?i
X range
?
X=Default
Y range
?-.1,.1
Z range
?
Z=Default
?#
?


→ ← .2571" TYP

1	16	31	46	61	76	91	106	121	136	151	166	181	196	211
2	17	32	47	62	77	92	107	122	137	152	167	182	197	212
3	18	33	48	63	78	93	108	123	138	153	168	183	198	213
4	19	34	49	64	79	94	109	124	139	154	169	184	199	214
5	20	35	50	65	80	95	110	125	140	155	170	185	200	215
6	21	36	51	66	81	96	111	126	141	156	171	186	201	216
7	22	37	52	67	82	97	112	127	142	157	172	187	202	217
8	23	38	53	68	83	98	113	128	143	158	173	188	203	218
9	24	39	54	69	84	99	114	129	144	159	174	189	204	219
10	25	40	55	70	85	100	115	130	145	160	175	190	205	220
11	26	41	56	71	86	101	116	131	146	161	176	191	206	221
12	27	42	57	72	87	102	117	132	147	162	177	192	207	222
13	28	43	58	73	88	103	118	133	148	163	178	193	208	223
14	29	44	59	74	89	104	119	134	149	164	179	194	209	224
15	30	45	60	75	90	105	120	135	150	165	180	195	210	225

LIMITS OF LOAD →

OUTER
← O-RING

↓
← .25" TYP



Revision 0
Doc. No. V049-1-016
Page 18 of 33

Auto Blowup Elem# Exit Full Help Local Move
Node Node# Plot Range Rest Rotate Shrink Slice

CLAMPING FORCE AT OUTER O-RING

ENHANCED MODEL

FORCE WILL BE NORMALIZED BY NODE SPACING AND TOTAL BOLT LOAD

NODE SPACING

$$S = \frac{3.6}{14} = .2571$$

TOTAL FORCE $F_T = 14000 \text{ LB}$, SAY 14^K

$$F_y = \frac{F_{iy}}{.2571(14)} = \frac{F_{iy}}{4.629}$$

WHERE .2571 = NODE SPACING *

NODE	F_{iy}	F_y	$F_y/.25$
7	150.5	32.5	130
22	282.5	61.0	244
37	232.6	50.3	201
52	164.4	35.6	142.4
67	94.3	20.8	83.2
82	42.3	9.14	36.6
97	9.02	1.95	7.8
112	-4.54	-1.42	-5.68
127	-11.1	-2.40	-9.60
142	-10.3	-2.22	-8.88
157	-7.69	-1.66	-6.64
172	-5.14	-1.11	-4.44
187	-3.24	-.76	-2.8
202	-2.12	-.45	-1.84
217	-.88	-.19	-.76

WHERE F_{iy} = OUTPUT FORCE, FILE = FLANGE

$F_y/.25$ NORMALIZED BY NODE SPACING IN BOTH DIRECTIONS



CLAMPING FORCE AT OUTER O-RING
 COARSE MODEL

$$S = \frac{3.6}{9} = .40$$

TOTAL FORCE = $\bar{F}_y = 14000 \text{ LB} = 14K$

$$F_y = \frac{F_{iy}}{140(14)} = \frac{F_{iy}}{5.6}$$

WIKERIE .40 = DOSE SACCING


NOOE	F_{iy}	F_y	$F_{y/1.329}$
5	577.4	103.1	265.1
15	984.6	175.8	452.1
25	612.8	109.4	271.3
35	240.7	46.6	119.8
45	54.3	9.69	24.9
55	-16.2	-2.89	-7.4
65	-21.8	-3.89	-10.0
75	-12.4	-2.25	-5.79
85	-5.46	-.975	-2.51
95	-1.64	-.293	-.753

F_{iy} = OUTPUT FORCE, F_{LL} = FLANGE





NORMALIZED CLAMPING FORCE AT O-RING



NOTE - HIGHER LOAD RESULTS FROM COARSE MODEL BECAUSE APPLIED BOLT FORCE IN MODEL IS CLOSER TO O-RING NODES THAN IT IS IN ENHANCED MODEL

ENHANCED MODEL w/ COMP. ONLY SPRINGS FOR FOUNDATION AND LINEAR SPRINGS FOR VITON SPRING RATE OF VITON O RING

CROSS SECTION .275 IN

COMPRESSION 20%
 = .20 (.275)
 = .055 IN

GROOVE DEPTH = .201 TO .211
 ∴ COMP = $\frac{.275 - .211}{.275}$
 = $\frac{.064}{.275} = 23\%$ MIN

= $.275 - .201$
 = .074
 = $\frac{.074}{.275} = 27\%$ MAX

COMPRESSION LOAD

F ≈ 25 TO 100 LB PER IN OF LENGTH / IN DIAMETER = 75

SEE P. A4-11 OF PARKER O-RING HANDBOOK

SAF F = 60 LB

SPRING RATE

$R = \frac{60}{.064} = 938$ LB/IN MAX PER IN OF CIRCUM

$R = \frac{60}{.074} = 810$ LB/IN MIN PER IN OF CIRCUM

USE

R = 900 LB/IN FOR 1 IN LENGTH
 R = $900 (.2571) = 231$ LB/IN FOR MODEL

REV D
 V049-1-018
 P. 22 OF 33

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



TRY DIAMETER = 90

SQUEEZE (COMPRESSION) VARIES FROM 21 TO 29% (P. A5-13 OF PARKER SEALS HANDBOOK). FROM P. A4-11 OF THE PARKER HANDBOOK, THE COMPRESSIVE FORCE PER INCH OF SEAL RANGES FROM

70 TO 160 LB/IN

FOR .080 IN COMPRESSION (CORRESPONDING TO MAX DEFLECTION) THE STIFFNESS PER IN OF SEAL IS

$$R = \frac{160}{.080} = 2000 \text{ LB/IN PER IN OF CIRCUM.}$$

FOR DISCRETE SPRINGS SPACED .2571 IN APART IN MODEL

$$R = 2000 (.2571) \text{ WHERE } .2571 = \text{NODE SPACING} \\ = 514 \text{ LB/IN} *$$


ALTHOUGH THIS IS HIGHER THAN $R = 231 \text{ LB/IN}$ USED IN FE ANALYSIS, IT IS ORDERS OF MAGNITUDE LESS STIFF THAN FOUNDATION SPRINGS USED TO REPRESENT THE STEEL. \therefore THE MODEL RESULTS WOULD NOT CHANGE SIGNIFICANTLY IF THE HIGHER VALUE OF R IS USED.

* SEE CALC 018, P. 5 FOR UPDATED VALUE OF R . RESULTS WILL NOT BE AFFECTED.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Version 3.0





IMAGES-3D
Version 3.0

DISPLACEMENT ALONG OUSEN O-RING



4 BOLT

SUM



COMP ← → SMALL UPERT

Revision 0
Doc No. V049-1-016
Page 25 of 33

Load Case
1


Displacement Contour Plot
DY

10/12/95
7:40:0

IMAGES-3D
Version 3.0

DEFLECTION ALONG OUTER O-RING

?c
Scale factor
?500
?





Revision 0
Doc. No. V049-1-016
Page 26 of 33

Animate	Auto	Blowup	Elem#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice



IMAGES-3D
Version 3.0

DISSECTION ALONG RADIAL LINE
THROUGH BOLT HOLE

X range
?-.1,.1
Y range
?
Y=Default
Z range
?
Z=Default
?r,, -90
?c
Scale factor
?200
?



↑
OUTER O-RING





Revision 0
Doc. No. V049-1-016
Page 27 of 33

Animate	Auto	Blowup	Elem#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice

IMAGES-3D
Version 3.0

DEFLECTION ALONG RADIAL LINE
MIDWAY BETWEEN BOLTS

?c
Scale factor
?500
?i
X range
?3.3,3.5
Y range
?
Y=Default
Z range
?
Z=Default
?



Revision 0
Doc. No. V049-1-016
Page 28 of 33

Animate	Auto	Blowup	Elen#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice

ENHANCED MODEL

FOUNDATION STIFFNESS = 10×10^6 LB/IN

OUTER O-RING DEFECTIONS

NODE	Δy	EXP (10 EXP)
7	-.101	-3
22	-.947	-4
27	-.768	-4
52	-.470	-4
67	-.125	-4
82	.239	-4
97	.572	-4
112	.876	-4
127	.114	-3
142	.136	-3
157	.154	-3
172	.168	-3
187	.178	-3
202	.184	-3
217	.186	-3

FROM COMPUTER OUTPUT
FILE: FLANGE



DEFLECTIONS AT BOLT

BOTTOM LAYER NODES			TOP LAYER NODES			Δ_{YT}/Δ_{YB}
NODE	$\Delta_{Y BOT}$		NODE	$\Delta_{Y TOP}$		
9	-.540	-4	1359	-.799	-3	14.8
10	-.353	-4	1360	-.153	-2	43
12	-.382	-4	1362	-.158	-2	41
13	-.542	-4	1363	-.822	-3	15
24	-.851	-4	1374	-.576	-3	6.8 *
25	-.592	-4	1375	-.101	-2	17.1
27	-.633	-4	1377	-.105	-2	16.6
28	-.847	-4	1378	-.596	-3	7.0
39	-.702	-4	1389	-.500	-3	7.1
40	-.657	-4	1390	-.668	-3	10.2
41	-.464	-4	1391	-.290	-3	19.2
42	-.664	-4	1392	-.684	-3	10.3
43	-.683	-4	1393	-.514	-3	7.57
54	-.510	-4	1404	-.409	-3	8.0
55	-.622	-4	1405	-.468	-3	7.5
56	-.664	-4	1406	-.484	-3	7.3
57	-.618	-4	1407	-.474	-3	7.7
58	-.448	-4	1408	-.416	-3	8.5

MIN RATIO OF TOP TO BOTTOM DEFLECTION = 6.8
 FOUNDATION STIFFNESS, $R = 10 \times 10^6 \text{ LB/IN}$
 IS REASONABLE



MAXIMUM LIFTOFF AT OUTER O-RING

IF THE DEFLECTION IN THE OSG DIRECTION IS ACTUALLY 0 AND THE RELATIVE Δy REMAINS CONSTANT, THE MAXIMUM SEPARATION BETWEEN THE FLANGES IS

$$\begin{aligned}\Delta y &= [0.186 - (-0.104)] \times 10^{-3} \\ &= 0.290 (10)^{-3}\end{aligned}$$

THIS IS DOUBLED FOR 2 FLANGES

$$\begin{aligned}\Delta y &= 2(0.290) (10)^{-3} \\ &= 0.58 (10)^{-3} \\ &= 0.00058 \text{ IN}\end{aligned}$$

THIS COMPARES TO THE MINIMUM O-RING COMPRESSION OF 0.064 IN *

THE COMPRESSION IS MORE THAN 100 TIMES THE FLANGE SEPARATION.

$$\frac{0.064}{0.00058} = 110$$

* CALCULATED VALUE, FROM PARKER HANDBOOK, MAXIMUM COMPRESSION IS 0.080 IN FOR 0.25 IN O-RING.





FOR THE ANALYSIS, THE BOLT LOAD IS 18000 LB FOR THE HALF MODEL OR 36000 LB PER BOLT. THE TOTAL VACUUM THRUST ON THE FLANGE IS

$$F_f = \pi r^2 (14.7)$$

$$r = \frac{108}{2} = 54$$

= RADIUS TO OUTER O-RING

$$F_f = \pi (54)^2 (14.7)$$

$$= 134,700 \text{ LB}$$

FOR 48 BOLTS THE FORCE PER BOLT IS

$$F_{\text{BOLT}} = \frac{134700}{48}$$

$$= 2800 \text{ LB} < 36000$$

∴ BOLT PRELOAD CAN BE REDUCED TO, SAY 6000 LB, AND THE BOLTS WILL HAVE A NET TENSION UNDER THE VACUUM LOAD

$$F_T = 6000 - 2800 = 3200 \text{ LB}$$

FOR A PRELOAD OF 6000 LB THE UNIFORM LOAD ON THE INNER AND OUTER O-RINGS IS

$$W = \frac{48(6000)}{\pi(108) + \pi(105)} \quad (\text{ASSUME RIGID FLG})$$

$$= 430 \text{ LB/IN} >> 160 \text{ LB/IN}$$

MAX LOAD REQUIRED TO COMPRESS 1/4 VITON O-RING SEA DURING 90

∴ VITON WILL BE COMPRESSED INTO GLAND

FOR FLANGES OF OTHER DIAMETERS,
MAINTAIN BOLT SPACING AT 7.2 IN

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



FLANGE ID	BC DIAM D _{BC}	BC CIRCUM π D _{BC} = C _{BC}	No. of Bolts N = C _{BC} /7.2	USE N =
104 1/4	110	345.6"	48	48
84 1/4	90	282.7	39	40
72 1/4	78	245.0	34	36
60 1/4	66	207.3	29	30
48 1/4	54	169.6	24	24
44 1/4	50	157.1	22	24
30 1/4	36	113	16	16

BOLT DIAMETER = 7/8"
WITH 1" HOLES


TOP FLANGE = 1" THICK
BOTTOM " = 1 1/4" THICK

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-017 PAGE 1 OF 10
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber Finite Element Analysis of 1 in Thick Flange for Bolt Preload plus Positive Pressure	
0	0139	12/6/95	RDC	AGR		
					BY: R. D. CLAYTON	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<p>PURPOSE: To determine if bolt clamping force combined with a positive internal pressure of 2 psi results in flange deformation that could allow leakage at o-rings.</p>						
<p>METHOD: The same method used for the preload - only analysis (V049-1-016) is used in this analysis. Pressure load is added to the finite elements model.</p>						
<p>ASSUMPTIONS: Same as preload-only analysis (calc. V049-1-016). The fine model is used with compression-only springs at the surface between flanges.</p>						
<p>INPUTS: LIGO project design sketches and drawings. Durometer of 90 for Viton o-rings.</p>						
<p>REFERENCES: 1. Parker O-Ring Handbook. 2. IMAGES-3D, Version 3.0, R.L. Cloud and Associates</p>						
<p>CALCULATIONS: (SEE ATTACHED)</p>						
<p>CONCLUSIONS: The gap opening between flanges is negligible and does not permit leakage of o-ring seals.</p>						
<p>NOTES: Computer file is FLANGE A.</p>						

FLANGES - 3D FE ANALYSIS FOR BOLT PRELOAD
PLUS POS PRESSURE

ANALYSIS FOR POSITIVE PRESSURE USING
3D FE MODEL - 104 ID FLANGE USES

PRESSURE LOAD FROM ATTACHED
CYLINDER



$$F_y = P \frac{r}{2}$$

$$P = 2 \text{ psi}$$

$$r = \frac{104.25}{2}$$

$$F_y = \frac{2 \left(\frac{104.25}{2} \right)}{2}$$

$$= 52.1 \text{ LBS/IN}$$

NODE SPACING ALONG Y - 94 IN IS .2571

$$F_{yi} = 52.1 (.2571)$$

$$= 13.4 \text{ LBS} \quad \text{NODES 1266 TO 1546, INC 15}$$

$$= \frac{13.4}{2} = 6.7 \text{ AT } Y = 0, 3.6$$

END NODES 1351 & 1561

PRELOAD FORCE

$$F_{PL} = 6000 \text{ LB FOR } 7/8" \text{ } \phi \text{ BOLTS}$$

16 NODES ARE LOADED, 4 NODES ARE AT PLANE OF SYMMETRY (Y=0)

$$F_R = 14 F_{yi} + 4 \frac{F_{yi}}{2} \\ = 16 F_{yi} \quad [Y=0]$$

$$F_{yi} = \frac{6000}{16} = -375 \text{ LB}$$

NODES 1274, 1275, 1277, 1278
1289 TO 1293
1404 TO 1408

$$F_{yj} = \frac{375}{2} = -188 \text{ LB NODES } 1359, 1360, 1362, 1363$$

THE TOTAL PRESSURE FORCE AT THE CYLINDER IS

$$F_y = 52.1 \times 3.60 = 188 \text{ LB}$$

$$\ll F_{PL} = 6000 \text{ LB}$$

∴ IT WILL BE ASSUMED THAT PRESSURE DOES NOT EXHAUST THE PRELOAD FORCE



∴ ACTUAL LOAD IS 3000 LB FOR 1/2 BOLT
THIS ANALYSIS IS CONSERVATIVE FOR EVALUATION OF FLOWLINE SEPARATION.

50 SHEETS
100 SHEETS
200 SHEETS



Tarsamir Pressure

IMAGES-3D
Version 3.0



Revision 0
Doc. No. V049-1-017
Page 4 of 10

Load Case
1

Stress Contour Plot
Stress Intensity




10/18/95
7:48:50

IMAGES-3D
Version 3.0

INTERNAL PRESSURE
DEFLECTION ALONG RADIAL LINE
THROUGH BOLT HOLE

?C
Scale factor
?200
?I
X range
?-.1,.1
Y range
?
Y=Default
Z range
?
Z=Default
?

Q BSC



↑
Outer Diameter

Animate	Auto	Blowup	Elem#	Exit	Full	Help	Lcase
Move	Node#	Origin	Plot	Range	Rotate	Scale	Slice


IMAGES-3D
Version 3.0

INTEGRATE PRESSURE
DIRECTION ALONG OUTER O-RING

?C
Scale factor
?100
?I
X range
?
X=Default
Y range
?
Y=Default
Z range
?1.4,1.6
?

4 BOLT

MID PLANE
BETWEEN
BOLTS



Revision 0
Doc. No. V049-1-017
Page 6 of 10

Animate Move Auto Node# Blowup Origin Elem# Plot Exit Range Full Rotate Help Scale Lcase Slice

DEFLECTIONS AT OUTER O-RING

Node	Δy
7	$.296 \times 10^{-5}$
217	$.138 \times 10^{-3}$

SPRING LOADS ALONG OUTER O-RING

Node	F_y^*	EXPONENT
7	.152	-2
22	.271	-2
37	.615	-2
52	.120	-1
67	.197	-1
82	.261	-1
97	.366	-1
112	.445	-1
127	.515	-1
142	.574	-1
157	.624	-1
172	.662	-1
187	.690	-1
202	.706	-1
217	.711	-1

* OUTPUT FROM FILE FLANGE A

50 SHEETS
 22-141 100 SHEETS
 22-142 200 SHEETS
 22-144





MAXIMUM SEPARATION OF FLANGES

AT NODE 717 WHICH IS MIDWAY BETWEEN 2 BOLTS ALONG THE OUTER O-RING, THE DEFLECTION IS

$$\Delta_y = .134 (10)^{-3} \text{ IN}$$

WHICH INDICATES A VERY SLIGHT OPENING OF THE GAP UNDER INTERNAL PRESSURE OF 2 PSI. FOR THE 2 FLANGES, THIS IS DOUBLED

$$\begin{aligned} \Delta_y &= 2(.134) (10)^{-3} \\ &= .276 (10)^{-3} \text{ IN} \end{aligned}$$

THIS COMPARES TO THE MINIMUM COMPRESSION OF .058 IN FROM PARKER HANDBOOK (P. A5-12)

$$\frac{58 (10)^3}{.276 (10)^3} = 210$$

∴ OPENING OR GAP ≪ INITIAL COMPRESSION OF O-RING AND O-RING REMAINS COMPRESSED DURING INTERNAL PRESS = 2 PSI.

MAX TENSILE LOAD IS $T = \frac{.711 (10)^{-1} \text{ LB}}{.257 \text{ IN}}$

$$T = .280 \text{ LB/IN}$$

THIS COMPARES TO MIN SEALING LOAD OF 70 LB/IN FOR DOADMIPPER 52 (PARKER HANDBOOK P A4-11)


$$C - T = 70 - .28 = 69.7 \text{ LB/IN}$$

HOOP STRESS IN FLANGE RING DUE TO INTERNAL PRESSURE

3D FE MODEL DOES NOT COMPUTE HOOP STRESS

ε

$$p \approx 2 \text{ psi}$$



$$V = .660 p \sqrt{rt}$$

$$r = \frac{ID}{2} + \frac{t}{2}$$

$$ID = 104.25 \text{ (LARGE)} \text{ IN}$$

$$t = .5 \text{ (MAX THICKNESS)}$$


$$r = \frac{104.25}{2} + \frac{.5}{2} = 52.4$$

$$V = .660 (2) \sqrt{52.4 (.5)}$$

$$= 6.8 \text{ LB/IN}$$

TOTAL RADIAL LOAD =


$$F_r = p (l) + V = 2 + 6.4 = 8.4 \text{ LB/IN}$$



$$dF_y = F_r ds \sin \theta$$

$$ds = r d\theta$$

$$dF_y = F_r r \sin \theta d\theta$$



$$\begin{aligned}
 \bar{F}_\theta &= - \int_0^{\frac{\pi}{2}} dF_y = \\
 &= - \int_0^{\frac{\pi}{2}} F_r r \sin \theta d\theta \\
 &= - F_r r \int_0^{\frac{\pi}{2}} \sin \theta d\theta \\
 &= + F_r r \cos \theta \Big|_0^{\frac{\pi}{2}} \\
 &= + F_r r (1) \\
 &= + F_r r \\
 &= 8.8(52.4) = 461 \text{ LB}
 \end{aligned}$$

FLANGE CROSS SECTION

$$A = 3.5(1) = 3.5 \text{ IN}^2$$

LOOP STRESS

$$f_b = \frac{461}{3.5} = 132 \text{ psi NEG}$$

THIS STRESS & STRESS INTENSITY PLOT CONFIRMS THAT STRESS IN FLANGE ARE LOW, EXCEPT AT LOCAL AREA UNDER BOLT

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-018 PAGE 1 OF 18
REV.	DEO #	DATE	BY:	CHECK	TITLE: Beam Splitter Chamber - Finite Element Analysis of 3/4 in. Thick Flange	
0	139	12/6/93	RDC	AGR		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> To determine if thin flange (3/4 in) can withstand clamping force due to bolt preload plus 2 psi internal pressure without leakage at o-ring.						
<u>METHOD:</u> The 3-D finite element model used for the 1 in. thick flange is modified to obtain a 3/4 thick flange model.						
<u>ASSUMPTIONS:</u> Same as 1 in. thick flange analysis.						
<u>INPUTS:</u> LIGO project design sketches and drawings. Durometer of 90 for Viton o-rings.						
<u>REFERENCES:</u> 1. Parker O-Ring Handbook. 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates.						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Although the gap opening between flanges is greater for the 3/4 in. thickness than it is for the 1 in. thickness, it still does not permit leakage. If a 1 in. or 1 1/4 in. flange is damaged by gouging, its thickness may be reduced by as much as 1/4 in by machining.						
<u>NOTES:</u> If a flange requires machining, it location should be evaluated for tensile force. Computer file is FLANGE B.						

FLANGE ANALYSIS USING 3D MODEL
FOR THICKNESS = $3/4$ IN.

THE FOLLOWING ANALYSIS USES THE
SAME MODEL AS THE ENLARGED
MODEL BUT THERE ARE 5 ELEMENTS
THROUGH THE THICKNESS RATHER
THAN 6 BECAUSE THE FLANGE IS
THINNER, $3/4$ " VS. 1".

LOADS INCLUDE THE 8500* LB BOLT
PRELOAD AND THE 2 PSI
INTERNAL PRESSURE WHICH IS A
WORST CASE FOR OPENING OF THE
GAP BETWEEN THE FLANGES.


NONLINEAR GAP ELEMENTS ARE USED
AT THE FOUNDATION OF THE MODEL TO
SIMULATE THE OPENING OF THE GAP.

BOTH THE INNER AND OUTER O-RINGS
ARE INCLUDED. THESE ARE MODELED
AS LINEAR SPRINGS USING THE MAX
STIFFNESS POSSIBLE FOR THE $1/4$ IN
VITON MATERIAL.


* THE MAXIMUM PRELOAD WILL BE 10000 LB
(REF. CALC V049-1-042, P. 26). THIS
WILL NOT AFFECT THE RESULTS OF THIS
CALC SIGNIFICANTLY.



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




TYPICAL ELEMENT NO. 25 NUMBERING



1ST EL i j k l m n o p
 226, 227, 242, 241, 451, 452, 467, 466



BOUNDARY CONDITIONS
 @ $y = 0, \Delta y = 0$



Revision 0
 Doc. No. V049-1-018
 Page 4 of 18

G = EQUIV NUT
 24.00 IN
 10.00 IN
 1.875 IN

SPRING RATE FOR SPRINGS REPRESENTING
VITON O RING

DIAMETER = 90

OBTAIN MAX SPRING RATE

MAX EDMA IS 2970 (P. 5-13 OF
PARSONS HANDBOOK). FROM P. 4-11
THE MAX LINEAR FORCE IS

160 LB/IN

MIN DEFLECTION (SQUIERE'S) IS .058
(P. 5-13)

$$R = \frac{160}{.058} = 2759 \text{ LB/IN PER IN OF CIRCUMFERENCE}$$

FOR DISCRETE SPRINGS AT .2571*
IN SPACING


$$R_s = 2759 (.2571) \\ = 709 \text{ LB/IN}$$

* REF CALL V049-1-016, P. 14 FOR
NOSE SPACING

FLANGES - 3D FE ANALYSIS FOR BOLT PRELOAD
PLUS POS PRESSURE

ANALYSIS FOR POSITIVE PRESSURE USING
3D FE MODEL - 104 ID FLANGE USED

PRESSURE LOAD FROM ATTACHED
CYLINDER



$$F_y = \frac{p r}{2}$$

$$p = 2 \text{ psi}$$

$$r = \frac{104.25}{2}$$

$$F_y = \frac{2 \left(\frac{104.25}{2} \right)}{2}$$

$$= 52.1 \text{ lb/in}$$

NODE SPACING ALONG Y - 94.11 IS .2571

$$F_{y1} = 52.1 (.2571)$$

$$= 13.4 \text{ lb}$$

$$= \frac{13.4}{2} = 6.7 \text{ AT } Y = 0, 3.6$$

DELETE SPRINGS

151, 152

DELETE SOLIDS

10, 11, 24, 25

206, 207, 220, 221

402, 403, 416, 417

598, 599, 612, 613

794, 795, 808, 809

BOLT LOADS

$F_{PL} = 8500 \text{ LB}$

FOR 1/2 BOLT

$F_{PL} = -4250 \text{ LB}$

$F_{PL} = 14 F_{yi} + 4 \frac{F_{zi}}{2}$

$\gamma = 0$

$-4250 = 16 F_{yi}$

$F_{yi} = -266 \text{ LB INTERIOR NODES}$

$F_{yi} = \frac{-266}{2} = -133 \text{ LB @ } x=0 \text{ AT END NODES}$

PRESSURE LOAD

$F_{yi} = +13.4 \text{ LB AT INTERIOR NODES @ } z=0$

$F_{yi} = +6.7 \text{ LB AT END NODES @ } z=0$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




IMAGES-3D
 Ver. 3.0
 Geometry Plot

Top Layer Nodes

?i
 X range
 ?
 X=Default
 Y range
 ?.7,.75
 Z range
 ?
 Z=Default
 ?n
 ?n
 ?#
 ?

~~1351 1366 1381 1396 1411 1426 1441 1456 1471 1486 1501 1516 1531 1546 1561~~
~~1352 1367 1382 1397 1412 1427 1442 1457 1472 1487 1502 1517 1532 1547 1562~~
~~1353 1368 1383 1398 1413 1428 1443 1458 1473 1488 1503 1518 1533 1548 1563~~
~~1354 1369 1384 1399 1414 1429 1444 1459 1474 1489 1504 1519 1534 1549 1564~~
~~1355 1370 1385 1400 1415 1430 1445 1460 1475 1490 1505 1520 1535 1550 1565~~
~~1356 1371 1386 1401 1416 1431 1446 1461 1476 1491 1506 1521 1536 1551 1566~~
~~1357 1372 1387 1402 1417 1432 1447 1462 1477 1492 1507 1522 1537 1552 1567~~
~~1358 1373 1388 1403 1418 1433 1448 1463 1478 1493 1508 1523 1538 1553 1568~~
~~1359 1374 1389 1404 1419 1434 1449 1464 1479 1494 1509 1524 1539 1554 1569~~
~~1360 1375 1390 1405 1420 1435 1450 1465 1480 1495 1510 1525 1540 1555 1570~~
~~1361 1376 1391 1406 1421 1436 1451 1466 1481 1496 1511 1526 1541 1556 1571~~
~~1362 1377 1392 1407 1422 1437 1452 1467 1482 1497 1512 1527 1542 1557 1572~~
~~1363 1378 1393 1408 1423 1438 1453 1468 1483 1498 1513 1528 1543 1558 1573~~
~~1364 1379 1394 1409 1424 1439 1454 1469 1484 1499 1514 1529 1544 1559 1574~~
~~1365 1380 1395 1410 1425 1440 1455 1470 1485 1500 1515 1530 1545 1560 1575~~



Auto	Blowup	Elem#	Exit	Full	Help	Local	Move
Node	Node#	Plot	Range	Rest	Rotate	Shrink	Slice

IMAGES-3D
 Ver. 3.0
 Geometry Plot


Nodes at $Y=0$ (AT INTERFACE BETWEEN FLANGES)

X range
 ?
 X=Default
 Y range
 ?-.04,.04
 Z range
 ?
 Z=Default
 ?r,90
 ?n
 ?n
 ?#
 ?

226	241	256	271	286	301	316	331	346	361	376	391	406	421	436
227	242	257	272	287	302	317	332	347	362	377	392	407	422	437
228	243	258	273	288	303	318	333	348	363	378	393	408	423	438
229	244	259	274	289	304	319	334	349	364	379	394	409	424	439
230	245	260	275	290	305	320	335	350	365	380	395	410	425	440
231	246	261	276	291	306	321	336	351	366	381	396	411	426	441
232	247	262	277	292	307	322	337	352	367	382	397	412	427	442
233	248	263	278	293	308	323	338	353	368	383	398	413	428	443
234	249	264	279	294	309	324	339	354	369	384	399	414	429	444
235	250	265	280	295	310	325	340	355	370	385	400	415	430	445
236	251	266	281	296	311	326	341	356	371	386	401	416	431	446
237	252	267	282	297	312	327	342	357	372	387	402	417	432	447
238	253	268	283	298	313	328	343	358	373	388	403	418	433	448
239	254	269	284	299	314	329	344	359	374	389	404	419	434	449
240	255	270	285	300	315	330	345	360	375	390	405	420	435	450


← INNER O-RING

← OUTER O-RING



Auto Node Blowup Node# Elem# Plot Exit Range Full Rest Help Rotate Local Shrink Move Slice

DEFLECTION ALONG OUTER O-RING





IMAGES-3D
Version 3.0

Y- DISPLACEMENT ALONG OUTER O-RING



1/2 BOLT

*MID PLANE
BETWEEN BOLTS*



Revision 0
Doc. No. V049-1-018
Page 11 of 18


Load Case
1

Displacement Contour Plot
DY

10/20/95
6:53:23



IMAGES-3D
Version 3.0

*Y - DISPLACEMENT ALONG RADIAL PLANE PASSING
THROUGH BOLT*



IMAGES-3D
Version 3.0

*Y- DISPLACEMENT ALONG RADIAL PLANE
PASSING MIDWAY BETWEEN BOLTS*



Revision 0
Doc. No. V049-1-018
Page 13 of 18



Load Case
1

Displacement Contour Plot
DY

10/20/95
7:2:23

IMAGES-3D
Version 3.0

STRESS INTENSITY ALONG RADIAL PLANE PASSING
THROUGH BOLT



Revision 0
Doc. No. V049-1-018
Page 14 of 18



Load Case
1

Stress Contour Plot
Stress Intensity

10/20/95
7:17:13

IMAGES-3D
Version 3.0

STRESS INTENSITY ALONG RADIAL PLANE PASSING
MIDWAY BETWEEN BOLTS



Revision 0
Doc. No. V049-1-018
Page 15 of 18

Load Case
1

Stress Contour Plot
Stress Intensity

10/20/95
7:22:44

14

Y - DISPLACEMENTS

	NODE	Δ_y	EXP	
INNER O-RING	226	.4127	-3	IN } FROM OUTPUT FILE: FLANGE B
	331	.501	-3	
	436	.568	-3	
OUTER O-RING	232	.536	-4	} SEE P. 10
	337	.172	-3	
	442	.251	-3	

RESIDUAL NORM = $.184 (10)^{-10}$
 $< 1 (10)^{-5}$

i. RUN CONVERGED BEFORE 10 ITERATIONS

FOUNDATION	SPRING	LEADS	
	NODE	F _y	
INNER O-RING	226	.303	LD
	331	.355	
	436	.403	
OUTER O-RING	232	.380 (10) ⁻¹	OK
	337	.122	
	442	.178	

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



CIRCUIT Y-DIRECTION REACTION

$$\begin{aligned}
 & \text{BOLT} + \text{PRESS} \\
 & -4250 + 52.1 \text{ lb/in} \times 3.6 \text{ in} \\
 & = -4062 \#
 \end{aligned}$$

REACTION FROM OUTPUT =

$$\sum F_y = 4062 \text{ OR}$$

MAXIMUM SEPARATION OF FLANGES

MAX DEFLECTION IS AT NODE 436 (AT INNER O-RING MIDWAY BETWEEN BOLTS)

$$\Delta_y = .568 (10)^{-3}$$

FOR BOTH BOLT PRELOAD AND INTERNAL PRESSURE, DOUBLE THIS FOR 2 FLANGES

$$\begin{aligned}
 \Delta_y &= 2 (.568) (10)^{-3} \\
 &= 1.137 (10)^{-3} \text{ IN}
 \end{aligned}$$

COMPARE TO MINIMUM COMPRESSION OF .058 IN FROM PAPER HANDBOOK (P A5-13)

$$\frac{54 (10)^{-3}}{1.137} = 51$$

∴ OPENING OF GRA << INITIAL COMPRESSION OF O-RING AND O-RING REMAINS COMPRESSED DURING INTERNAL PRESS = 2 PSIG.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



MAXIMUM TENSILE LOAD AT VITON O-RING

$$T = .403 \text{ LB AT NODE 436}$$

ALONG THE O-RING, THE LINEAR FORCE IS

$$T = \frac{.403}{.257} \leftarrow \text{NODE SPACING} = 1.57 \text{ LB/IN}$$

THIS COMPARES TO MINIMUM SEALING LOAD OF 70 LB/IN (PARKER HANDBOOK, P. A4-11)

$$C - T = 70 - 1.57 = 68.4 \text{ LB/IN}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-019 PAGE 1 OF 24
REV.	DEO #	DATE	BY:	CHECK	Flange Design for Internal Pressure	
0	0024	12/6/95	RAC	P.W.K.		
					BY: <i>R.D. Cirro</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	

PURPOSE: To evaluate bolted flanges ranging in diameter from 30 in. to 104 in. for positive internal pressure in accordance with the ASME Code.

METHOD: The calculation method provided in Appendix Y of the ASME Code, Section VIII, Division 1, is used. This method applies to flat face flanges with metal-to-metal contact. It has been programmed on the Quatro-Pro spread sheet program.

ASSUMPTIONS:

INPUTS: LIGO project sketches and drawings.

- REFERENCES:** 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 1, Appendix Y.
 2. Quattro-Pro Version 5.00
 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: Using a nominal bolt spacing of 7.2 in. for 7/8 in. diameter bolts, the flanges meet App. Y of Section VIII, Div. 1 for 2 psi internal pressure. Computer file names are shown in the lower left corner of the output in this calculation.

NOTES: In this calculation, flange thickness varies from 3/4 in. for small diameter to 1 in. for large diameter flanges.

FLANGE DESIGN FOR INTERNAL PRESSURE

THE FLANGES ARE EVALUATED IN ACCORDANCE WITH SECT VIII, DIV 1 APP Y FOR FLAT FOOT FLANGES. THE DESIGN INTERNAL PRESSURE IS 2.00 PSIG

THE NOMINAL FLANGE THICKNESS IS 2.00 IN

QUARTER PAD IS USED FOR THE FLANGE EVALUATION. IT SHOWS THAT $7/8$ " BOLTS SPACED AT APPROX 7.2 IN ARE ADEQUATE.

FOR THE MAXIMUM DIAMETER OF 90, THE MAXIMUM O-RING COMPRESSION LOAD IS 160 LB/IN SINCE THERE IS A DOUBLE O-RING, THE LOAD IS MULTIPLIED BY 2 FOR THE ANALYSIS.

$$H_g = 2(160) = 320 \text{ LB/IN}$$

THE ROOT DIAMETER OF THE $7/8$ " BOLT IS

$$d_b = .755 \text{ IN (AISC P 4-147)}$$

WHICH IS USED TO COMPUTE THE TENSILE AREA

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

C = BOLT CIRCLE DIAM in.
 PRES = Internal Pressure for this case
 B=ID OF FLANGE
 A=OD OF FLANGE
 g_1 =THICKNESS OF HUB AT LARGE END
 g_0 =THICK @ SMALL END
 r_b =SEE FIG Y3.1
 V=SEE FIG 2-7.3
 F=SEE FIG 2-7.2
 t=FLANGE THICKNESS ASSUMED VALUE
 G=DIAM OF GASKET
 n=NUMBER OF BOLTS
 d_b =DIAM OF BOLTS
 r_e =RATIO MOD E (flange)/ MOD E (bolts)
 Z=SEE FIG 2-7.1

INPUT VALUES..... 104 1/4 in Flange

C	PRES	B	A	g_1	g_0	V
110.00	2.00	105.00	112.00	0.000	0.000	0.11

g_1 and $g_2=0$ for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
0.75	1.00	108.25	48	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0525	0.0292	105.00	1.02	1.0571

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	17318.0	18406.7	1088.66	108824.8

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	140353.861	95221.7	0.00	7129.60
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4837.01	2.807E+05	190443.3	407939.2	299268.1	21.49	0.818
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.113550	0.000467	0.022424	1.066667	15.52

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
18983.24	13926.29	18844.7	13832.3	2749.0	1865.0
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
67.9	46.1
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g1=g0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- $g1$ =THICKNESS OF HUB AT LARGE END
- $g0$ =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 84 1/4 in Flange

C	PRES	B	A	$g1$	$g0$	V
89.75	2.00	84.75	91.75	0.000	0.000	0.11
				$g1$ and $g2=0$ for loose type flanges		fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	1.00	88.00	40	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0650	0.0363	84.75	1.03	1.0708

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	11282.3	12164.2	881.90	88467.2

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	107102.913	77408.8	0.00	6759.70
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4885.59	2.142E+05	154817.7	314837.3	243284.9	17.91	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.124841	0.000685	0.027398	1.082596	12.63

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
17580.95	13585.37	17451.7	13491.9	2604.2	1882.2
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
79.8	57.6
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1 = g_0 =$ thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F' = 0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 72 1/4 in Flange

C	PRES	B	A	g_1	g_0	V
77.75	2.00	72.75	79.75	0.000	0.000	0.11

g_1 and $g_2 = 0$ for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	1.00	76.00	36	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0754	0.0422	72.75	1.03	1.0825

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	8313.5	9072.9	759.38	76403.5

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.755	88918.3929	66853.1	0.00	6516.01
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
4899.04	1.778E+05	133706.2	263313.2	210109.7	16.12	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.129698	0.000825	0.029710	1.096220	10.92

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
16337.53	13036.47	16213.8	12943.5	2509.7	1886.9
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
89.6	67.3
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 60 1/4 in Flange Thickness = 7/8 in

C	PRES	B	A	g_1	g_0	V
65.75	2.00	60.75	67.75	0.000	0.000	0.11

g_1 and $g_2=0$ for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.875	64.00	30	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.0896	0.0500	60.75	1.04	1.0988

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	5797.1	6434.0	636.86	64339.8

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.505	71864.8462	56297.3	0.00	9327.89
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
7307.26	1.437E+05	112594.7	214503.5	176934.5	13.43	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.127808	0.000960	0.028798	1.115226	9.21

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
15970.90	13173.69	15777.3	13022.0	3126.0	2448.9
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
134.4	105.2
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g1=g0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- $g1$ =THICKNESS OF HUB AT LARGE END
- $g0$ =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t =FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n =NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 48 1/4 in Flange Thickness = 7/8 in

C	PRES	B	A	$g1$	$g0$	V
53.75	2.00	48.75	55.75	0.000	0.000	0.11

$g1$ and $g2=0$ for loose type flanges
 fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.875	52.00	24	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1103	0.0615	48.75	1.05	1.1231

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	3733.1	4247.4	514.34	52276.1

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.505	55942.2729	45741.6	0.00	8927.49
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
7299.62	1.119E+05	91483.2	168408.1	143759.3	10.74	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.125074	0.001146	0.027507	1.143590	7.50

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
15673.57	13379.53	15489.8	13229.3	2967.4	2426.3
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
160.2	131.0
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1 = g_0 =$ thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F' = 0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- db=DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 44 1/4 in Flange Thickness = 3/4 in

C	PRES	B	A	g_1	g_0	V
49.75	2.00	44.75	51.75	0.000	0.000	0.11

g_1 and $g_2 = 0$ for loose type flanges fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.750	48.00	24	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1199	0.0670	44.75	1.06	1.1341

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	3145.6	3619.1	473.50	48254.9

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.255	50886.0759	42223.0	0.00	14046.64
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
11655.27	1.018E+05	84446.0	153646.1	132700.9	10.74	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.135130	0.001351	0.032420	1.156425	6.93

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
14299.69	12350.34	13981.6	12086.4	4015.4	3331.8
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
235.4	195.3
14700.00	14700.00
ok	ok

THIS PROGRAM SOLVES APPENDIX Y (Y-6.1) FLAT FACE FLANGES FOR CLASS 1, CAT 3 (LOOSE TYPE) ASSEMBLIES WITH OR WITHOUT SELF ENERGIZING GASKETS FOR POSITIVE PRESSURE OR VACUUM PRESSURE.

ANALYZE CLASS 1 CATEGORY 3 LOOSE TYPE FLANGES ONLY.

ASSUMPTIONS:

1. $g_1=g_0$ =thickness of vessel wall
2. B substituted for B1
3. conditions at bolt up and operating evaluated separately
4. $F'=0$ for loose type flanges implies M_s is zero

REQUIRED INPUT:

- C = BOLT CIRCLE DIAM in.
- PRES = Internal Pressure for this case
- B=ID OF FLANGE
- A=OD OF FLANGE
- g_1 =THICKNESS OF HUB AT LARGE END
- g_0 =THICK @ SMALL END
- r_b =SEE FIG Y3.1
- V=SEE FIG 2-7.3
- F=SEE FIG 2-7.2
- t=FLANGE THICKNESS ASSUMED VALUE
- G=DIAM OF GASKET
- n=NUMBER OF BOLTS
- d_b =DIAM OF BOLTS
- r_e =RATIO MOD E (flange)/ MOD E (bolts)
- Z=SEE FIG 2-7.1

INPUT VALUES..... 30 1/4 in Flange Thickness = 3/4 in

C	PRES	B	A	g_1	g_0	V
35.75	2.00	30.75	37.75	0.000	0.000	0.11
				g_1 and $g_2=0$ for loose type flanges		fig 2-7.3 required for integral only

F	t	G	n	db	rE	fhub
	0.750	34.00	16	0.755	0.96	1.00

fig 2-7.2
required for
integral only

fig 2-7.6
fhub= 1 for
loose type
flanges

Sbb	Sfb	Snb	Sbo	Sfo	Sno	Hg(unit)
25000	14700	14700	25000	14700	14700	320

unit gasket
seating and
sealing forces

RESULTS/OUTPUT:

- Si = DESIGN PRESTRESS IN BOLTS
- Sr@BC = RAD. FLANGE STRESS @ BOLT CIRCLE
- Sr@ID = RAD FLG STRESS @ ID
- St = TANGENTIAL FLANGE STRESS @ ID
- Sh = LONGITUDINAL HUB STRESS (= 0 FOR CL1, CAT3 LOOSE TYPE FLANGES)

CALCULATED VALUES.....

R	hd	Js	Jp	B1	BETA	a
2.50	2.50	0.1694	0.0942	30.75	1.08	1.1951

for loose
type flgs

hc	ho	F'	Hd	H	Ht	Hg
0.50	0.00	0.00	1485.3	1815.8	330.55	34180.5

hg	ht	l	Mpo	Mpb	Ms	E0bo
0.88	1.688	2.255	34178.988	29908.0	0.00	13266.80
			operating moment	bolt up moment		operating slope

E0bb	Hco	Hcb	Wm1o	Wm1b	Ab	D
11608.97	6.836E+04	59815.9	104354.3	93996.5	7.16	0.880
bolt up slope	operating contact	bolt up contact	operating bolt load	bolt up bolt load		

AR	rB	nrB	K	Z
0.125365	0.001728	0.027643	1.227642	4.94

SIGMAbo	SIGMAbb	Sio	Sib	Sr@BCo	Sr@BCb
14568.23	13122.23	14273.2	12864.0	3711.4	3247.6
25000.00	25000.00	25000.00	25000.00	14700.00	14700.00
ok	ok	ok	ok	ok	ok

St@IDo	St@IDb
323.6	283.1
14700.00	14700.00
ok	ok

BOLT PRELOAD

PER APP Y, THE DESIGN BOLT PRELOAD IS W_{M10} (CONSIDERS INTERNAL PRESSURE AT OPERATING CONDITION)

FLANGE SIZE	N	W_{M10} LB	$F_{PL} = W_{M10}/N$	USE
104	48	407939	8498	8500 LB ↓
84	40	314137	7870	
72	36	263313	7314	
60	30	214504	7150	
48	24	168404	7017	
44	24	153646	6402	
30	16*	104354	6522	

NOTE: BOLT PRELOAD IS INCREASED TO 10K. BOLT STRESS IS STILL WITHIN LIMIT REF CALL 042, P. 20.

* NO. OF BOLTS WAS INCREASED TO 24 FOR THE 30 IN FLANGE, REF CALL 042, P. 26

REVISION 0
Doc. No. V049-1-019
P 24 OF 24



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-020 PAGE 1 OF 13
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of Removable Work Floor	
0	0024	4/12/96	ROC	AGR		
					BY: R.D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	

PURPOSE: To design removable floor and support members to be installed in lower section of BSC.

METHOD: Hand calculations using standard beam design method for support beams and removable floor sections.

ASSUMPTIONS:

INPUTS: See Doc. No. LIGO-C951078-00-4 which provides response to V049-NL-PL-9 (requesting clarifications of BSC internal floor requirements). Maximum load is 500 Kg during maintenance. This occurs at room temperature.


REFERENCES: 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1.
2. Aluminum Association Handbook
3. Doc. No. V049-1-066, LIGO VAC. EQUIP., S-2007, DESIGN CR.

CALCULATIONS: (SEE ATTACHED)

CONCLUSIONS: The design of the aluminum floor meets LIGO requirements and the requirements of the applicable design codes.

NOTES:

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



I 6x4.3
AL SUPP BM



C 12 x 10.374 (TYP) - FLAT SIDE UP

MATERIAL

SB 22) - 6061 - T6

REV D
Doc. No. V049-1-020
P. 2 OF 13

22-141 50 SHEETS
22-142 100 SHEETS
22-143 200 SHEETS




A - A

RING THICKNESS = 1/2"
GUSSET THICKNESS = 3/8"

REV 0
Doc. No. J049-1-020
P. 2 OF 13

FLOOR SUPPORT TO SKEL CONNECTION



22-141 60 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



REV D
Doc. No V049-1-020
P. 4 OF 13

FLOOR MATERIAL

SB 221 ALLOY 6061
TEMPER T6

YIELD $F_y = 35 \text{ ksi} @ \text{ROOM TEMP}$

ULTIMATE $F_u = 38 \text{ ksi} @ \text{ROOM TEMP}$
REF ASME B31 CODE SECT II, TABLE 1B

ALLOWABLE BENDING STRESS

FOR WEAK AXIS BENDING USE ASSE RULE

$$F_b = .75 F_y \\ = .75 (35) = 26.25 \text{ ksi}$$

NOTE: THIS IS LESS THAN ALUMINUM ASSOC.
ALLOWABLE USING $F_s = 1.5$

FOR STRONG AXIS BENDING STRESS
WILL BE KEPT REASONABLY LOW TO
AVOID LOCAL & LATERAL TORSIONAL
BUCKLING

REV 0
Doc. No. V049-1-070
P. 5 OF 13

STIFFNESS OF ALUM C12X 7.41 FOR
LOAD AT CENTER BENT ABOUT WEAK
AXIS

$$\Delta_y = \frac{PL^3}{48EI_y}$$

$$L = 104$$

$$E = 10(10)^6 \text{ psi}$$

$$I_y = 3.99 \text{ in}^4$$

$$\begin{aligned} \Delta_y &= \frac{P(104)^3}{48(10)^7(3.99)} \\ &= \frac{P}{1702.6} \end{aligned}$$

$$R_1 = 1702.6 = \frac{P}{\Delta_y} \text{ LB/IN}$$

STIFFNESS OF ALUM I6X 4.3 FOR LOAD
AT CENTER BENT ABOUT STRONG AXIS


$$I_x = 22.06 \text{ in}^4$$

$$\begin{aligned} R_2 = \frac{P}{\Delta_y} &= \frac{48(10)^7(22.06)}{(104)^3} \\ &= 9422 \text{ LB/IN} \end{aligned}$$

REV D
DOC. NO. V049-1-020
P. 6 OF 13



THE SUPPORT BEAM AND THE LOWER CHANNEL ACT AS SPRINGS IN PARALLEL FOR A LOAD AT THE CENTER OF THE VESSEL



$$K = R_1 + R_2$$

$$= 1703 + 5422 = 11125 \text{ LB/IN}$$

MAY DEFLECT AT CTR (LIVE LOAD)

$$K = \frac{P}{\Delta}$$

$$\Delta = \frac{P}{K} = \frac{1100}{11125} = .10 \text{ IN OK}$$

STRESS IN INVERTED CHANNEL DUE TO LOAD AT CTR

$$\Delta = \frac{P_i}{R_i}$$

$$P_i = \Delta R_i = .10(1703) = 170 \text{ LB}$$

$$M = \frac{PL}{4} + \frac{WL^2}{8}$$

$$= \frac{170(104)}{4} + \frac{7.41(104)^2}{8}$$

$$= 4420 + 835$$

$$= 5255 \text{ IN-LB}$$

REV D
DOC NO V049-1-020
P. 7 OF 13

$$S_y = 1.76 \text{ FOR } C12 \times 7.41^*$$

* CHANGED TO C10 X 10.374

$$f_b = \frac{M}{S} = \frac{5255}{1.76} = 2985 \text{ psi OK}$$

STRESS IN INVERTED CHANNEL W/ LOAD AT
1/4 PT

$$M = \frac{1100(52)}{4} + \frac{7.41(52)^2}{8}$$

$$= 14300 + 209$$

$$= 14509 \text{ IN-LB}$$

$$f_b = \frac{M}{S} = \frac{14509}{1.76} = 8243 \text{ psi OK}$$

STRESS IN SUPPORT BEAM DUE TO DW

$$\text{Use } w = 30 \overset{C12}{+} 4.3 = 34.3 \text{ LB/FT}$$

$$\approx 3 \text{ LB/IN}$$

$$M = \frac{wL^2}{8} = \frac{3(104)^2}{8}$$

$$= 4056$$

$$f_b = \frac{M}{S_y} = \frac{4056}{7.36} = 550 \text{ psi}$$

REV 0
Doc. NO. 1049-1-020
P. 8 OF 13



STRESS IN SUPPORT BEAM DUE TO
LIVE LOAD AT CENTER

$$\Delta = \frac{P_2}{K_2}$$

$$P_2 = K_2 \Delta$$

$$= 9422 (.10) = 942 \text{ LB}$$

$$M = \frac{PL}{4} = \frac{942(104)}{4} = 24500$$

$$f_b = \frac{M}{S_v} = \frac{24500}{22.08}$$

$$= 1100 \text{ PSI}$$

TOTAL STRESS IN SUPPORT BEAM DUE TO
DW & LL

$$f_b = 1100 + 550$$

$$= 1650 \text{ PSI} \quad \text{LOW}$$

REV. 0
Doc. No. V049-1-020
p. 9 OF 13


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



BENDING STRESS IN WEB OF CHANNEL

TRAY C12 X 10.374 AMERICAN STD

WEB THICKNESS $t = .510$



ASSUME THAT LOAD IS 3 IN WIDE

$$M = \frac{PL}{4} = \frac{1100(12)}{4}$$

$$= 3300 \text{ IN-}\#$$

$$f = \frac{6M}{bt^2} = \frac{6(3300)}{3(.510)^2}$$

$$= 25400 \text{ PSI}$$

$$< 26250 \text{ PSI} \quad \text{OK}$$

FOR BENDING ABOUT WEAR AXIS

$$S_y = 2.06 \quad \text{REF AISC CODE}$$

$$= \text{SECT. MODULUS}$$

ASSUME SINGLE SUPPORT BEAM AT CENTER OF BSC

$$L = 52$$

$$M = \frac{1100(52)}{4} = 14300 \text{ IN-}\#$$

$$f_b = \frac{14300}{2.06} = 6940 \text{ OK}$$

REV D
DOC. NO. V0119-1-023
P. 10 OF 13



SUPPORT RING

GUSSETS WILL BE PLACED UNDER SUPPORT RING SO THAT THEY ARE ALIGNED WITH POINT OF CONTACT OF C12 FLANGE

THE MAX REACTION FROM THE C12 IS

$$R = 1100 + 52 \times 10.274 \\ = 1640 \text{ LB}$$

SINCE THE GUSSET IS $\frac{3}{8}$ " THICK AND THE WELD BETWEEN THE SHELL & GUSSET IS A FULL PEN., THE WELD AREA IS

$$A_w = 2\left(\frac{3}{8}\right) = .75 \text{ IN}^2$$

WELD SHEAR STRESS

$$f_v = \frac{R}{A_w} \\ = \frac{1640}{.75} = \\ = 2200 \text{ psi} \quad \text{OK}$$

SUPPORT RING & GUSSETS ARE 304/304L

REV D
Doc. No. V049-1-020
P. 11 OF 13

SUPPORT BEAM CONNECTION TO SHELL
THE WEB THICKNESS FOR THE I6x4.3
IS

$$t_w = .23 \text{ IN}$$

FOR A SINGLE 3/4 IN PIN
THE BEARING AREA IS

$$A_p = .75(.23) \\ = .1725$$

THE MAX REACTION IS

$$R = \frac{104}{2(12)} (24.3 \text{ LB/FT}) + 1100 \\ = 150 + 1100 = 1250 \text{ LB}$$

BEARING STRESS

$$f_p = \frac{R}{A_p} \\ = \frac{1250}{.1725} = 7250 \text{ PSI} \quad \text{MA}$$

USE A 1 IN PIN TO REDUCE f_p

$$f_p = 7250 \times .75 = 5400 \text{ PSI}$$

IN DOUBLE SHEAR

$$A_s = 2 \pi (.5)^2 \\ = 1.57 \text{ IN}^2$$

$$f_s = \frac{1250}{1.57} = 800 \text{ PSI} \quad \text{OK FOR SS PIN}$$

REV D
DOC. NO. V049-1-020
P. 12 OF 13

DIFFERENTIAL EXPANSION BETWEEN
STEEL AND ALUM SUPPORT BEAM

$$\alpha_{AL} = 13.52 (10)^{-6} \frac{IN}{IN \cdot ^\circ F}$$

FOR 6061

$$\alpha_{SS} = 9.19 (10)^{-6}$$

FOR TEMP RISE TO 400°F

$$\Delta T = 400 - 70 = 330^\circ F$$

$$\delta = (\alpha_{AL} - \alpha_{SS}) L \Delta T$$

$$L = 104 \text{ IN}$$

$$\begin{aligned} \delta &= (13.52 - 9.19) (10)^{-6} (104) (330) \\ &= .15 \text{ IN} \end{aligned}$$

USE AN OVSER-20 BOLT HOLE TO
TAKE δ FROM BIC E

$$\delta = \frac{.15}{2} = .075$$

HOLE SIZE = $1\frac{1}{2}$ GIVES CLEARANCE

$$.125 > \delta = .075 \quad R$$

REV 0
Doc. NO. V049-1-020
P. 13 OF 13


50 SHEETS
100 SHEETS
200 SHEETS

22-141
22-142
22-144



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-021 PAGE 1 OF 7
REV.	DEO #	DATE	BY:	CHECK	TITLE: Design of Flange Welds	
0	0136	12/6/95	RDC	WDB		
1	0253	8/22/96	RDC	WDB		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Design partial penetration seal weld and external stitch weld between flanges and shells						
<u>METHOD:</u> Hand calculations are used to determine the pressure discontinuity moments and forces and resulting weld stresses.						
<u>ASSUMPTIONS:</u> To determine the discontinuity moment and shear it is conservatively assumed that the cylindrical shell is built into a rigid wall.						
<u>INPUTS:</u> 1. LIGO project drawings of bolted flanges 2. Calc. No. V049-1-066, LIGO Vacuum Equipment Structural Design Criteria						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Div. 2. 2. Doc. No. V049-1-042, Bolted Flange Analysis for Tensile Forces. 3. Doc. No. V049-1-107, Welds for 60.5 in Nozzle to Shell Joints.						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> For the bounding case flange (104.5 in) the required partial penetration weld is 1/8 in and the required fillet weld is 3/16 (2 in every 6 in).						
<u>NOTES:</u>						

BARFL FLANGE IS CONNECTED TO THE CYLINDRICAL SHELL WITH 2 WELDS AS SHOWN BELOW



THESE WELDS RESIST DISCONTINUITY MOMENTS AND FORCES BETWEEN THE CYLINDER AND THE FLANGE THAT RESULT FROM POSITIVE OR NEGATIVE PRESSURE. THE FILLET WELD (STITCH) AND THE PARTIAL PEN WELD ARE ASSUMED TO RESIST THE DISCONTINUITY MOMENT WITH A FORCE COUPLE.


ONLY THE PARTIAL PEN WELD IS ASSUMED TO RESIST THE DISCONTINUITY SHEAR FORCE. TO BE CONSERVATIVE, ONLY THE PARTIAL PEN WELD IS ASSUMED TO RESIST THE FLANGE TENSILE FORCE THAT RESULTS FROM POSITIVE PRESSURE AND COMPONENT INTERFACE LOADS (REF CALLS V049-1-032 AND -042).

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PRESSURE DISCONTINUITY STRESSES FOR A CYLINDER AT A RIGID WALL.

(FLANGE IS ASSUMED TO ACT AS A RIGID WALL)



FOR EXTERNAL PRESSURE, P

SHEAR $V = .660 P \sqrt{rt}$

MOMENT $M = .257 P r t$

STRESSES WILL BE DETERMINED WITHOUT REGARD TO SIGN IN ORDER TO OBTAIN THE MAXIMUM TENSILE STRESS IN THE PP WELD AND THE MAXIMUM SHEAR STRESS IN THE STITCH FILL-WELD.

FROM THE ABOVE EQUATIONS, IT IS APPARENT THAT THE MAX DISCONTINUITY SHEAR FORCE AND MOMENT PER IN OF CIRCUMFERENCE WILL BE IN THE LARGEST DIAMETER FLANGE. THIS IS THE 104 1/2" FLANGE

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



$$r = 52.25 + .25 = 52.5 \text{ IN}$$

FOR 104 1/2 IN FLANGE

$$t = .5$$

$$p = 14.7 \text{ PSI FOR FULL VACUUM}$$

$$V = .660 p \sqrt{rt}$$
$$= .660 (14.7) (52.5 \times .5)^{1/2}$$
$$= 49.71 \text{ LB/IN}$$

$$M = .257 p r t =$$
$$= .257 (14.7) (52.5) (.5)$$
$$= 99.17 \text{ IN-LB/IN}$$


SHEAR STRESS IN PAR. PEN. WELD (TAY 1/8 IN)

$$f_v = \frac{V}{t_w}$$

$$t_w = .125$$

$$f_v = \frac{49.71}{.125} = 398 \text{ PSI}$$

DIRECT STRESS IN PAR. PEN WELD



$$p = 14.7 \text{ PSI}$$

$$F = \frac{p r}{2} + \frac{M}{t/2} + 362^*$$

Revision No. 1
Doc. No. V049-1-021
Page 4 of 7

t/2 IS CONSERVATIVE MOMENT ARM

* REF TABLE V049-1-042, P 72 FOR
WORST CASE FLANGE TENSILE FORCE.
THIS IS FOR 30.25 IN FLANGE.

$$F = \frac{14.7(52.5)}{2} + \frac{99.17}{.25} + 362$$

$$= 386 + 397 + 362 = 1145 \text{ LB/IN}$$

TENSILE STRESS

$$f_t = \frac{1145}{.125} = 9160 \text{ PSI}$$

PRINCIPAL STRESS IN PAR PWD WELD

$$\sigma_{MAX, MIN} = \frac{\sigma_x + \sigma_y}{2} \pm \sqrt{\left(\frac{\sigma_x - \sigma_y}{2}\right)^2 + \tau^2}$$

$$\sigma_x = f_t = 9160$$

$$\sigma_y = 0$$

$$\tau = f_v = 398$$

$$\sigma_{MAX, MIN} = \frac{9160}{2} \pm \sqrt{\left(\frac{9160}{2}\right)^2 + 398^2}$$

$$= 4580 \pm 4597$$

$$= 9177 \text{ OR } -17 \text{ PSI}$$

STRESS INTENSITY

$$SE = 9177 - (-17)$$

$$= 9195, \text{ SAY } 9200 \text{ PSI OR}$$

FOR PL CATEGORY, COMPARE TO 1.5 SM


$$S_M = 15.8 \text{ KSI}^* \Rightarrow 1.5 S_M = 23.7 \text{ KSI OR}$$

*FOR 304L @ 400°F, FLANGE IS 304L SS.

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



STITCH FILLET WELD RESISTS MOMENT THROUGH COUPLE, DIRECT LOAD, F, IS ASSUMED TO BE RESISTED BY PAR PEN WELD ONLY



$$M = F \left(\frac{t}{2} \right)$$

$$\Rightarrow F = \frac{2M}{t}$$

$$= \frac{2(99.17)}{.5}$$

$$= 397$$

FOR A 3/16 STITCH FILLET, 2 IN LONG @ 6 IN THE SHEAR STRESS IS

$$f_v = \frac{F}{1707 t_{weld}} \times \frac{6}{2}$$

$$= \frac{397}{1707(3/16)} \times \frac{6}{2}$$

$$= 9000 \text{ psi}$$

COMPARE TO LIMIT FOR PLATE SHEAR PER SECT. VIII, DIV. 2, AD 132.2. THIS IS .6 S_M

S_M = 15.8 ksi @ 400°F FOR TA 304L

304L IS USED FOR FLANGES

$$.6 S_M = 9.5 \text{ ksi}$$

$$f_v < .6 S_M \quad \text{OK}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



TRY THE SAME WELD CONFIGURATION IN A 1/4" THICK SHELL SAME MANY OF THE TUBES ARE 1/4" IN THICK

$$V = .660 (14.7) (52.5 \times .25)^{\frac{1}{2}} = 35.15 \text{ LB/IN}$$

$$M = .257 (14.7) (52.5)(.25) = 49.58 \text{ IN-LB/IN}$$

1/8" PAR PEN WELD

$$f_v = \frac{V}{t_w} = \frac{35.15}{.125} = 281 \text{ psi}$$

$$F = 346 + \frac{M}{\frac{t}{2}} + 362 = 346 + \frac{49.58}{\frac{.25}{2}} + 362 = 346 + 397 + 362 = 1145$$

SAME AS F FOR 1/2 IN SHELL

$$\therefore S I \approx 9200 \text{ OR}$$

FOR 3/16 SEITCH FILLET *

$$F = \frac{2M}{t} = \frac{2(49.58)}{.25} = 397$$

SAME AS F FOR 1/2 IN SHELL

$$\therefore f_v \approx 9000 \text{ psi OR}$$

* NOTE 1/4" FILLET 2" @ 6" USED IN FINAL DESIGN OF SOME COMPONENTS.

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-022 PAGE 1 OF 16
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber, FE Analysis of Lower Section	
0	0128	12/6/95	RDC			
		4/18/96		P.W.Y.		
					BY: <i>R.D. CIRIO</i>	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
<u>PURPOSE:</u> To evaluate the lower section of the beam splitter chamber for vacuum pressure.						
<u>METHOD:</u> A finite element analysis of the lower section shell, head and nozzles is performed.						
<u>ASSUMPTIONS:</u>						
<u>INPUTS:</u> LIGO project sketches and drawings. Shell thickness = .5 in. 60 in. nozzle thickness = .5 in. Head thickness = .375 in.						
<u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Div. 1 2. IMAGES 3D, Version 3.0, R.L. Cloud & Associates 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP. STRUCTURAL DESIGN CRITERIA						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Stresses are within the limits of the ASME Code, Section VIII, Div. 1.						
<u>NOTES:</u> Computer files are BMSPLI10, BMSPLI11, and BMSPLI12.						

BSC

END CAP LOADS ON 60 IN. NOZZLES

THERE ARE 32 ELEMENTS AROUND THE 60 IN FLANGE. THE AREA FOR THE MODEL IS $\frac{1}{2}$ OF THE CIRCLE

$$A = \frac{\pi r^2}{2}$$

$$r = 30 \text{ IN}$$

$$A = 1414 \text{ IN}^2$$

THE TOTAL VACUUM LOAD IS

$$F = pA$$

$$p = 14.7 \text{ PSI}$$

$$F = 14.7(1414) = 20,782 \text{ LB}$$

FOR EACH FLANGE NODE AT THE NOZZLE INNER SURFACE, EXCEPT THE CORNER NODES THE FORCE IS

$$F_i = \frac{20782}{32} = 649.4 \text{ LB}$$

FOR CORNER NODES

$$F_i = \frac{649.4}{2} = 324.7 \text{ LB}$$

BSC FE ANALYSIS OF LOWER SHELL

FILE NAME: BMSPL12 - FINAL MODEL

LOAD CASES

1. VACUUM PRESS = 1417 PSI
END CAP LOAD ON BOTH GD IN NOZZLES
2. SAME AS 1 BUT GD IN NOZZLE ON Y AXIS HAS NO END CAP LOAD (SIMULATED BELLOWS)
3. SAME AS 1 BUT SUPPORT LEG REACTIONS ARE APPLIED TO SHELL AT 12 NODES AT WELD PAD

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



LOAD CASE 3

SUPPORT LEG REACTION ON SHELL.


LOCAL MEMBER FORCES (FROM BSC5000B FILE)

MEMBER	NODE	F_y (VERT)	F_z (TANGENTIAL)	F_x (RADIAL)
2	3	-3019	-14900	442 LB
→ 4	6	-18760	125	-15620
6	9	-3281	14900	694
8	12	12460	-125	14490

THE BOUNDING LOADS ARE AT MEMBER 4
WHERE THE VERTICAL LOAD IS 18760 AND
THE RADIAL LOAD IS 15620 LB. MOMENTS
ARE NOT EVALUATED SINCE THEY ARE ROTATION
LIMITED.

* NO PRINTED OUTPUT, FORCES FROM SCREEN

FOR THE BMSPL12 MODEL, THE RADIAL
LOAD WILL BE APPLIED OUTWARD AND
THE VERTICAL LOAD WILL BE DOWNWARD
THE GLOBAL LOAD COMPONENTS IN THE
BMSPL12 MODEL ARE



$$F_y = 18760 \text{ LB}$$

$$F_z = .707 (15620) = 11045 \text{ LB}$$

$$F_x = F_z = 11045 \text{ LB}$$

$\theta = 45^\circ = \text{ANGULAR}$
LOCATION OF PAD FROM
Z-AXIS



APPLY LOADS TO THE FOLLOWING NODES

131
134
178
179
273
275
~~294~~ ⇒ 12 NODES
~~279~~
281
1028
1031
1035
1174
1172

NODAL LOADS

$$F_{Y1} = \frac{F_1}{12} = \frac{18760}{12} = 1563 \text{ LB}$$

$$F_{Y2} = \frac{F_2}{12} = \frac{11045}{12} = 920.4 \text{ LB}$$

$$F_{Z1} = \frac{F_3}{12} = 920.4 \text{ LB}$$

NOTE: THE FINAL SUPPORT LEG FORCES ARE GIVEN ON P. 32 OF CASE 024. THE RESULTANT FINAL LOAD IS $F = 27.2 \text{ K}$. FOR THE FORCES ANALYZED IN THIS CASE THE RESULTANT IS SLIGHTLY LOWER

$$F = (18.76^2 + 11.0^2 + 11.0^2)^{\frac{1}{2}} \\ = 24.4 \text{ K}$$

SINCE THE SHELL STRESS PLOT ON P. 15 SHOWS THAT THE MAX STRESS INTENSITY IS ONLY ABOUT 8.5 KSI AT THE LEG ATTACHMENT, THE SHELL STRESSES MEET THE CRITERIA FOR THE FINAL LOADS.

LOAD CASE 1 RESULTS SUMMARY FOR 3 LAST MODELS

BEAM SPL 10

- NO STIFFENERS AT G-NOZZLES
- RING STIFFENER ABOVE PORTS
- ANGLE STIFFENER BELOW "

MAX SE = 12.5 KSI AT MIDDLE G-NEZ

" " = 14 KSI AT UPPER NOZZLES
(MAX LOCAL AT RING STIFFENER)

MAX SE = 23.8 KSI AT BOTTOM OF
60 IN PORTS

STRESS IN LOWER HEAD \approx 2.7 KSI
MAX RADIAL DISP = .15" @ G-NEZ

BMSPL12

- SAME AS BMSPL10 BUT NO STIFFENER
BELOW 60" PORT

MAX RADIAL DISP = .19 IN @ G-NEZ

AT MIDDLE NEZ G, MAX SE = 21 KSI

AT UPPER NOZZLES, MAX SE = 17.1 KSI
AT RING STIFFENER.

AT BOTTOM OF 60 IN PORTS, SE = 28.4 KSI

LOAD CASE 1 RESULTS CONT.

BMP LI 12 (FINAL MODEL)

- STIFFNESS BETWEEN G NOZ*
- RING STIFFNESS ABOVE PORTS (4" x 3/4")
- NO STIFFNESS BELOW PORTS

AT G-NOZZ

MAX SE = 27.9 KSI AT STIFF. JOINT /
GO IN PORT

MAX Δ = .14" (RADIAL)

AT UPPER NOZZLES

MAX SE = 14 KSI AT TOP OF 60" PORT

AT BOT OF 60" PORTS

MAX SE = 27.9 KSI (VERY LOCAL)

NOTE: ALL SE'S ARE AT SURFACES

* STIFFNESS IS 2" x 3/4"

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



THE FOLLOWING PLOTS ARE FROM
THE MODEL WITH

FILENAME: BMSPLI2

MAX STRESS INTENSITY

$SI_{MAX} = 23.5 \text{ KSI}$ AT BOTTOM OF
60 IN NOZZLES

$\leq 1.5 S = 24.3 \text{ KSI @ } 400^\circ \text{ F}$


FOR 304/304L
DUAL CERTIFIED MATERIAL

THIS MAX STRESS IS VERY LOCAL


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
Version 3.0



MAY DEFL AT MIDDLE
NORTH G
 $D_x = D_y = .106$
 Result $\Delta = (.106^2 + .106^2)^{1/2}$
 = .15 IN
 INWARD






Load Case
1

Displacement Contour Plot
DY

11/16/95
11:53:45

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-022
Page 10 of 16

Load Case
1

Stress Contour Plot
Surf: Top
Stress Intensity

11/16/95
11:50:33

IMAGES-3D
Version 3.0





Revision 0
Doc. No. V049-1-022
Page 11 of 16

Load Case
2

Displacement Contour Plot
DY

11/16/95
12: 2: 0

IMAGES-3D
Version 3.0




Revision 0
Doc. No. V049-1-022
Page 12 of 16

Load Case
2

Displacement Contour Plot
DZ

11/16/95
11:57:54



IMAGES-3D
Version 3.0



SI = 22.7 KSI AT
STIFF/ND* JUNCTION



← UNLOADED AREA




Revision 0
Doc. No. Y049-1-022
Page 13 of 16

Load Case
2


Stress Contour Plot
Surf: Top
Stress Intensity

11/16/95
13: 1:10

IMAGES-3D
Version 3.0



MAXIMUM DISPLACEMENT
 AT MIDDLE HOLE G
 $D_1 = D_2 \approx .0914 \text{ IN}$
 RADIAL $\Delta = (.0914^2 + .0914^2)^{\frac{1}{2}}$
 $= .129 \text{ IN}$




Revision 0
 Doc. No. V049-1-022
 Page 14 of 16

Load Case
 3


Displacement Contour Plot
 D2

11/16/95
 13: 7:39

IMAGES-3D
Version 3.0



MAX SE AT
STIFF/NOZ JUNCTION
& AT JUNCTION ON
60 IN NOZ & STIFF
LEG REACTION IS
OUTWARD & ADJUSTED
VACUUM FORCES



Revision 0
Doc. No. V049-1-022
Page 15 of 16

CONFIRMATION OF NOZZLE G

NOZ G WRC 107 ANALYSIS FOR
RADIAL FORCE

$$F = 738.9 \text{ LB}$$

STRESS

$$\sigma = -2646 \text{ psi}$$

THE "COMPRESS" PRESSURE VESSEL
PROGRAM SHOWS THAT NO REINFORCEMENT
IS REQD.

SHELL THICKNESS = .5 IN


NOZZLE THICKNESS = .125 IN

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-023 PAGE 1 OF 19
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of 60 in. Access Covers	
0	0029	12/6/95	RDC	P.W.Y.		
					BY: R.D. CIATTO	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO:	
<p><u>PURPOSE:</u> To design the cover and nozzles for the 60 in. port in accordance with Section VIII, Division 1 of the ASME Code.</p>						
<p><u>METHOD:</u> Equations for thickness and reinforcement requirements of the ASME Code, Section VIII, Division 1, are evaluated using the COMPRESS computer program, Version 5.31.</p>						
<p><u>ASSUMPTIONS:</u></p>						
<p><u>INPUTS:</u> Vacuum pressure = 14.7 psi Design temperature = 400⁰F</p>						
<p><u>REFERENCES:</u> 1. ASME Boiler & Pressure Vessel Code, Section VIII, Pressure Vessels, Division 1. 2. COMPRESS 5.31, Computer Aided Pressure Vessel Design, Codeware Computer Systems, Inc. 3. Doc. No. V049-1-066, LIGO VACUUM EQUIP., STRUCTURAL DESIGN CRITERIA</p>						
<p><u>CALCULATIONS:</u> (SEE ATTACHED)</p>						
<p><u>CONCLUSIONS:</u> The requirements of the ASME Code, Section VIII, Division 1, are met for the cover and nozzles for the 60 in. port.</p>						
<p><u>NOTES:</u></p>						

NOZZLE LOCATIONS IN COMPRESS



N1 @ CENTER


N2 : $\theta = 42.90$

$$r = (10.625^2 + 9.875^2)^{\frac{1}{2}}$$

$$= 14.51$$

← 60 IN ACCESS COVER

$L = 14.53 - \gamma$



$$y = (60.25^2 - 14.51^2)^{\frac{1}{2}}$$

$$= 58.48 \text{ IN}$$

$$\gamma = 60.25 - 58.48$$

$$= 1.77$$

$L = 14.53 - 1.77$

$$= 12.76$$

N3 : $\theta = 90$

$r = 15.75$

$$y = (60.25^2 - 15.75^2)^{\frac{1}{2}}$$

$$= 58.15$$

$\gamma = 60.25 - 58.15 = 2.10$

$L = 14.53 - 2.10 = 12.43$

DUE TO OVERLAPPING REINFORCEMENT, NOZZLE LOCATIONS WERE MOVED AS SHOWN ON THE FOLLOWING SHEET.

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



60 IN PORT

G-NOZZLES IN 60 IN PORT

OD = 7.5 IN

WALL THICKNESS = .25 IN


FILLET WELD = .25

PARTIAL PEN GROOVE WELD = .1875

REINF. ROD = .73 IN²

" AREA = .83 IN² OR W/O PAD

LOCATE NOZZLES AS FOLLOWS



RADIAL PRESSURE LOAD FOR WAC
107 ANAL

$$F_R = \frac{\pi}{4} (7.5)^2 (14.7)$$

$$= 649.4 \text{ LB}$$

MAX STRESS AT OD OF NOZZLE

$$f = 2802 \text{ PSI FROM}$$

WAC 107 ANAL



BSC 60 in PortASME Section VIII Division 1, 1992 Edition, A93 Addenda

Component: F&D head
 Material specification: SA 240 304L HIGH
 External design pressure: $P_e = 14.7$ psi @ 400 deg F
 Corrosion allowance: Inner C = 0 Outer = 0 in

PWHT is not performed

Radiography: Category A joints - Spot UW-11(b) type 1
 Head to shell seam - Spot UW-11(b) type 1

Estimated weight: new = 272.9 corr = 272.9 lb
 capacity: new = 88.89 corr = 88.89 US ga

ID = 60.25 crown L = 60.25 knuckle r = 3.75 t = .25 in (min)

Straight flange = 1 forming allowance = 0 in

MAP: (New & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned}
 P &= 2 * S * E * t / (L * M + 0.2 * t) - P_s \\
 &= 2 * 16700 * 0.85 * 0.25 / (60.25 * 1.7521 + 0.2 * 0.25) - 0 \\
 &= 67.20225 \text{ psi}
 \end{aligned}$$

MAWP: (Corroded & at 0 deg F) Appendix 1-4(d) Eq 3

$$\begin{aligned}
 P &= 2 * S * E * t / (L * M + 0.2 * t) - P_s \\
 &= 2 * 16700 * 0.85 * 0.25 / (60.25 * 1.7521 + 0.2 * 0.25) - 0 \\
 &= 67.20225 \text{ psi}
 \end{aligned}$$

External Pressure: (Corroded & at 400 deg F) UG-33(e)

$$\begin{aligned}
 A &= .125 / (R_o / t) \\
 &= .125 / (60.5 / 0.18787) \\
 &= 0.000388
 \end{aligned}$$

From table HA-3: B = 4757.7

$$\begin{aligned}
 P_a &= B / (R_o / t) \\
 &= 4757.7 / (60.5 / 0.18787) \\
 &= 14.774 \text{ psi}
 \end{aligned}$$

Check the external pressure per UG-33(a)(1)

$$\begin{aligned}
 t &= 1.67 * P_a * L_o * M / (2 * S * E + 1.67 * P_a * (M - 0.2)) \\
 &= 1.67 * 14.774 * 60.5 * 1.7521 / (2 * 14700 * 1 + 1.67 * 14.774 * (1.7521 - 0.2)) \\
 &= 0.088842 \text{ in}
 \end{aligned}$$

Design thickness for external pressure $P_a = 14.774$ psi:

REV 0

Doc. No. 1049-1-023

Page 4 of 19

BSC 60 in Port

$$\begin{aligned} &= t + \text{Corrosion} + fa \\ &= 0.18787 + 0 + 0 \\ &= 0.18787 \text{ in} \end{aligned}$$

Maximum Allowable External Pressure: (Corroded @ 400 deg F)

$$\begin{aligned} A &= .125/(Ro/t) \\ &= .125/(60.5/0.25) \\ &= 0.000517 \end{aligned}$$

From table HA-3: $B = 5004.1$

$$\begin{aligned} Pa &= B/(Ro/t) \\ &= 5004.1/(60.5/0.25) \\ &= 20.6781 \text{ psi} \end{aligned}$$

Check the Maximum External Pressure: UG-33(a)(1) & App. 1-4(d)

$$\begin{aligned} Pe &= 2*S*E*t/((M*Lo - t*(M-0.2))*1.67) \\ &= 2*14700*1*0.25/((1.7521*60.5 - 0.25*(1.7521-0.2))*1.67) \\ &= 41.67247 \text{ psi} \end{aligned}$$

The maximum allowable external pressure is 20.6781 psi.

Rev 0

Doc. No. V049-1-023

Page 5 of 19


Center Nozzle n1

Opening n1 Reinforcement Calculations Per UG-37

Located on: BSC 60 in Port
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# SO A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 115 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 0 degrees
 End of nozzle to datum line: 14.53 in
 Nozzle calculated as hillside: no
 Projection outside vessel Lpr: 2.996 in



corrosion allow = 0 in
 noz thick new tn = .25 in
 nozzle id. new d = 7.5 in
 fillet weld tw1 = .25 in
 groove weld tw2 = .1875 in

To head center R = 0 in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.5$ in
 Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Nozzle required thickness

$$trn = \frac{P \cdot Rn}{Sn \cdot E - 0.6 \cdot P}$$

$$= \frac{0 \cdot 3.75}{16700 \cdot 1 - 0.6 \cdot 0}$$

$$= 0 \text{ in}$$

Required thickness tr from UG-37(a)(1)

$$tr = \frac{P \cdot L \cdot M}{2 \cdot S \cdot E - 0.2 \cdot P}$$

$$= \frac{0 \cdot 60.25 \cdot 1}{2 \cdot 16700 \cdot 1 - 0.2 \cdot 0}$$

$$= 0 \text{ in}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$

REV 0

Doc. No. V049-1-015

Page 6 of 19

Center Nozzle n1

$$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$$

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0*1 + 2*0.25*0*1*(1 - 1) \\ &= 0 \text{ in}^2 \end{aligned}$$

Area available

$$A1 = \text{larger of the following} \quad = 1.875 \text{ in}^2$$

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= 1.875 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= .25 \text{ in}^2 \end{aligned}$$

$$A2 = \text{smaller of the following} \quad = 0.313 \text{ in}^2$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.875 + 0.313 + 0.063 \\ &= 2.251 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 0 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

Rev 0
Doc. No. V049-1-023

Center Nozzle n1

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 16700 = 12358$ psi
 Nozzle wall in shear = $0.7 * 16700 = 11690$ psi
 Inner fillet weld in shear = $0.49 * 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 8 * 0.25 * 8183 = 25694.62$ lbf

(3) Nozzle wall in shear
 $(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 7.75 * 0.25 * 11690 = 35559.52$ lbf

(4) Groove weld in tension
 $(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 8 * 0.1875 * 12358 = 29103.09$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 * t_n) * (E_1 * t - F * t_r)) * S_v$
 $= (0 - (7.5 - 2 * 0.25) * (1 * 0.25 - 1 * 0)) * 16700$
 $= -29225$ lbf

$W_{1-1} = (A_2 + A_5 + A_{41} + A_{42}) * S_v$
 $= (0.313 + 0 + 0.063 + 0) * 16700$
 $= 6279.2$ lbf

$W_{2-2} = (A_2 + A_3 + A_{41} + A_{43} + 2 * t_n * t * f_{r1}) * S_v$
 $= (0.313 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700$
 $= 8366.7$ lbf

Load for path 1-1 lesser of W or W1-1 = -29225 lbf
 Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -29225 lbf
 Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.5 in

REV 0

Doc. No V049-1-023

Page 8 of 15

Center Nozzle n1

Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in
 Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Nozzle required thickness

$$L/Do = 2.996/8 = .3745 \quad Do/t = 8/0.0184 = 434.7826$$

$$\text{From table G:} \quad A = 0.000415$$

$$\text{From table HA-3:} \quad B = 4814.3$$

$$Pa = 4*B/(3*Do/t)$$

$$= 4*4814.3/(3*8/0.0184)$$

$$= 14.7639 \text{ psi}$$

Nozzle required thickness $trn = .0184$ in

Required thickness tr from UG-37(d)(1) = .1879 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$
 $fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$

$$A = 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1))$$

$$= 0.5*(7.5*0.1879*1 + 2*0.25*0.1879*1*(1 - 1))$$

$$= .7046 \text{ in}^2$$

Area available

$A1 = \text{larger of the following} = .466 \text{ in}^2$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$

$$= 7.5*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1)$$

$$= .466 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1)$$

$$= 2*(0.25+0.25)*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1)$$

$$= .062 \text{ in}^2$$

$A2 = \text{smaller of the following} = 0.289 \text{ in}^2$

$$= 5*(tn - trn)*fr2*t$$

$$= 5*(0.25 - 0.0184)*1*0.25$$

$$= .289 \text{ in}^2$$

$$= 5*(tn - trn)*fr2*tn$$

$$= 5*(0.25 - 0.0184)*1*0.25$$

$$= .289 \text{ in}^2$$

$$A41 = \text{Leg}^2*fr2$$

$$= 0.25^2*1 = .063 \text{ in}^2$$

REV 0

1049-1-023

Center Nozzle n1

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.466 + 0.289 + 0.063 \\ &= .818 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.0184 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0528 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

REV 0

Doc. No. V049-1-023

Page 10 OF 19

Center Nozzle n1Applied Loads

Radial load	$P_r = 649.4$ lbf
Circumferential moment	$M_1 = 0$ lbf-ft
Circumferential shear	$V_2 = 0$ lbf
Longitudinal moment	$M_2 = 0$ lbf-ft
Longitudinal shear	$V_1 = 0$ lbf
Torsion moment	$M_t = 0$ lbf-ft
Internal pressure	$P = 0$ psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean dish radius } R_m = 60.375 \text{ in}$$

$$U = r_o / \text{Sqr}(R_m * t) = 1.03$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.7

$$I = 1 + (r/x)^2$$

$$= 1 + (3.75/4.25)^2$$

$$= 1.779$$

$$\text{Local pressure stress} = I * P * R_m / 2 * t = 0 \text{ psi}$$

$$\text{Maximum combined stress} = -2802 \text{ psi}$$

$$\text{Allowable combined stress} = +3 * S = \pm 50100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -670 \text{ psi}$$

$$\text{Allowable primary membrane stress} = \pm 1.5 * S = \pm 25050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

Rev D

Doc. No. V049-1-023

Center Nozzle n1

From Fig.	Value read	Au	A1	Bu	B1	Cu	C1	Du	D1
SR-2*	0.0645	-670	-670	-670	-670	-670	-670	-670	-670
SR-2	0.0342	-2132	2132	-2132	2132	-2132	2132	-2132	2132
SR-3*	0.0750								
SR-3	0.0711								
SR-3*	0.0750								
SR-3	0.0711								
pressure stress*									
Total Ox stress Primary membrane Ox stress*		-2802	1462	-2802	1462	-2802	1462	-2802	1462
		-670	-670	-670	-670	-670	-670	-670	-670
SR-2*	0.0200	-208	-208	-208	-208	-208	-208	-208	-208
SR-2	0.0103	-642	642	-642	642	-642	642	-642	642
SR-3*	0.0226								
SR-3	0.0214								
SR-3*	0.0226								
SR-3	0.0214								
pressure stress*									
Total Oy stress Primary membrane Oy stress*		-850	434	-850	434	-850	434	-850	434
		-208	-208	-208	-208	-208	-208	-208	-208
torsion moment Mt Shear from V1 Shear from V2									
Total Shear stress									
Combined stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462

Rev 0

Doc. No V048-1-023


Nozzle n5

Opening n5 Reinforcement Calculations Per UG-37

Located on: BSC 60 in Port
 Local vessel thickness: .25 in
 Liquid static head included: 0 psi
 Flange description: 8 inch 75# WN A240304L
 ANSI B16.47 flange rating MAP: 115 psi
 ANSI B16.47 flange rating MAWP: 115 psi

Nozzle material specification: SA 240 304L HIGH

Nozzle orientation: 330 degrees
 End of nozzle to datum line: 13.76 in
 Nozzle calculated as hillside: no
 Projection outside vessel Lpr: 4.173 in



corrosion allow = 0 in
 noz thick new $t_n = .25$ in
 nozzle id. new $d = 7.5$ in
 fillet weld $tw_1 = .25$ in
 groove weld $tw_2 = .1875$ in

To head center $R = 15.75$ in

Reinforcement Calculations For Nozzle MAWP

Limits of reinforcement UG-40

Parallel to the vessel wall $d = 7.5$ in
 Normal to the vessel wall outside $2.5*(t_n - C_n) + t_e = .625$ in
 Normal to the vessel wall inside $2.5*(t_n - C_n - C) = .625$ in

Nozzle required thickness

$$t_{rn} = \frac{P \cdot R_n}{S_n \cdot E - 0.6 \cdot P}$$

$$= \frac{0 \cdot 3.75}{16700 \cdot 1 - 0.6 \cdot 0}$$

$$= 0 \text{ in}$$

Required thickness t_r from UG-37(a)(1)

$$t_r = \frac{P \cdot L \cdot M}{2 \cdot S \cdot E - 0.2 \cdot P}$$

$$= \frac{0 \cdot 60.25 \cdot 1}{2 \cdot 16700 \cdot 1 - 0.2 \cdot 0}$$

$$= 0 \text{ in}$$

Area required

Allowable stresses: $S_n = 16700$, $S_v = 16700$, psi
 $fr_1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr_1 = 1$

REV 0
Doc No V049-1-023
 Page 13 OF 19

Nozzle n5

fr2 = lesser of 1 or Sn/Sv so fr2 = 1

$$\begin{aligned} A &= d*tr*F + 2*tn*tr*F*(1 - fr1) \\ &= 7.5*0*1 + 2*0.25*0*1*(1 - 1) \\ &= 0 \text{ in}^2 \end{aligned}$$

Area available

A1 = larger of the following = 1.875 in²

$$\begin{aligned} &= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 7.5*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= 1.875 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ &= 2*(0.25+0.25)*(1*0.25-1*0) - 2*0.25*(1*0.25-1*0)*(1-1) \\ &= .25 \text{ in}^2 \end{aligned}$$

A2 = smaller of the following = 0.313 in²

$$\begin{aligned} &= 5*(tn - trn)*fr2*t \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} &= 5*(tn - trn)*fr2*tn \\ &= 5*(0.25 - 0)*1*0.25 \\ &= .313 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A41 &= \text{Leg}^2*fr2 \\ &= 0.25^2*1 = .063 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 1.875 + 0.313 + 0.063 \\ &= 2.251 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for MAWP = 0 at 0 Deg F

Check the welds - From UW-16(d):

$$\begin{aligned} t_{min} &= \text{lesser of } 0.75 \text{ or } t_n \text{ or } t, t_{min} = 0.25 \text{ in} \\ t1 \text{ or } t2(\text{min}) &= \text{lesser of } 0.25 \text{ or } 0.7*t_{min}, t1(\text{min}) = 0.175 \text{ in} \\ t1(\text{actual}) &= 0.7*\text{Leg} = 0.7*0.25 = 0.175 \text{ in} \\ t2(\text{actual}) &= 0.1875 \text{ in} \\ t1 + t2 &= 0.3625 \geq 1.25*t_{min} \end{aligned}$$

The weld sizes for t1 and t2 are satisfactory.

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0 in (E = 1)
Wall thickness per UG-45(b)(1):	tr2 = 0 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in

Rev 0

Doc. No V049-1-023

Nozzle n5

The greater of tr2 or tr3: tr5 = 0.0625 in
 The lesser of tr4 or tr5: tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for MAWP.

Allowable stresses in joints UG-45(c) and UW-15(c)

Groove weld in tension = $0.74 * 16700 = 12358$ psi
 Nozzle wall in shear = $0.7 * 16700 = 11690$ psi
 Inner fillet weld in shear = $0.49 * 16700 = 8183$ psi

Strength of welded joints:

(1) Inner fillet weld in shear
 $(\pi/2) * \text{Nozzle O.D.} * \text{Leg} * S_i = 1.57 * 8 * 0.25 * 8183 = 25694.62$ lbf

(3) Nozzle wall in shear
 $(\pi/2) * \text{Mean nozzle dia.} * t_n * S_n = 1.57 * 7.75 * 0.25 * 11690 = 35559.52$ lbf

(4) Groove weld in tension
 $(\pi/2) * \text{Nozzle O.D.} * t_w * S_g = 1.57 * 8 * 0.1875 * 12358 = 29103.09$ lbf

Loading on welds per UG-41(b)(1)

$W = (A - (d - 2 * t_n) * (E1 * t - F * tr)) * S_v$
 $= (0 - (7.5 - 2 * 0.25) * (1 * 0.25 - 1 * 0)) * 16700$
 $= -29225$ lbf

$W1-1 = (A2 + A5 + A41 + A42) * S_v$
 $= (0.313 + 0 + 0.063 + 0) * 16700$
 $= 6279.2$ lbf

$W2-2 = (A2 + A3 + A41 + A43 + 2 * t_n * t * fr1) * S_v$
 $= (0.313 + 0 + 0.063 + 0 + 2 * 0.25 * 0.25 * 1) * 16700$
 $= 8366.7$ lbf

Load for path 1-1 lesser of W or W1-1 = -29225 lbf
 Path 1-1 Thru (1) & (3) = $25694.62 + 35559.52 = 61254.14$ lbf
 Path 1-1 is stronger than W so it is acceptable per UG-41(b)(2).

Load for path 2-2 lesser of W or W2-2 = -29225 lbf
 Path 2-2 Thru (1), (4) = $25694.62 + 29103.09 = 54797.71$ lbf
 Path 2-2 is stronger than W so it is acceptable per UG-41(b)(2).

Reinforcement Calculations for External PressureLimits of reinforcement UG-40

Parallel to the vessel wall d = 7.5 in

Rev 0

Doc No V049-1-023
 Page 15 of 19

Nozzle n5

Normal to the vessel wall outside $2.5*(tn-Cn) + te = .625$ in

Normal to the vessel wall inside $2.5*(tn-Cn-C) = .625$ in

Nozzle required thickness

$$L/Do = 4.173/8 = .5216 \quad Do/t = 8/0.02022 = 395.6479$$

From table G:

$$A = 0.000332$$

From table HA-3:

$$B = 4394.8$$

$$Pa = 4*B/(3*Do/t) \\ = 4*4394.8/(3*8/0.02022) \\ = 14.8105 \text{ psi}$$

Nozzle required thickness $trn = .02022$ in

Required thickness tr from UG-37(d)(1) = .1879 in

Area required

Allowable stresses: $S_n = 14700$, $S_v = 14700$, psi

$fr1 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr1 = 1$

$fr2 = \text{lesser of } 1 \text{ or } S_n/S_v \text{ so } fr2 = 1$

$$A = 0.5*(d*tr*F + 2*tn*tr*F*(1 - fr1)) \\ = 0.5*(7.5*0.1879*1 + 2*0.25*0.1879*1*(1 - 1)) \\ = .7046 \text{ in}^2$$

Area available

$A1 = \text{larger of the following} = .466 \text{ in}^2$

$$= d*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ = 7.5*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1) \\ = .466 \text{ in}^2$$

$$= 2*(t+tn)*(E1*t-F*tr) - 2*tn*(E1*t-F*tr)*(1-fr1) \\ = 2*(0.25+0.25)*(1*0.25-1*0.1879) - 2*0.25*(1*0.25-1*0.1879)*(1-1) \\ = .062 \text{ in}^2$$

$A2 = \text{smaller of the following} = 0.287 \text{ in}^2$

$$= 5*(tn - trn)*fr2*t \\ = 5*(0.25 - 0.02022)*1*0.25 \\ = .287 \text{ in}^2$$

$$= 5*(tn - trn)*fr2*tn \\ = 5*(0.25 - 0.02022)*1*0.25 \\ = .287 \text{ in}^2$$

$$A41 = Leg^2*fr2 \\ = 0.25^2*1 = .063 \text{ in}^2$$

Rev 0

Doc No V049-1-023

Page 16 of 19

Nozzle n5

$$\begin{aligned} \text{Area} &= A1 + A2 + A41 \\ &= 0.466 + 0.287 + 0.063 \\ &= .816 \text{ in}^2 \end{aligned}$$

As Area > A the reinforcement is adequate for Pe = 14.7 at 400 Deg F

UG-45 Nozzle Neck Thickness Check

Wall thickness per UG-45(a):	tr1 = 0.02022 in (E = 1)
Wall thickness per UG-45(b)(2):	tr2 = 0.0528 in
Wall thickness per UG-16(b):	tr3 = 0.0625 in
Std pipe wall per UG-45(b)(4):	tr4 = 0.28175 in
The greater of tr2 or tr3:	tr5 = 0.0625 in
The lesser of tr4 or tr5:	tr6 = 0.0625 in

Req'd per UG-45 is the larger of tr1 or tr6 = 0.0625 in

Available nozzle wall thickness new, tn = 0.25 in

The nozzle neck thickness is adequate for Pe.

Rev 0

Doc No V049-1-023

Page 17 of 19

Nozzle n5Applied Loads

Radial load	Pr = 649.4 lbf
Circumferential moment	M1 = 0 lbf-ft
Circumferential shear	V2 = 0 lbf
Longitudinal moment	M2 = 0 lbf-ft
Longitudinal shear	V1 = 0 lbf
Torsion moment	Mt = 0 lbf-ft
Internal pressure	P = 0 psi

Stresses at the nozzle OD per WRC bulletin 107 (psi)

$$\text{Mean dish radius } R_m = 60.375 \text{ in}$$

$$U = r_0 / \text{Sqr}(R_m * t) = 1.03$$

$$\text{Stress concentration factor } K_n \text{ (tension)} = 1$$

$$\text{Stress concentration factor } K_b \text{ (bending)} = 1$$

Pressure stress intensity factor, Farr equation 11.7

$$I = 1 + (r/x)^2$$

$$= 1 + (3.75/4.25)^2$$

$$= 1.779$$

$$\text{Local pressure stress} = I * P * R_m / 2 * t = 0 \text{ psi}$$

$$\text{Maximum combined stress} = -2802 \text{ psi}$$

$$\text{Allowable combined stress} = +3 * S = \pm 50100 \text{ psi}$$

The maximum combined stress is within allowable limits.

$$\text{Maximum primary membrane stress} = -670 \text{ psi}$$

$$\text{Allowable primary membrane stress} = \pm 1.5 * S = \pm 25050 \text{ psi}$$

The maximum primary membrane stress is within allowable limits.

REV 0

Doc No. V044-1-023

Page 14 of 19








Nozzle n5

From Fig.	Value read	Au	A1	Bu	B1	Cu	C1	Du	D1
SR-2*	0.0645	-670	-670	-670	-670	-670	-670	-670	-670
SR-2	0.0342	-2132	2132	-2132	2132	-2132	2132	-2132	2132
SR-3*	0.0750								
SR-3	0.0711								
SR-3*	0.0750								
SR-3	0.0711								
pressure stress*									
Total Ox stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462
Primary membrane Ox stress*		-670	-670	-670	-670	-670	-670	-670	-670
SR-2*	0.0200	-208	-208	-208	-208	-208	-208	-208	-208
SR-2	0.0103	-642	642	-642	642	-642	642	-642	642
SR-3*	0.0226								
SR-3	0.0214								
SR-3*	0.0226								
SR-3	0.0214								
pressure stress*									
Total Oy stress		-850	434	-850	434	-850	434	-850	434
Primary membrane Oy stress*		-208	-208	-208	-208	-208	-208	-208	-208
torsion moment Mt									
Shear from V1									
Shear from V2									
Total Shear stress									
Combined stress		-2802	1462	-2802	1462	-2802	1462	-2802	1462

Rev 0
 1049-1-023
 Page 19 of 19

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-024 PAGE 1 OF 35
REV.	DEO #	DATE	BY:	CHECK	Beam Splitter Chamber - Design of Support Legs and Base Plates	
0	GJ28	12/29/91	RDC	AGL		
					BY: R.D. CLAYTON	DEPT.: 744
PROJECT: LIGO Vacuum Equipment					PROJECT NO: V59049	
PURPOSE: To design BSC support structure to meet requirements of AISC Code for unbalanced vacuum loads.						
METHOD: A stiffness analysis of the frame is performed using the IMAGES program.						
ASSUMPTIONS:						
INPUTS: 1. LIGO project design sketches & drawings. 2. Vacuum pressure = 14.7 psi. 3. Seismic acceleration = .05625 g. 4. Forces from V049-1-032						
REFERENCES: 1. AISC Code, Ninth Edition, Allowable Stress Design. 2. ASCE 7-88, Minimum Design Loads 3. IMAGES 3D, Version 3.0, R.L. Cloud & Associates 4. Calc. No. V049-1-032 "Component Interface Loads" <i>5. V049-1-026, LIGO VAC. EQUIP STRUCT. DES. CRITERIA</i>						
CALCULATIONS: (SEE ATTACHED)						
CONCLUSIONS: Support legs and other frame members meet the AISC Code.						
NOTES: Computer file is BSCSUPP. *					Revision No. 0 Doc. No. V049-1-024 Page 1 of 35	


SITE SKETCH ON
LATER SHEET FOR
W/110



Revision No. 0
Doc. No. V049-1-024
Page 2 of 35

PROPERTY AND DIMENSIONS		UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES		TOLERANCES		MATERIALS		PROCESS SYSTEMS INTERNATIONAL INC.	
REV.	DESCRIPTION	REV.	DESCRIPTION	FINISH	FUNCTIONAL	FINISH	FUNCTIONAL	CHAMBER SUPPORT ASSEMBLY	BY WARDUP DR. 425 BROADWAY, MASSACHUSETTS 02127 USA
BVC 44	DESCRIPTION	BVC 44	DESCRIPTION	AS SUPPLIED	AS SUPPLIED	303 STAINLESS STEEL	303 STAINLESS STEEL	BSC	REV. 0
	REFERENCE DRAWINGS							LIGO VACUUM EQUIPMENT	P3
				DO NOT SCALE THIS DRAWING	PL	PRELIMINARY FOR QUOTES	CHD	DATE	SCALE
				USER OR	REV	DESCRIPTION	CHD	DATE	SCALE
				NEXT ASSY		ISSUE DESCRIPTION	CHD	DATE	SCALE

BASE PLATE




14125. HVA ADHESIVE ANCHORS
1" Ø , 8 1/4" EMBEDMENT
A307 (OR EQUIV) TYPED ROD

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



IMAGES-3D
 Ver. 3.0
 Geometry Plot

IMAGES 3D MODEL
BSC SUPPORT STRUCTURE



Beam Splitter Chamber Support Structure
 Wireframe Plot

12/28/95
 12:58:58

===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

SOLVE BEAM LOADS/STRESSES

Version 3.0

12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Load Case 1:MAXIMUM UNBALANCED LOADS COMBINED WITH DEAD WT + EQ(.056G)

BEAM LOADS AND/OR STRESSES

GLoads	Node	Fx	Fy	Fz	Mx	My	Mz
LLoads	Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
Stress	Node	Axial	Y-Shear	Z-Shear	Torsion	Y-Bending	Z-Bending
		Corner1	Corner2	Corner3	Corner4	Maximum	Minimum
BEAM NO. 1							
GLoads	16	-.1840E+05	-.3504E+04	-.1547E+05	.1393E+06	.4803E-11	-.1656E+06
GLoads	2	.1840E+05	.3504E+04	.1547E+05	-.2785E+06	-.4803E-11	.3313E+06
LLoads	16	-.3504E+04	.2395E+05	.2072E+04	.4803E-11	.1865E+05	-.2156E+06
LLoads	2	.3504E+04	-.2395E+05	-.2072E+04	-.4803E-11	-.3730E+05	.4312E+06
Stress	16	.2014E+03	.3201E+04	.2769E+03	-.7064E-13	.4876E+03	.5636E+04
		-.4947E+04	.6325E+04	.5350E+04	-.5923E+04	.6325E+04	-.5923E+04
Stress	2	.2014E+03	.3201E+04	.2769E+03	-.7064E-13	.9752E+03	.1127E+05
		-.1010E+05	.1245E+05	.1050E+05	-.1205E+05	.1245E+05	-.1205E+05
BEAM NO. 2							
GLoads	2	-.1016E+05	-.2198E+03	-.6706E+04	.4805E+05	.0000E+00	.4180E+05
GLoads	3	.1016E+05	.2198E+03	.6706E+04	-.2224E+06	.0000E+00	.2224E+06
LLoads	2	-.2198E+03	.1193E+05	.2444E+04	.0000E+00	-.6353E+05	-.4415E+04
LLoads	3	.2198E+03	-.1193E+05	-.2444E+04	.0000E+00	.0000E+00	.3145E+06
Stress	2	.1263E+02	.1594E+04	.3265E+03	.0000E+00	-.1661E+04	.1154E+03
		-.1764E+04	-.1533E+04	.1789E+04	.1558E+04	.1789E+04	-.1764E+04
Stress	3	.1263E+02	.1594E+04	.3265E+03	.0000E+00	.0000E+00	.8223E+04
		-.8211E+04	.8236E+04	.8236E+04	-.8211E+04	.8236E+04	-.8211E+04
BEAM NO. 3							
GLoads	17	-.5751E+04	.3504E+05	.2574E+04	-.2317E+05	.9770E-13	-.5176E+05
GLoads	5	.5751E+04	-.3504E+05	-.2574E+04	.4633E+05	-.9770E-13	.1035E+06
LLoads	17	.3504E+05	-.5886E+04	.2246E+04	.9770E-13	.2022E+05	.5298E+05
LLoads	5	-.3504E+05	.5886E+04	-.2246E+04	-.9770E-13	-.4043E+05	-.1060E+06
Stress	17	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.5285E+03	-.1385E+04
		-.1001E+03	-.2870E+04	-.3927E+04	-.1157E+04	-.1001E+03	-.3927E+04
Stress	5	-.2014E+04	-.7866E+03	.3002E+03	-.1437E-14	.1057E+04	-.2770E+04
		.1813E+04	-.3727E+04	-.5841E+04	-.3006E+03	.1813E+04	-.5841E+04
BEAM NO. 4							
GLoads	5	-.1399E+05	.2025E+05	-.9445E+04	-.3035E+06	.0000E+00	.3059E+06
GLoads	6	.1399E+05	-.2025E+05	.9445E+04	.5790E+05	.0000E+00	.5790E+05
LLoads	5	.2025E+05	-.3215E+04	.1657E+05	.0000E+00	-.4309E+06	-.1715E+04
LLoads	6	-.2025E+05	.3215E+04	-.1657E+05	.0000E+00	.0000E+00	-.8188E+05
Stress	5	-.1164E+04	-.4297E+03	.2215E+04	.0000E+00	-.1127E+05	.4484E+02
		-.1247E+05	-.1238E+05	.1015E+05	.1006E+05	.1015E+05	-.1247E+05
Stress	6	-.1164E+04	-.4297E+03	.2215E+04	.0000E+00	.0000E+00	-.2141E+04
		.9770E+03	-.3304E+04	-.3304E+04	.9770E+03	.9770E+03	-.3304E+04

LOADS

ESTIMATED WEIGHT

$$W = 14000 \text{ LB}$$

SEISMIC FORCE

$$F_{EQ} = a W$$

$$a = .05625 \text{ g} - \text{REF CALC V049-1-031}$$

$$F_{EQ} = .05625 (14000) \\ = 788 \text{ LB}$$

UNBALANCED VACUUM LOADS

FROM CALC V049-1-032, BSCS 7 3 8
IN THE WALLS HAVE THE MAX UNBALANCED
FORCES. LET $F_x = 45460 \text{ LB}$

$$F_z = 29440 \text{ LB}$$

COMINE SEISMIC w/ F_x UNBALANCED LOAD

$$\text{NODE 15: } F_y = 45460 + 788 = 46248 \text{ LB}$$

$$\text{NODE 15: } F_y = -W = -14000 \text{ LB}$$


$$\text{NODE 21: } F_z = 29440 \text{ LB}$$

22-141 50 SHEETS
22-122 100 SHEETS
22-146 200 SHEETS



DETERMINE IF CROSS MEMBER WILL CLEAR HEAD

LOWEST PT AT CENTER OF BOTTOM HEAD IS 15 IN ABOVE FLOOR, & OF COLUMN IS 42 IN FROM BEAM TUBE AXIS. CROWN RADIUS OF LOWER HEAD IS 105.375



$$\tan \theta = \frac{42}{105.375}$$

$$\theta = 23.49^\circ$$

$$S = 105.375 - 105.375 \cos \theta$$

$$= 8.73 \text{ IN}$$

OR FOR 6 IN DEEP MEMBER

HEIGHT OF CROSS MEMBER ABOVE FLOOR


$$h = 15 + \frac{6}{2}$$

$$= 18 \text{ IN TO } \phi \text{ OF TS } 6 \times 4 \times \frac{1}{4}$$

USE TS 7x4x3/8

TOTAL CLEARANCE FROM FLOOR =

$$15 + 8.73 = 23.73 \text{ IN}$$



MEMBERS

1 TO 8	}	TS 8x4x 5/8
17 TO 20		
9 TO 12		TS 8x4x 1/2
13 TO 16		DUMMY

PIN TYPE SUPPORTS AT NOSES 1, 4, 7, 10


PIN RELEASE AT TOP OF 8x4x5/8 TUBE STEEL SUPPORT LEG

SINCE THE SHELL IS FLEXIBLE FOR LOCAL BENDING AT SUPPORT LEG ATTACHMENT, THE FOLLOWING LOCAL MOMENTS ARE RELEASED:

M_x (PIN RELEASE 4 - TORSION IN W8x58)

M_y (" " 5 - WEAK AXIS BENDING IN W8x58)

M_z IS RETAINED SINCE IT TRANSFERS MEMBRANE FORCES INTO SHELL



x, y, z ARE LOCAL AXES OF SUPPORT LEG



```
===== I M A G E S - 3 D =====  
= Copyright (c) 1984-1993.   RLCA/Celestial Software =  
=====
```

Interactive Microcomputer Analysis & Graphics of Engineering Systems

```
IMAGES-3D           Version 3.0           12/31/93
```

```
Filename=BSCSUPP           RUN ID=XX11111
```

```
=====  
=                               NOTICE                               =  
-----  
=   RLCA/Celestial Software assumes no responsi-   =  
=   bility for the validity, accuracy, or         =  
=   applicability of the results obtained from    =  
=   IMAGES-3D.                                     =  
=====
```

```
=====  
=   Any questions or comments concerning the use   =  
=   of IMAGES-3D or the users manual should       =  
=   be addressed to:                               =  
=   =  
=   RLCA/Celestial Software                         =  
=   2150 Shattuck Ave.                             =  
=   Suite 1200                                       =  
=   Berkeley, CA                                    =  
=   94704                                           =  
=   =  
=   510-843-0977                                    =  
=====
```


===== I M A G E S - 3 D =====
 = Copyright (c) 1984-1993. RLCA/Celestial Software =
 =====

CHECK GEOMETRY Version 3.0 12/31/93

Filename=BSCSUPP

Title =Beam Splitter Chamber Support Structure

Acceleration of Gravity = 3.864E+02

Force Multiplier	Length Multiplier	Temp. Multiplier
1.0000E+00	1.0000E+00	1.0000E+00
(For database properties only)		

MATERIAL PROPERTIES

Mat No.	N a m e
1	STEEL
2	STEEL
3	STEEL

Mat No	Ex Gxy	Ey Gyz	Ez Gzx	nxy axy	nyz ayz	nxz azx	Density
1	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	
2	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	
3	2.900E+07	2.900E+07	2.900E+07	3.000E-01	3.000E-01	3.000E-01	2.830E-01
	1.120E+07	1.120E+07	1.120E+07	6.500E-06	6.500E-06	6.500E-06	

BEAM CROSS SECTION PROPERTIES

Prop No.	N a m e
1	W8X58
2	TB4X4X4
4	TB8X4X8
5	TB8X8X10

Pr. No.	X-Section Area	Moment of Inertia Iy	of Inertia / Iz	Torsional Const.- J	Iyz	Shear Shape Fact. SFy	/ SFz
1	1.710E+01	7.510E+01	2.280E+02	3.340E+00	0.000E+00	3.83E+00	1.28E+00
2	3.590E+00	8.220E+00	8.220E+00	1.350E+01	0.000E+00	1.79E+00	1.79E+00
3	1.000E+02	1.000E+03	1.000E+03	2.000E+03	0.000E+00	0.00E+00	0.00E+00
4	1.040E+01	2.460E+01	7.510E+01	6.410E+01	0.000E+00	1.30E+00	2.60E+00
5	1.740E+01	1.530E+02	1.530E+02	2.580E+02	0.000E+00	1.74E+00	1.74E+00