



*LIGO Laboratory / LIGO Scientific Collaboration*

LIGO-E1100519-v1

*LIGO*

6/8/11

---

Test Procedure for Test Oscillator Boxes.

---

Paul Schwinberg and Daniel Sigg

Distribution of this document:  
LIGO Scientific Collaboration

This is an internal working note  
of the LIGO Laboratory.

**California Institute of Technology**  
**LIGO Project – MS 18-34**  
**1200 E. California Blvd.**  
**Pasadena, CA 91125**  
Phone (626) 395-2129  
Fax (626) 304-9834  
E-mail: [info@ligo.caltech.edu](mailto:info@ligo.caltech.edu)

**Massachusetts Institute of Technology**  
**LIGO Project – NW22-295**  
**185 Albany St**  
**Cambridge, MA 02139**  
Phone (617) 253-4824  
Fax (617) 253-7014  
E-mail: [info@ligo.mit.edu](mailto:info@ligo.mit.edu)

**LIGO Hanford Observatory**  
**P.O. Box 159**  
**Richland WA 99352**  
Phone 509-372-8106  
Fax 509-372-8137

**LIGO Livingston Observatory**  
**P.O. Box 940**  
**Livingston, LA 70754**  
Phone 225-686-3100  
Fax 225-686-7189

<http://www.ligo.caltech.edu/>

## 1 Introduction

The following Test Procedure describes the test of proper operation of the Test Oscillator Boxes.

s/n S1103738

Tested by PBS

## 2 Test Equipment

- Voltmeter
- Oscilloscope
- Stanford Research SR785 analyzer
- RF Power Meter HP E4418A or Agilent N1914A
- Board Schematics—D1100663

## 3 Tests

*The Test Oscillators use the Low Noise Power Module (D0901846-D).*

- 1) Verify the proper current draw.** Using a bench DC supply apply +/- 24Volts to P7 and +/- 17 Volts to P6 of the low noise power Module (D0901846-D). Measure the current draw of the board.

+24 Volt current 0.1 A Nom.                      -24 Volt current 0.0 A Nom.

+17 Volt current 1.41A                      less than 1.1 A

-17 Volt current 0.055A                      less than 0.01 A

- 2) On the low noise power module check the voltage on TP 1-13.**

TP1 (+17V) 22.4V                      TP2 (-17V) -23V

TP3 , 4 ( GND )                      TP5 (+ 5V) 5.04V

TP6 (-15V ) \_\_\_ -14.98V\_\_\_                      TP7 (+24V ) \_\_\_ 22.41V\_\_\_\_\_

TP8 ( GND )    TP9 ( -24V ) \_\_\_ -23.0V\_\_\_\_\_

TP10 ( GND )    TP11 (+15V ) \_\_\_ 14.98V\_\_\_\_\_

TP12 (+VREF ) \_\_\_ 9.988V\_\_\_\_\_                      TP13 (-VREF) \_-9.988V\_\_\_\_\_

**3) If TP 1 , 2 , 7 , 9 and 8 are correct then TP14 ( OK ) should be Logic high ~3Volts.      Confirm. \_\_\_ X\_\_\_\_\_**

**4) The noise on TP 12, 13, 11 and 6 should be measured with a SR785 using an rms power spectrum.**

TP12 noise \_\_\_ 6.229 nVrms/sqrt Hz\_\_\_\_\_ less than 20 nVrms/sqrt Hz at 140 Hz

TP13 noise \_\_\_ 11.6 nVrms/sqrt Hz\_\_\_\_\_ less than 20 nVrms/sqrt Hz at 140 Hz

TP11 noise \_\_\_ 11.43 nVrms/sqrt Hz\_\_\_\_\_ less than 20 nVrms/sqrt Hz at 140 Hz

TP6 noise \_\_\_ 16.44 nVrms/sqrt Hz\_\_\_\_\_ \_ less than 30 nVrms/sqrt Hz at 140 Hz.

This concludes the test of the power supply. Now test the crystal oscillators.

**5) With the frequency control input grounded measure the RF output with a RF Power meter. The nominal output level is 12 dBm +/- 2dBm.**

RF Output levels (dBm)

OSC1	OSC2	OSC3	OSC4
11.71	11.44	11.50	11.48

5) **Apply a dc voltage to the frequency control input.** Measure the output frequency as a function of input voltage. The frequency change is typically 50 ppm for +/- 10 volt input.

Oscillator 1 frequency change for 10 Volt input change \_\_\_\_\_ ppm

Oscillator 2 frequency change for 10 Volt input change \_\_\_\_\_ ppm.

Oscillator 3 frequency change for 10 Volt input change \_\_\_\_\_ ppm.

Oscillator 4 frequency change for 10 Volt input change \_\_\_\_\_ ppm

Oscillator 1, Center Frequency = 9.099 476 MHz

Frequency	9471	9472	9472	9473	9473
Voltage	10	9	8	7	6
Voltage	1	2	3	4	5
Frequency	9476	9475	9475	9474	9474
Frequency	9477	9477	9478	9478	9479
Voltage	-1	-2	-3	-4	-5
Voltage	-10	-9	-8	-7	-6
Frequency	9481	9481	9480	9480	9479

Oscillator 2, Center Frequency = 24.078 817 MHz

Frequency	6295	6697	7059	7380	7658
Voltage	10	9	8	7	6
Voltage	1	2	3	4	5
Frequency	8666	8487	8278	8045	7872
Frequency	8945	9053	9144	9221	9285
Voltage	-1	-2	-3	-4	-5
Voltage	-10	-9	-8	-7	-6
Frequency	9491	9461	9426	9386	9340

Oscillator 3, Center Frequency = 24.407 630MHz

Frequency	5814	6047	6271	6486	6692
Voltage	10	9	8	7	6
Voltage	1	2	3	4	5
Frequency	7516	7384	7234	7068	6887
Frequency	7728	7810	7878	7933	7980
Voltage	-1	-2	-3	-4	-5
Voltage	-10	-9	-8	-7	-6
Frequency	8187	8154	8117	8074	8027

Oscillator 4, Center Frequency = 24.441 427 MHz

Frequency	9240	9529	9794	0049	0299
Voltage	10	9	8	7	6
Voltage	1	2	3	4	5
Frequency	1301	1153	0976	0770	0541
Frequency	1545	1648	1731	1798	1852
Voltage	-1	-2	-3	-4	-5
Voltage	-10	-9	-8	-7	-6
Frequency	2019	1994	1966	1934	1896



